



Length of time water remained in pipes before sampled (hours)
Report based on lab results dated
Date of test
Water last used (Time and date)

13.00
5/10/16
05/31/16
Approx 4 PM 5/16/16

[illegible]

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/l

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit
BA-Below EPA Action Level of 15 ppb
AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations