



School Lead Water Testing - Data Collection Form

School Short Name **Henry**

Length of time water remained in pipes before sampled (hours)

13.00

Report based on lab results dated

6/13/16

Date of test

06/01/16

Water last used (Time and date)

Approx 4 PM 5/31/16

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
51016-B-N-CS01-001	Main- N. Basement Kitchen cooking sink	6/1/16 5:00 AM	0.336	BA
51016-B-N-CS01-002	Main- N. Basement Kitchen cooking sink	6/1/16 5:00 AM	0.151	BA
51016-B-N-CS01-003	Main- N. Basement Kitchen cooking sink	6/1/16 5:00 AM	0.404	BA
51016-B-N-CS01-004	Main- N. Basement Kitchen cooking sink	6/1/16 5:00 AM	0.484	BA
51016-B-N-CS01-005	Main- N. Basement Kitchen cooking sink	6/1/16 5:00 AM	0.521	BA
51016-B-SW-F02-001	Main- Basement SW Lunchroom Fountain	6/1/16 5:00 AM	0.809	BA
51016-B-SW-F02-002	Main- Basement SW Lunchroom Fountain	6/1/16 5:00 AM	0.869	BA
51016-B-SW-F02-003	Main- Basement SW Lunchroom Fountain	6/1/16 5:00 AM	0.909	BA
51016-B-SW-F02-004	Main- Basement SW Lunchroom Fountain	6/1/16 5:00 AM	0.767	BA
51016-B-SW-F02-005	Main- Basement SW Lunchroom Fountain	6/1/16 5:00 AM	0.772	BA
51016-B-NW-F03-001	Main- Second Basement SW Lunchroom Fountain	6/1/16 5:00 AM	0.793	BA
51016-B-NW-F03-002	Main- Second Basement SW Lunchroom Fountain	6/1/16 5:00 AM	0.456	BA
51016-B-NW-F03-003	Main- Second Basement SW Lunchroom Fountain	6/1/16 5:00 AM	0.455	BA
51016-B-NW-F03-004	Main- Second Basement SW Lunchroom Fountain	6/1/16 5:00 AM	0.43	BA
51016-B-NW-F03-005	Main- Second Basement SW Lunchroom Fountain	6/1/16 5:00 AM	0.428	BA
51016-B-SW-F04-001	Main- Basement N. Lunchroom Fountain	6/1/16 5:00 AM	0.426	BA
51016-B-SW-F04-002	Main- Basement N. Lunchroom Fountain	6/1/16 5:00 AM	0.383	BA
51016-B-SW-F04-003	Main- Basement N. Lunchroom Fountain	6/1/16 5:00 AM	0.387	BA
51016-B-SW-F04-004	Main- Basement N. Lunchroom Fountain	6/1/16 5:00 AM	0.37	BA
51016-B-SW-F04-005	Main- Basement N. Lunchroom Fountain	6/1/16 5:00 AM	0.347	BA
51016-B-NW-F05-001	Main- Basement W. Lunchroom Fountain	6/1/16 5:00 AM	0.384	BA
51016-B-NW-F05-002	Main- Basement W. Lunchroom Fountain	6/1/16 5:00 AM	0.44	BA
51016-B-NW-F05-003	Main- Basement W. Lunchroom Fountain	6/1/16 5:00 AM	0.358	BA
51016-B-NW-F05-004	Main- Basement W. Lunchroom Fountain	6/1/16 5:00 AM	0.355	BA
51016-B-NW-F05-005	Main- Basement W. Lunchroom Fountain	6/1/16 5:00 AM	0.367	BA
51016-1-N-F01-001	Main- N. 1st floor hallway by Main Office	6/1/16 5:00 AM	1.83	BA
51016-1-N-F01-002	Main- N. 1st floor hallway by Main Office	6/1/16 5:00 AM	1.73	BA
51016-1-N-F01-003	Main- N. 1st floor hallway by Main Office	6/1/16 5:00 AM	1.44	BA
51016-1-N-F01-004	Main- N. 1st floor hallway by Main Office	6/1/16 5:00 AM	1.37	BA
51016-1-N-F01-005	Main- N. 1st floor hallway by Main Office	6/1/16 5:00 AM	0.966	BA
51016-1-S-F02-001	Main- S. 1st floor hallway by Main Office	6/1/16 5:00 AM	0.964	BA
51016-1-S-F02-002	Main- S. 1st floor hallway by Main Office	6/1/16 5:00 AM	0.902	BA
51016-1-S-F02-003	Main- S. 1st floor hallway by Main Office	6/1/16 5:00 AM	0.657	BA
51016-1-S-F02-004	Main- S. 1st floor hallway by Main Office	6/1/16 5:00 AM	<0.120	ND
51016-1-S-F02-005	Main- S. 1st floor hallway by Main Office	6/1/16 5:00 AM	<0.120	ND
51016-2-N-F01-001	Main- N. 2nd floor hallway by room 206	6/1/16 5:00 AM	<0.120	ND
51016-2-N-F01-002	Main- N. 2nd floor hallway by room 206	6/1/16 5:00 AM	<0.120	ND
51016-2-N-F01-003	Main- N. 2nd floor hallway by room 206	6/1/16 5:00 AM	<0.120	ND
51016-2-N-F01-004	Main- N. 2nd floor hallway by room 206	6/1/16 5:00 AM	0.78	BA
51016-2-N-F01-005	Main- N. 2nd floor hallway by room 206	6/1/16 5:00 AM	0.685	BA
51016-2-S-F02-001	Main- S. 2nd floor hallway by room 206	6/1/16 5:00 AM	0.896	BA
51016-2-S-F02-002	Main- S. 2nd floor hallway by room 206	6/1/16 5:00 AM	0.914	BA
51016-2-S-F02-003	Main- S. 2nd floor hallway by room 206	6/1/16 5:00 AM	1.01	BA
51016-2-S-F02-004	Main- S. 2nd floor hallway by room 206	6/1/16 5:00 AM	1.03	BA
51016-2-S-F02-005	Main- S. 2nd floor hallway by room 206	6/1/16 5:00 AM	0.657	BA
51016-3-N-F01-001	Main- N. 3rd floor hallway between rooms 306 & 304	6/1/16 5:00 AM	0.804	BA
51016-3-N-F01-002	Main- N. 3rd floor hallway between rooms 306 & 304	6/1/16 5:00 AM	0.959	BA
51016-3-N-F01-003	Main- N. 3rd floor hallway between rooms 306 & 304	6/1/16 5:00 AM	1.17	BA
51016-3-N-F01-004	Main- N. 3rd floor hallway between rooms 306 & 304	6/1/16 5:00 AM	1.13	BA
51016-3-N-F01-005	Main- N. 3rd floor hallway between rooms 306 & 304	6/1/16 5:00 AM	1.13	BA
51016-1-N-F01-001	Annex-N. 1st floor hallway by girls toilets	6/1/16 5:00 AM	<0.120	ND
51016-1-N-F01-002	Annex-N. 1st floor hallway by girls toilets	6/1/16 5:00 AM	<0.120	ND
51016-1-N-F01-003	Annex-N. 1st floor hallway by girls toilets	6/1/16 5:00 AM	<0.120	ND
51016-1-N-F01-004	Annex-N. 1st floor hallway by girls toilets	6/1/16 5:00 AM	<0.120	ND
51016-1-N-F01-005	Annex-N. 1st floor hallway by girls toilets	6/1/16 5:00 AM	<0.120	ND
51016-1-S-F02-001	Annex-S. 1st floor hallway by girls toilets	6/1/16 5:00 AM	<0.120	ND
51016-1-S-F02-002	Annex-S. 1st floor hallway by girls toilets	6/1/16 5:00 AM	<0.120	ND
51016-1-S-F02-003	Annex-S. 1st floor hallway by girls toilets	6/1/16 5:00 AM	<0.120	ND
51016-1-S-F02-004	Annex-S. 1st floor hallway by girls toilets	6/1/16 5:00 AM	<0.120	ND
51016-1-S-F02-005	Annex-S. 1st floor hallway by girls toilets	6/1/16 5:00 AM	<0.120	ND

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit

BA-Below EPA Action Level of 15 ppb

AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations