



School Lead Water Testing Summary

School Short Name Jungman
Address 1746 S Miller
Facility ID 51242
CPS Team Member Prins Sales
MEC Team Member Roxana Ordóñez

Length of time water remained in pipes before sampled Approx 8-9 hours
Water last used (Time and date) Approx 10 PM 5/9/16
Date of test 5/10/2016
Report based on lab results dated 5/19/2016

Sample ID #	Sample Location	Sample Collection Time & Date	Test Results (ppb)	ppb Level
51242-B-F-CS-01	Kitchen	6:10 AM 5/10/16	ND	-
51242-B-E-WC-02	Hallway by SE Stairwell	6:22 AM 5/10/16	ND	-
51242-1-W-WC-03	Hallway by Room 102	6:26 AM 5/10/16	ND	-
51242-2-E-F-04	Hallway by Room 205	6:31 AM 5/10/16	ND	-
51242-3-W-WC-05	Hallway by Room 302	6:35 AM 5/10/16	ND	-

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit
BA-Below EPA Action Level of 15 ppb
AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations