



School Lead Water Testing - Data Collection Form

School Short Name **Hanson Park**

Length of time water remained in pipes before sampled (hours)

13.00

Report based on lab results dated

5/31/16

Date of test

05/26/16

Water last used (Time and date)

Approx 4 PM 5/25/16

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
24461-1-N-F01-001	Pod F across from boys toilet, Fountain	5/26/16 5:00AM	ND	ND
24461-1-N-F01-002	Pod F across from boys toilet, Fountain	5/26/16 5:00AM	ND	ND
24461-1-N-F01-003	Pod F across from boys toilet, Fountain	5/26/16 5:00AM	ND	ND
24461-1-N-F01-004	Pod F across from boys toilet, Fountain	5/26/16 5:00AM	ND	ND
24461-1-N-F01-005	Pod F across from boys toilet, Fountain	5/26/16 5:00AM	ND	ND
24461-1-N-F02-001	Pod E across from girls toilet, Fountain	5/26/16 5:00AM	ND	ND
24461-1-N-F02-002	Pod E across from girls toilet, Fountain	5/26/16 5:00AM	ND	ND
24461-1-N-F02-003	Pod E across from girls toilet, Fountain	5/26/16 5:00AM	ND	ND
24461-1-N-F02-004	Pod E across from girls toilet, Fountain	5/26/16 5:00AM	ND	ND
24461-1-N-F02-005	Pod E across from girls toilet, Fountain	5/26/16 5:00AM	ND	ND
24461-1-E-F03-001	Hallway across from Room 122, East Fountain 1	5/26/16 5:00AM	ND	ND
24461-1-E-F03-002	Hallway across from Room 122, East Fountain 1	5/26/16 5:00AM	ND	ND
24461-1-E-F03-003	Hallway across from Room 122, East Fountain 1	5/26/16 5:00AM	ND	ND
24461-1-E-F03-004	Hallway across from Room 122, East Fountain 1	5/26/16 5:00AM	ND	ND
24461-1-E-F03-005	Hallway across from Room 122, East Fountain 1	5/26/16 5:00AM	ND	ND
24461-1-E-F04-001	Hallway across from Room 122, East Fountain 2	5/26/16 5:00AM	ND	ND
24461-1-E-F04-002	Hallway across from Room 122, East Fountain 2	5/26/16 5:00AM	ND	ND
24461-1-E-F04-003	Hallway across from Room 122, East Fountain 2	5/26/16 5:00AM	ND	ND
24461-1-E-F04-004	Hallway across from Room 122, East Fountain 2	5/26/16 5:00AM	ND	ND
24461-1-E-F04-005	Hallway across from Room 122, East Fountain 2	5/26/16 5:00AM	ND	ND
24461-1-E-F05-001	Hallway across from Room 122, East Fountain 3	5/26/16 5:00AM	ND	ND
24461-1-E-F05-002	Hallway across from Room 122, East Fountain 3	5/26/16 5:00AM	ND	ND
24461-1-E-F05-003	Hallway across from Room 122, East Fountain 3	5/26/16 5:00AM	ND	ND
24461-1-E-F05-004	Hallway across from Room 122, East Fountain 3	5/26/16 5:00AM	ND	ND
24461-1-E-F05-005	Hallway across from Room 122, East Fountain 3	5/26/16 5:00AM	ND	ND
24461-1-E-F06-001	Hallway across from Room 122, East Fountain 4	5/26/16 5:00AM	ND	ND
24461-1-E-F06-002	Hallway across from Room 122, East Fountain 4	5/26/16 5:00AM	ND	ND
24461-1-E-F06-003	Hallway across from Room 122, East Fountain 4	5/26/16 5:00AM	ND	ND
24461-1-E-F06-004	Hallway across from Room 122, East Fountain 4	5/26/16 5:00AM	ND	ND
24461-1-E-F06-005	Hallway across from Room 122, East Fountain 4	5/26/16 5:00AM	ND	ND
24461-1-N-S07-001	Kitchen, Sink	5/26/16 5:00AM	ND	ND
24461-1-N-S07-002	Kitchen, Sink	5/26/16 5:00AM	ND	ND
24461-1-N-S07-003	Kitchen, Sink	5/26/16 5:00AM	ND	ND
24461-1-N-S07-004	Kitchen, Sink	5/26/16 5:00AM	ND	ND
24461-1-N-S07-005	Kitchen, Sink	5/26/16 5:00AM	ND	ND
24461-1-S-F08-001	Pod C across bathrooms, Fountain	5/26/16 5:00AM	ND	ND
24461-1-S-F08-002	Pod C across bathrooms, Fountain	5/26/16 5:00AM	ND	ND
24461-1-S-F08-003	Pod C across bathrooms, Fountain	5/26/16 5:00AM	ND	ND
24461-1-S-F08-004	Pod C across bathrooms, Fountain	5/26/16 5:00AM	ND	ND
24461-1-S-F08-005	Pod C across bathrooms, Fountain	5/26/16 5:00AM	ND	ND
24461-1-S-F09-001	Pod B across bathrooms, Fountain	5/26/16 5:00AM	ND	ND
24461-1-S-F09-002	Pod B across bathrooms, Fountain	5/26/16 5:00AM	ND	ND
24461-1-S-F09-003	Pod B across bathrooms, Fountain	5/26/16 5:00AM	ND	ND
24461-1-S-F09-004	Pod B across bathrooms, Fountain	5/26/16 5:00AM	ND	ND
24461-1-S-F09-005	Pod B across bathrooms, Fountain	5/26/16 5:00AM	ND	ND
24461-1-S-F10-001	Pod A across bathrooms, Fountain	5/26/16 5:00AM	ND	ND
24461-1-S-F10-002	Pod A across bathrooms, Fountain	5/26/16 5:00AM	ND	ND
24461-1-S-F10-003	Pod A across bathrooms, Fountain	5/26/16 5:00AM	ND	ND
24461-1-S-F10-004	Pod A across bathrooms, Fountain	5/26/16 5:00AM	ND	ND
24461-1-S-F10-005	Pod A across bathrooms, Fountain	5/26/16 5:00AM	ND	ND
24461-1-S-F11-001	Inside Kindergarten Room 115, Fountain 1	5/26/16 5:00AM	ND	ND
24461-1-S-F11-002	Inside Kindergarten Room 115, Fountain 1	5/26/16 5:00AM	ND	ND
24461-1-S-F11-003	Inside Kindergarten Room 115, Fountain 1	5/26/16 5:00AM	ND	ND
24461-1-S-F11-004	Inside Kindergarten Room 115, Fountain 1	5/26/16 5:00AM	ND	ND
24461-1-S-F11-005	Inside Kindergarten Room 115, Fountain 1	5/26/16 5:00AM	ND	ND
24461-1-S-F12-001	Inside Kindergarten Room 115, Fountain 2	5/26/16 5:00AM	ND	ND
24461-1-S-F12-002	Inside Kindergarten Room 115, Fountain 2	5/26/16 5:00AM	ND	ND
24461-1-S-F12-003	Inside Kindergarten Room 115, Fountain 2	5/26/16 5:00AM	ND	ND
24461-1-S-F12-004	Inside Kindergarten Room 115, Fountain 2	5/26/16 5:00AM	ND	ND
24461-1-S-F12-005	Inside Kindergarten Room 115, Fountain 2	5/26/16 5:00AM	ND	ND
24461-1-S-F14-001	Outside classroom 101, Fountain	5/26/16 5:00AM	ND	ND
24461-1-S-F14-002	Outside classroom 101, Fountain	5/26/16 5:00AM	ND	ND

[illegible]

24461-1-N-S30-001	Branch- Kitchen East Wall, Sink 2	5/26/16 5:00AM	ND	ND
24461-1-N-S30-002	Branch- Kitchen East Wall, Sink 2	5/26/16 5:00AM	ND	ND
24461-1-N-S30-003	Branch- Kitchen East Wall, Sink 2	5/26/16 5:00AM	ND	ND
24461-1-N-S30-004	Branch- Kitchen East Wall, Sink 2	5/26/16 5:00AM	ND	ND
24461-1-N-S30-005	Branch- Kitchen East Wall, Sink 2	5/26/16 5:00AM	ND	ND
24461-1-S-F31-001	Branch- Hallway South Wall by bathrooms, Fountain 1	5/26/16 5:00AM	ND	ND
24461-1-S-F31-002	Branch- Hallway South Wall by bathrooms, Fountain 1	5/26/16 5:00AM	ND	ND
24461-1-S-F31-003	Branch- Hallway South Wall by bathrooms, Fountain 1	5/26/16 5:00AM	ND	ND
24461-1-S-F31-004	Branch- Hallway South Wall by bathrooms, Fountain 1	5/26/16 5:00AM	ND	ND
24461-1-S-F31-005	Branch- Hallway South Wall by bathrooms, Fountain 1	5/26/16 5:00AM	ND	ND
24461-1-S-F32-001	Branch- Hallway South Wall by bathrooms, Fountain 2	5/26/16 5:00AM	ND	ND
24461-1-S-F32-002	Branch- Hallway South Wall by bathrooms, Fountain 2	5/26/16 5:00AM	ND	ND
24461-1-S-F32-003	Branch- Hallway South Wall by bathrooms, Fountain 2	5/26/16 5:00AM	ND	ND
24461-1-S-F32-004	Branch- Hallway South Wall by bathrooms, Fountain 2	5/26/16 5:00AM	ND	ND
24461-1-S-F32-005	Branch- Hallway South Wall by bathrooms, Fountain 2	5/26/16 5:00AM	ND	ND
24461-2-S-F01-001	Branch- 2nd floor Across from room 207, Fountain	5/26/16 5:00AM	ND	ND
24461-2-S-F01-002	Branch- 2nd floor Across from room 207, Fountain	5/26/16 5:00AM	ND	ND
24461-2-S-F01-003	Branch- 2nd floor Across from room 207, Fountain	5/26/16 5:00AM	ND	ND
24461-2-S-F01-004	Branch- 2nd floor Across from room 207, Fountain	5/26/16 5:00AM	ND	ND
24461-2-S-F01-005	Branch- 2nd floor Across from room 207, Fountain	5/26/16 5:00AM	ND	ND

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit

BA-Below EPA Action Level of 15 ppb

AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations