



School Lead Water Testing - Data Collection Form

School Short Name **Goethe**
Address 2236 N. Rockwell

Length of time water remained in pipes before sampled (hours) 13.00
Report based on lab results dated 6/3/16
Date of test 05/25/16
Water last used (Time and date) Approx 4:00 PM 5/24/16

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
23341-1-N-S01-001	Sink in Kindergarten room 402	5/25/16 5:00 AM	2.19	BA
23341-1-N-S01-002	Sink in Kindergarten room 402	5/25/16 5:00 AM	1.84	BA
23341-1-N-S01-003	Sink in Kindergarten room 402	5/25/16 5:00 AM	1.31	BA
23341-1-N-S01-004	Sink in Kindergarten room 402	5/25/16 5:00 AM	1.08	BA
23341-1-N-S01-005	Sink in Kindergarten room 402	5/25/16 5:00 AM	0.987	BA
23341-1-E-S02-001	Sink in Pre-K room 403	5/25/16 5:00 AM	2.19	BA
23341-1-E-S02-002	Sink in Pre-K room 403	5/25/16 5:00 AM	1.27	BA
23341-1-E-S02-003	Sink in Pre-K room 403	5/25/16 5:00 AM	0.801	BA
23341-1-E-S02-004	Sink in Pre-K room 403	5/25/16 5:00 AM	0.648	BA
23341-1-E-S02-005	Sink in Pre-K room 403	5/25/16 5:00 AM	0.591	BA
23341-1-N-F03-001	Fountain 1 near room 403	5/25/16 5:00 AM	0.288	BA
23341-1-N-F03-002	Fountain 1 near room 403	5/25/16 5:00 AM	0.218	BA
23341-1-N-F03-003	Fountain 1 near room 403	5/25/16 5:00 AM	0.219	BA
23341-1-N-F03-004	Fountain 1 near room 403	5/25/16 5:00 AM	0.239	BA
23341-1-N-F03-005	Fountain 1 near room 403	5/25/16 5:00 AM	0.692	BA
23341-1-N-F04-001	Fountain 2 near room 403	5/25/16 5:00 AM	1.96	BA
23341-1-N-F04-002	Fountain 2 near room 403	5/25/16 5:00 AM	0.507	BA
23341-1-N-F04-003	Fountain 2 near room 403	5/25/16 5:00 AM	0.468	BA
23341-1-N-F04-004	Fountain 2 near room 403	5/25/16 5:00 AM	0.449	BA
23341-1-N-F04-005	Fountain 2 near room 403	5/25/16 5:00 AM	0.425	BA
23341-1-E-S05-001	Sink in Pre-K room 404	5/25/16 5:00 AM	1.28	BA
23341-1-E-S05-002	Sink in Pre-K room 404	5/25/16 5:00 AM	0.648	BA
23341-1-E-S05-003	Sink in Pre-K room 404	5/25/16 5:00 AM	0.721	BA
23341-1-E-S05-004	Sink in Pre-K room 404	5/25/16 5:00 AM	0.756	BA
23341-1-E-S05-005	Sink in Pre-K room 404	5/25/16 5:00 AM	0.606	BA
23341-2-N-F1-001	Fountain outside room 207	5/25/16 5:00 AM	0.308	BA
23341-2-N-F1-002	Fountain outside room 207	5/25/16 5:00 AM	0.395	BA
23341-2-N-F1-003	Fountain outside room 207	5/25/16 5:00 AM	0.404	BA
23341-2-N-F1-004	Fountain outside room 207	5/25/16 5:00 AM	0.335	BA
23341-2-N-F1-005	Fountain outside room 207	5/25/16 5:00 AM	0.263	BA
23341-B-E-S01-001	Kitchen sink 1	5/25/16 5:00 AM	0.304	BA
23341-B-E-S01-002	Kitchen sink 1	5/25/16 5:00 AM	0.427	BA
23341-B-E-S01-003	Kitchen sink 1	5/25/16 5:00 AM	0.215	BA
23341-B-E-S01-004	Kitchen sink 1	5/25/16 5:00 AM	0.46	BA
23341-B-E-S01-005	Kitchen sink 1	5/25/16 5:00 AM	0.341	BA
23341-B-E-S02-001	Kitchen sink 2	5/25/16 5:00 AM	0.357	BA
23341-B-E-S02-002	Kitchen sink 2	5/25/16 5:00 AM	0.156	BA
23341-B-E-S02-003	Kitchen sink 2	5/25/16 5:00 AM	0.164	BA
23341-B-E-S02-004	Kitchen sink 2	5/25/16 5:00 AM	1.62	BA
23341-B-E-S02-005	Kitchen sink 2	5/25/16 5:00 AM	0.185	BA
23341-B-N-F03-001	Fountain 1 near kitchen door	5/25/16 5:00 AM	1.01	BA
23341-B-N-F03-002	Fountain 1 near kitchen door	5/25/16 5:00 AM	0.636	BA
23341-B-N-F03-003	Fountain 1 near kitchen door	5/25/16 5:00 AM	0.669	BA
23341-B-N-F03-004	Fountain 1 near kitchen door	5/25/16 5:00 AM	1.04	BA
23341-B-N-F03-005	Fountain 1 near kitchen door	5/25/16 5:00 AM	0.733	BA
23341-B-N-F04-001	Fountain 2 near kitchen door	5/25/16 5:00 AM	1.28	BA

23341-B-N-F04-002	Fountain 2 near kitchen door	5/25/16 5:00 AM	1.02	BA
23341-B-N-F04-003	Fountain 2 near kitchen door	5/25/16 5:00 AM	1.01	BA
23341-B-N-F04-004	Fountain 2 near kitchen door	5/25/16 5:00 AM	0.9	BA
23341-B-N-F04-005	Fountain 2 near kitchen door	5/25/16 5:00 AM	1.04	BA
23341-1-N-F01-001	Fountain 1 outside rm 106	5/25/16 5:00 AM	0.688	BA
23341-1-N-F01-002	Fountain 1 outside rm 106	5/25/16 5:00 AM	0.514	BA
23341-1-N-F01-003	Fountain 1 outside rm 106	5/25/16 5:00 AM	0.56	BA
23341-1-N-F01-004	Fountain 1 outside rm 106	5/25/16 5:00 AM	0.74	BA
23341-1-N-F01-005	Fountain 1 outside rm 106	5/25/16 5:00 AM	1.09	BA
23341-1-N-F02-001	Fountain 2 outside rm 106	5/25/16 5:00 AM	1.48	BA
23341-1-N-F02-002	Fountain 2 outside rm 106	5/25/16 5:00 AM	0.812	BA
23341-1-N-F02-003	Fountain 2 outside rm 106	5/25/16 5:00 AM	0.763	BA
23341-1-N-F02-004	Fountain 2 outside rm 106	5/25/16 5:00 AM	0.696	BA
23341-1-N-F02-005	Fountain 2 outside rm 106	5/25/16 5:00 AM	0.784	BA
23341-2-N-F01-001	Fountain 1 outside rm 206	5/25/16 5:00 AM	0.569	BA
23341-2-N-F01-002	Fountain 1 outside rm 206	5/25/16 5:00 AM	0.781	BA
23341-2-N-F01-003	Fountain 1 outside rm 206	5/25/16 5:00 AM	0.539	BA
23341-2-N-F01-004	Fountain 1 outside rm 206	5/25/16 5:00 AM	0.517	BA
23341-2-N-F01-005	Fountain 1 outside rm 206	5/25/16 5:00 AM	0.504	BA
23341-2-N-F02-001	Fountain 2 outside rm 206	5/25/16 5:00 AM	0.739	BA
23341-2-N-F02-002	Fountain 2 outside rm 206	5/25/16 5:00 AM	0.649	BA
23341-2-N-F02-003	Fountain 2 outside rm 206	5/25/16 5:00 AM	0.559	BA
23341-2-N-F02-004	Fountain 2 outside rm 206	5/25/16 5:00 AM	0.518	BA
23341-2-N-F02-005	Fountain 2 outside rm 206	5/25/16 5:00 AM	0.477	BA
23341-3-N-F01-001	Fountain 1 outside room 305	5/25/16 5:00 AM	0.617	BA
23341-3-N-F01-002	Fountain 1 outside room 305	5/25/16 5:00 AM	0.612	BA
23341-3-N-F01-003	Fountain 1 outside room 305	5/25/16 5:00 AM	0.518	BA
23341-3-N-F01-004	Fountain 1 outside room 305	5/25/16 5:00 AM	0.487	BA
23341-3-N-F01-005	Fountain 1 outside room 305	5/25/16 5:00 AM	0.51	BA
23341-3-N-F02-001	Fountain 2 outside room 305	5/25/16 5:00 AM	0.865	BA
23341-3-N-F02-002	Fountain 2 outside room 305	5/25/16 5:00 AM	0.593	BA
23341-3-N-F02-003	Fountain 2 outside room 305	5/25/16 5:00 AM	0.542	BA
23341-3-N-F02-004	Fountain 2 outside room 305	5/25/16 5:00 AM	0.537	BA
23341-3-N-F02-005	Fountain 2 outside room 305	5/25/16 5:00 AM	0.536	BA

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit

BA-Below EPA Action Level of 15 ppb

AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations