

## School Lead Water Testing - Data Collection Form

School Name **Tonti**

Length of time water remained in pipes before sampled (hours)

ned in pipes before sampled (hours)	13.00
Report based on lab results dated	6/14/16
Date of test	05/27/16
Water last used (Time and date)	Approx 4 PM 5/26/16

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
51310-1-N-F02-001	Main- 1st floor Fountain by Office	5/27/16 5:00 AM	0.182	BA
51310-1-N-F02-002	Main- 1st floor Fountain by Office	5/27/16 5:00 AM	0.205	BA
51310-1-N-F02-003	Main- 1st floor Fountain by Office	5/27/16 5:00 AM	1.75	BA
51310-1-N-F02-004	Main- 1st floor Fountain by Office	5/27/16 5:00 AM	0.412	BA
51310-1-N-F02-005	Main- 1st floor Fountain by Office	5/27/16 5:00 AM	0.179	BA
51310-1-N-F03-001	Main- 1st floor Fountain 2 by Office	5/27/16 5:00 AM	0.14	BA
51310-1-N-F03-002	Main- 1st floor Fountain 2 by Office	5/27/16 5:00 AM	0.352	BA
51310-1-N-F03-003	Main- 1st floor Fountain 2 by Office	5/27/16 5:00 AM	0.136	BA
51310-1-N-F03-004	Main- 1st floor Fountain 2 by Office	5/27/16 5:00 AM	0.187	BA
51310-1-N-F03-005	Main- 1st floor Fountain 2 by Office	5/27/16 5:00 AM	0.149	BA
51310-1-N-F04-001	Main- 1st floor Fountain 1 by Storage room	5/27/16 5:00 AM	0.893	BA
51310-1-N-F04-002	Main- 1st floor Fountain 1 by Storage room	5/27/16 5:00 AM	0.173	BA
51310-1-N-F04-003	Main- 1st floor Fountain 1 by Storage room	5/27/16 5:00 AM	2.18	BA
51310-1-N-F04-004	Main- 1st floor Fountain 1 by Storage room	5/27/16 5:00 AM	6.12	BA
51310-1-N-F04-005	Main- 1st floor Fountain 1 by Storage room	5/27/16 5:00 AM	50.9	AA
51310-1-W-F05-001	Main- 1st floor Fountain 2 by Storage room	5/27/16 5:00 AM	0.122	BA
51310-1-W-F05-002	Main- 1st floor Fountain 2 by Storage room	5/27/16 5:00 AM	<+0.120	ND
51310-1-W-F05-003	Main- 1st floor Fountain 2 by Storage room	5/27/16 5:00 AM	<+0.120	ND
51310-1-W-F05-004	Main- 1st floor Fountain 2 by Storage room	5/27/16 5:00 AM	<+0.120	ND
51310-1-W-F05-005	Main- 1st floor Fountain 2 by Storage room	5/27/16 5:00 AM	0.132	BA
51310-1-W-F06-001	Main- 1st floor Fountain by girls toilets	5/27/16 5:00 AM	<+0.120	ND
51310-1-W-F06-002	Main- 1st floor Fountain by girls toilets	5/27/16 5:00 AM	0.159	BA
51310-1-W-F06-003	Main- 1st floor Fountain by girls toilets	5/27/16 5:00 AM	<+0.120	ND
51310-1-W-F06-004	Main- 1st floor Fountain by girls toilets	5/27/16 5:00 AM	<+0.120	ND
51310-1-W-F06-005	Main- 1st floor Fountain by girls toilets	5/27/16 5:00 AM	0.129	BA
51310-1-W-S07-001	Main- 1st floor Kitchen Sink	5/27/16 5:00 AM	0.534	BA
51310-1-W-S07-002	Main- 1st floor Kitchen Sink	5/27/16 5:00 AM	0.512	BA
51310-1-W-S07-003	Main- 1st floor Kitchen Sink	5/27/16 5:00 AM	0.513	BA
51310-1-W-S07-004	Main- 1st floor Kitchen Sink	5/27/16 5:00 AM	0.291	BA
51310-1-W-S07-005	Main- 1st floor Kitchen Sink	5/27/16 5:00 AM	0.741	BA
51310-1-W-F08-001	Main- 1st floor Fountain 1 by kitchen	5/27/16 5:00 AM	0.494	BA
51310-1-W-F08-002	Main- 1st floor Fountain 1 by kitchen	5/27/16 5:00 AM	0.421	BA
51310-1-W-F08-003	Main- 1st floor Fountain 1 by kitchen	5/27/16 5:00 AM	0.641	BA
51310-1-W-F08-004	Main- 1st floor Fountain 1 by kitchen	5/27/16 5:00 AM	0.423	BA
51310-1-W-F08-005	Main- 1st floor Fountain 1 by kitchen	5/27/16 5:00 AM	0.455	BA
51310-1-W-F09-001	Main- 1st floor Fountain 2 by kitchen	5/27/16 5:00 AM	0.412	BA
51310-1-W-F09-002	Main- 1st floor Fountain 2 by kitchen	5/27/16 5:00 AM	0.691	BA
51310-1-W-F09-003	Main- 1st floor Fountain 2 by kitchen	5/27/16 5:00 AM	0.575	BA
51310-1-W-F09-004	Main- 1st floor Fountain 2 by kitchen	5/27/16 5:00 AM	0.617	BA
51310-1-W-F09-005	Main- 1st floor Fountain 2 by kitchen	5/27/16 5:00 AM	3.05	BA
51310-2-N-F02-001	Main- 2nd floor Fountain by Room 201	5/27/16 5:00 AM	1.76	BA
51310-2-N-F02-002	Main- 2nd floor Fountain by Room 201	5/27/16 5:00 AM	1.68	BA
51310-2-N-F02-003	Main- 2nd floor Fountain by Room 201	5/27/16 5:00 AM	1.28	BA
51310-2-N-F02-004	Main- 2nd floor Fountain by Room 201	5/27/16 5:00 AM	0.844	BA
51310-2-N-F02-005	Main- 2nd floor Fountain by Room 201	5/27/16 5:00 AM	1.1	BA
51310-2-N-F04-001	Main- 2nd floor Fountain by Room 206	5/27/16 5:00 AM	0.139	BA
51310-2-N-F04-002	Main- 2nd floor Fountain by Room 206	5/27/16 5:00 AM	0.159	BA
51310-2-N-F04-003	Main- 2nd floor Fountain by Room 206	5/27/16 5:00 AM	0.2	BA
51310-2-N-F04-004	Main- 2nd floor Fountain by Room 206	5/27/16 5:00 AM	0.476	BA
51310-2-N-F04-005	Main- 2nd floor Fountain by Room 206	5/27/16 5:00 AM	0.215	BA
51310-2-W-F05-001	Main- 2nd floor Fountain 1 by Room 209	5/27/16 5:00 AM	0.296	BA
51310-2-W-F05-002	Main- 2nd floor Fountain 1 by Room 209	5/27/16 5:00 AM	0.409	BA
51310-2-W-F05-003	Main- 2nd floor Fountain 1 by Room 209	5/27/16 5:00 AM	0.303	BA
51310-2-W-F05-004	Main- 2nd floor Fountain 1 by Room 209	5/27/16 5:00 AM	0.315	BA
51310-2-W-F05-005	Main- 2nd floor Fountain 1 by Room 209	5/27/16 5:00 AM	0.146	BA
51310-2-W-F06-001	Main- 2nd floor Fountain 2 by Room 209	5/27/16 5:00 AM	0.189	BA
51310-2-W-F06-002	Main- 2nd floor Fountain 2 by Room 209	5/27/16 5:00 AM	0.247	BA
51310-2-W-F06-003	Main- 2nd floor Fountain 2 by Room 209	5/27/16 5:00 AM	0.26	BA
51310-2-W-F06-004	Main- 2nd floor Fountain 2 by Room 209	5/27/16 5:00 AM	0.25	BA
51310-2-W-F06-005	Main- 2nd floor Fountain 2 by Room 209	5/27/16 5:00 AM	0.259	BA
51310-2-W-F07-001	Main- 2nd floor Fountain by Room 211	5/27/16 5:00 AM	1.01	BA
51310-2-W-F07-002	Main- 2nd floor Fountain by Room 211	5/27/16 5:00 AM	0.897	BA
51310-2-W-F07-003	Main- 2nd floor Fountain by Room 211	5/27/16 5:00 AM	0.891	BA
51310-2-W-F07-004	Main- 2nd floor Fountain by Room 211	5/27/16 5:00 AM	0.773	BA
51310-2-W-F07-005	Main- 2nd floor Fountain by Room 211	5/27/16 5:00 AM	1.01	BA
51310-3-N-F02-001	Main- 3rd floor Fountain by Room 301	5/27/16 5:00 AM	0.75	BA
51310-3-N-F02-002	Main- 3rd floor Fountain by Room 301	5/27/16 5:00 AM	1.14	BA
51310-3-N-F02-003	Main- 3rd floor Fountain by Room 301	5/27/16 5:00 AM	1.52	BA
51310-3-N-F02-004	Main- 3rd floor Fountain by Room 301	5/27/16 5:00 AM	1.88	BA
51310-3-N-F02-005	Main- 3rd floor Fountain by Room 301	5/27/16 5:00 AM	1.74	BA
51310-3-N-F03-001	Main- 3rd floor Fountain 1 by Room 306	5/27/16 5:00 AM	1.2	BA
51310-3-N-F03-002	Main- 3rd floor Fountain 1 by Room 306	5/27/16 5:00 AM	1.2	BA
51310-3-N-F03-003	Main- 3rd floor Fountain 1 by Room 306	5/27/16 5:00 AM	1.28	BA
51310-3-N-F03-004	Main- 3rd floor Fountain 1 by Room 306	5/27/16 5:00 AM	1.32	BA
51310-3-N-F03-005	Main- 3rd floor Fountain 1 by Room 306	5/27/16 5:00 AM	1.2	BA
51310-3-N-F04-001	Main- 3rd floor Fountain 2 by Room 306	5/27/16 5:00 AM	0.469	BA
51310-3-N-F04-002	Main- 3rd floor Fountain 2 by Room 306	5/27/16 5:00 AM	0.594	BA
51310-3-N-F04-003	Main- 3rd floor Fountain 2 by Room 306	5/27/16 5:00 AM	0.645	BA
51310-3-N-F04-004	Main- 3rd floor Fountain 2 by Room 306	5/27/16 5:00 AM	0.478	BA
51310-3-N-F04-005	Main- 3rd floor Fountain 2 by Room 306	5/27/16 5:00 AM	0.711	BA
51310-3-N-F05-001	Main- 3rd floor Fountain by Room 307	5/27/16 5:00 AM	0.479	BA
51310-3-N-F05-002	Main- 3rd floor Fountain by Room 307	5/27/16 5:00 AM	0.412	BA
51310-3-N-F05-003	Main- 3rd floor Fountain by Room 307	5/27/16 5:00 AM	0.538	BA
51310-3-N-F05-004	Main- 3rd floor Fountain by Room 307	5/27/16 5:00 AM	0.352	BA
51310-3-N-F05-005	Main- 3rd floor Fountain by Room 307	5/27/16 5:00 AM	0.485	BA
51310-1-W-S01-001	Modular- 1st floor Sink in Room 121	5/27/16 5:00 AM	<+0.120	ND
51310-1-W-S01-002	Modular- 1st floor Sink in Room 121	5/27/16 5:00 AM	<+0.120	ND
51310-1-W-S01-003	Modular- 1st floor Sink in Room 121	5/27/16 5:00 AM	<+0.120	ND
51310-1-W-S01-004	Modular- 1st floor Sink in Room 121	5/27/16 5:00 AM	<+0.120	ND
51310-1-W-S01-005	Modular- 1st floor Sink in Room 121	5/27/16 5:00 AM	<+0.120	ND
51310-1-W-F01-001	Modular- 1st floor Fountain by Room 121	5/27/16 5:00 AM	<+0.120	ND
51310-1-W-F01-002	Modular- 1st floor Fountain by Room 121	5/27/16 5:00 AM	<+0.120	ND
51310-1-W-F01-003	Modular- 1st floor Fountain by Room 121	5/27/16 5:00 AM	<+0.120	ND
51310-1-W-F01-004	Modular- 1st floor Fountain by Room 121	5/27/16 5:00 AM	<+0.120	ND
51310-1-W-F01-005	Modular- 1st floor Fountain by Room 121	5/27/16 5:00 AM	<+0.120	ND
51310-1-E-S03-001	Modular- 1st floor Sink in room 122	5/27/16 5:00 AM	0.185	BA
51310-1-E-S03-002	Modular- 1st floor Sink in room 122	5/27/16 5:00 AM	<+0.120	ND
51310-1-E-S03-003	Modular- 1st floor Sink in room 122	5/27/16 5:00 AM	<+0.120	ND
51310-1-E-S03-004	Modular- 1st floor Sink in room 122	5/27/16 5:00 AM	<+0.120	ND
51310-1-E-S03-005	Modular- 1st floor Sink in room 122	5/27/16 5:00 AM	<+0.120	ND
51310-1-E-F04-001	Modular- 1st floor Fountain by room 122	5/27/16 5:00 AM	0.218	BA
51310-1-E-F04-002	Modular- 1st floor Fountain by room 122	5/27/16 5:00 AM	0.14	BA
51310-1-E-F04-003	Modular- 1st floor Fountain by room 122	5/27/16 5:00 AM	<+0.120	ND
51310-1-E-F04-004	Modular- 1st floor Fountain by room 122	5/27/16 5:00 AM	<+0.120	ND
51310-1-E-F04-005	Modular- 1st floor Fountain by room 122	5/27/16 5:00 AM	<+0.120	ND
51310-1-W-S05-001	Modular- 1st floor Sink in room 123	5/27/16 5:00 AM	<+0.120	ND
51310-1-W-S05-002	Modular- 1st floor Sink in room 123	5/27/16 5:00 AM	<+0.120	ND
51310-1-W-S05-003	Modular- 1st floor Sink in room 123	5/27/16 5:00 AM	<+0.120	ND
51310-1-W-S05-004	Modular- 1st floor Sink in room 123	5/27/16 5:00 AM	<+0.120	ND
51310-1-W-S05-005	Modular- 1st floor Sink in room 123	5/27/16 5:00 AM	<+0.120	ND
51310-1-W-F06-001	Modular- 1st floor Fountain by room 123	5/27/16 5:00 AM	<+0.120	ND
51310-1-W-F06-002	Modular- 1st floor Fountain by room 123	5/27/16 5:00 AM	<+0.120	ND
51310-1-W-F06-003	Modular- 1st floor Fountain by room 123	5/27/16 5:00 AM	<+0.120	ND
51310-1-W-F06-004	Modular- 1st floor Fountain by room 123	5/27/16 5:00 AM	<+0.120	ND
51310-1-W-F06-005	Modular- 1st floor Fountain by room 123	5/27/16 5:00 AM	<+0.120	ND
51310-1-E-S07-001	Modular- 1st floor Sink in Room 124	5/27/16 5:00 AM	0.275	BA
51310-1-E-S07-002	Modular- 1st floor Sink in Room 124	5/27/16 5:00 AM	<+0.120	ND
51310-1-E-S07-003	Modular- 1st floor Sink in Room 124	5/27/16 5:00 AM	<+0.120	ND
51310-1-E-S07-004	Modular- 1st floor Sink in Room 124	5/27/16 5:00 AM	<+0.120	ND
51310-1-E-S07-005	Modular- 1st floor Sink in Room 124	5/27/16 5:00 AM	<+0.120	ND
51310-1-E-F08-001	Modular- 1st floor Fountain in Room 124	5/27/16 5:00 AM	0.127	BA
51310-1-E-F08-002	Modular- 1st floor Fountain in Room 124	5/27/16 5:00 AM	<+0.120	ND
51310-1-E-F08-003	Modular- 1st floor Fountain in Room 124	5/27/16 5:00 AM	<+0.120	ND
51310-1-E-F08-004	Modular- 1st floor Fountain in Room 124	5/27/16 5:00 AM	<+0.120	ND
51310-1-E-F08-005	Modular- 1st floor Fountain in Room 124	5/27/16 5:00 AM	<+0.120	ND
51310-1-N-F09-001	Modular- 1st floor Corridor N Fountain 1	5/27/16 5:00 AM	<+0.120	ND
51310-1-N-F09-002	Modular- 1st floor Corridor N Fountain 1	5/27/16 5:00 AM	<+0.120	ND
51310-1-N-F09-003	Modular- 1st floor Corridor N Fountain 1	5/27/16 5:00 AM	<+0.120	ND
51310-1-N-F09-004	Modular- 1st floor Corridor N Fountain 1	5/27/16 5:00 AM	<+0.120	ND
51310-1-N-F09-005	Modular- 1st floor Corridor N Fountain 1	5/27/16 5:00 AM	<+0.120	ND
51310-1-N-F09-006	Modular- 1st floor Corridor N Fountain 2	5/27/16 5:00 AM	<+0.120	ND

51310-1-N-F10-002	Modular- 1st floor Corridor N. Fountain 2	5/27/16 5:00 AM	0.134	BA
51310-1-N-F10-003	Modular- 1st floor Corridor N. Fountain 2	5/27/16 5:00 AM	<0.240	ND
51310-1-N-F10-004	Modular- 1st floor Corridor N. Fountain 2	5/27/16 5:00 AM	<0.120	ND
51310-1-N-F10-005	Modular- 1st floor Corridor N. Fountain 2	5/27/16 5:00 AM	<0.120	ND
51310-1-N-F11-001	Modular- 1st floor Corridor N. Fountain 3	5/27/16 5:00 AM	<0.120	ND
51310-1-N-F11-002	Modular- 1st floor Corridor N. Fountain 3	5/27/16 5:00 AM	<0.120	ND
51310-1-N-F11-003	Modular- 1st floor Corridor N. Fountain 3	5/27/16 5:00 AM	<0.120	ND
51310-1-N-F11-004	Modular- 1st floor Corridor N. Fountain 3	5/27/16 5:00 AM	<0.120	ND
51310-1-N-F11-005	Modular- 1st floor Corridor N. Fountain 3	5/27/16 5:00 AM	<0.120	ND
51310-1-W-S12-001	Modular- 1st floor Sink in Room 125	5/27/16 5:00 AM	<0.120	ND
51310-1-W-S12-002	Modular- 1st floor Sink in Room 125	5/27/16 5:00 AM	<0.120	ND
51310-1-W-S12-003	Modular- 1st floor Sink in Room 125	5/27/16 5:00 AM	<0.120	ND
51310-1-W-S12-004	Modular- 1st floor Sink in Room 125	5/27/16 5:00 AM	<0.120	ND
51310-1-W-S12-005	Modular- 1st floor Sink in Room 125	5/27/16 5:00 AM	0.166	BA
51310-1-W-F13-001	Modular- 1st floor Fountain in Room 125	5/27/16 5:00 AM	<0.120	ND
51310-1-W-F13-002	Modular- 1st floor Fountain in Room 125	5/27/16 5:00 AM	<0.120	ND
51310-1-W-F13-003	Modular- 1st floor Fountain in Room 125	5/27/16 5:00 AM	<0.120	ND
51310-1-W-F13-004	Modular- 1st floor Fountain in Room 125	5/27/16 5:00 AM	<0.120	ND
51310-1-W-F13-005	Modular- 1st floor Fountain in Room 125	5/27/16 5:00 AM	<0.120	ND
51310-1-E-S14-001	Modular- 1st floor Sink in Room 126	5/27/16 5:00 AM	0.166	BA
51310-1-E-S14-002	Modular- 1st floor Sink in Room 126	5/27/16 5:00 AM	<0.120	ND
51310-1-E-S14-003	Modular- 1st floor Sink in Room 126	5/27/16 5:00 AM	<0.120	ND
51310-1-E-S14-004	Modular- 1st floor Sink in Room 126	5/27/16 5:00 AM	<0.120	ND
51310-1-E-S14-005	Modular- 1st floor Sink in Room 126	5/27/16 5:00 AM	<0.120	ND
51310-1-E-F15-001	Modular- 1st floor Fountain in Room 126	5/27/16 5:00 AM	<0.120	ND
51310-1-E-F15-002	Modular- 1st floor Fountain in Room 126	5/27/16 5:00 AM	<0.120	ND
51310-1-E-F15-003	Modular- 1st floor Fountain in Room 126	5/27/16 5:00 AM	0.208	BA
51310-1-E-F15-004	Modular- 1st floor Fountain in Room 126	5/27/16 5:00 AM	<0.120	ND
51310-1-E-F15-005	Modular- 1st floor Fountain in Room 126	5/27/16 5:00 AM	<0.120	ND
51310-1-W-S16-001	Modular- 1st floor Sink in Room 127	5/27/16 5:00 AM	0.166	BA
51310-1-W-S16-002	Modular- 1st floor Sink in Room 127	5/27/16 5:00 AM	<0.120	ND
51310-1-W-S16-003	Modular- 1st floor Sink in Room 127	5/27/16 5:00 AM	<0.120	ND
51310-1-W-S16-004	Modular- 1st floor Sink in Room 127	5/27/16 5:00 AM	<0.120	ND
51310-1-W-S16-005	Modular- 1st floor Sink in Room 127	5/27/16 5:00 AM	<0.120	ND
51310-1-W-F17-001	Modular- 1st floor Fountain in Room 127	5/27/16 5:00 AM	<0.120	ND
51310-1-W-F17-002	Modular- 1st floor Fountain in Room 127	5/27/16 5:00 AM	<0.120	ND
51310-1-W-F17-003	Modular- 1st floor Fountain in Room 127	5/27/16 5:00 AM	<0.120	ND
51310-1-W-F17-004	Modular- 1st floor Fountain in Room 127	5/27/16 5:00 AM	<0.120	ND
51310-1-W-F17-005	Modular- 1st floor Fountain in Room 127	5/27/16 5:00 AM	<0.120	ND
51310-1-E-S18-001	Modular- 1st floor Sink in Room 128	5/27/16 5:00 AM	0.253	BA
51310-1-E-S18-002	Modular- 1st floor Sink in Room 128	5/27/16 5:00 AM	<0.120	ND
51310-1-E-S18-003	Modular- 1st floor Sink in Room 128	5/27/16 5:00 AM	<0.120	ND
51310-1-E-S18-004	Modular- 1st floor Sink in Room 128	5/27/16 5:00 AM	<0.120	ND
51310-1-E-S18-005	Modular- 1st floor Sink in Room 128	5/27/16 5:00 AM	<0.120	ND
51310-1-E-F19-001	Modular- 1st floor Fountain in Room 128	5/27/16 5:00 AM	<0.120	ND
51310-1-E-F19-002	Modular- 1st floor Fountain in Room 128	5/27/16 5:00 AM	<0.120	ND
51310-1-E-F19-003	Modular- 1st floor Fountain in Room 128	5/27/16 5:00 AM	<0.120	ND
51310-1-E-F19-004	Modular- 1st floor Fountain in Room 128	5/27/16 5:00 AM	<0.120	ND
51310-1-E-F19-005	Modular- 1st floor Fountain in Room 128	5/27/16 5:00 AM	<0.120	ND
51310-1-S-F20-001	Modular- 1st floor Corridor S. Sink	5/27/16 5:00 AM	<0.120	ND
51310-1-S-F20-002	Modular- 1st floor Corridor S. Sink	5/27/16 5:00 AM	<0.120	ND
51310-1-S-F20-003	Modular- 1st floor Corridor S. Sink	5/27/16 5:00 AM	<0.120	ND
51310-1-S-F20-004	Modular- 1st floor Corridor S. Sink	5/27/16 5:00 AM	<0.120	ND
51310-1-S-F20-005	Modular- 1st floor Corridor S. Sink	5/27/16 5:00 AM	<0.120	ND
51310-1-S-F21-001	Modular- 1st floor Corridor W. Fountain	5/27/16 5:00 AM	<0.120	ND
51310-1-S-F21-002	Modular- 1st floor Corridor W. Fountain	5/27/16 5:00 AM	0.144	BA
51310-1-S-F21-003	Modular- 1st floor Corridor W. Fountain	5/27/16 5:00 AM	<0.120	ND
51310-1-S-F21-004	Modular- 1st floor Corridor W. Fountain	5/27/16 5:00 AM	<0.120	ND
51310-1-S-F21-005	Modular- 1st floor Corridor W. Fountain	5/27/16 5:00 AM	<0.120	ND
51310-1-S-F01-001	Annex- 1st floor S. Fountain	5/27/16 5:00 AM	<0.120	ND
51310-1-S-F01-002	Annex- 1st floor S. Fountain	5/27/16 5:00 AM	<0.120	ND
51310-1-S-F01-003	Annex- 1st floor S. Fountain	5/27/16 5:00 AM	<0.120	ND
51310-1-S-F01-004	Annex- 1st floor S. Fountain	5/27/16 5:00 AM	<0.120	ND
51310-1-S-F01-005	Annex- 1st floor S. Fountain	5/27/16 5:00 AM	0.169	BA
51310-1-S-F02-001	Annex- 1st floor S. Sink	5/27/16 5:00 AM	<0.120	ND
51310-1-S-F02-002	Annex- 1st floor S. Sink	5/27/16 5:00 AM	<0.120	ND
51310-1-S-F02-003	Annex- 1st floor S. Sink	5/27/16 5:00 AM	<0.120	ND
51310-1-S-F02-004	Annex- 1st floor S. Sink	5/27/16 5:00 AM	<0.120	ND
51310-1-S-F02-005	Annex- 1st floor S. Sink	5/27/16 5:00 AM	<0.120	ND

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

#### SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit  
BA-Below EPA Action Level of 15 ppb  
AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations