



School Lead Water Testing - Data Collection Form

School Short Name **McPherson**

Sample ID #	Sample Location	Water Last Used (Time & Date)	Sample Collection Time & Date	Test Result (ppb)	Test Results
1-E-CS01-1	1st Floor Kitchen	6/1/16 10:30 PM	6/2/16 6:05 AM	None Detected	ND
1-E-CS01-2	1st Floor Kitchen	6/1/16 10:30 PM	6/2/16 6:05 AM	None Detected	ND
1-E-CS01-3	1st Floor Kitchen	6/1/16 10:30 PM	6/2/16 6:05 AM	None Detected	ND
1-E-CS01-4	1st Floor Kitchen	6/1/16 10:30 PM	6/2/16 6:05 AM	None Detected	ND
1-E-CS01-5	1st Floor Kitchen	6/1/16 10:30 PM	6/2/16 6:05 AM	None Detected	ND
1-E-CS02-6	1st Floor Kitchen	6/1/16 10:30 PM	6/2/16 6:07 AM	None Detected	ND
1-E-CS02-7	1st Floor Kitchen	6/1/16 10:30 PM	6/2/16 6:07 AM	None Detected	ND
1-E-CS02-8	1st Floor Kitchen	6/1/16 10:30 PM	6/2/16 6:07 AM	None Detected	ND
1-E-CS02-9	1st Floor Kitchen	6/1/16 10:30 PM	6/2/16 6:07 AM	None Detected	ND
1-E-CS02-10	1st Floor Kitchen	6/1/16 10:30 PM	6/2/16 6:07 AM	None Detected	ND
1-E-CS03-11	1st Floor Kitchen	6/1/16 10:30 PM	6/2/16 6:09 AM	None Detected	ND
1-E-CS03-12	1st Floor Kitchen	6/1/16 10:30 PM	6/2/16 6:09 AM	None Detected	ND
1-E-CS03-13	1st Floor Kitchen	6/1/16 10:30 PM	6/2/16 6:09 AM	None Detected	ND
1-E-CS03-14	1st Floor Kitchen	6/1/16 10:30 PM	6/2/16 6:09 AM	None Detected	ND
1-E-CS03-15	1st Floor Kitchen	6/1/16 10:30 PM	6/2/16 6:09 AM	None Detected	ND
1-N-CS02-46	N Room 117	6/1/16 10:30 PM	6/2/16 6:46 AM	None Detected	ND
1-N-CS02-47	N Room 117	6/1/16 10:30 PM	6/2/16 6:46 AM	None Detected	ND
1-N-CS02-48	N Room 117	6/1/16 10:30 PM	6/2/16 6:46 AM	None Detected	ND
1-N-CS02-49	N Room 117	6/1/16 10:30 PM	6/2/16 6:46 AM	None Detected	ND
1-N-CS02-50	N Room 117	6/1/16 10:30 PM	6/2/16 6:46 AM	None Detected	ND
1-E-F01-61	E Boy's Bathroom	6/1/16 10:30 PM	6/2/16 7:03 AM	None Detected	ND
1-E-F01-62	E Boy's Bathroom	6/1/16 10:30 PM	6/2/16 7:03 AM	None Detected	ND
1-E-F01-63	E Boy's Bathroom	6/1/16 10:30 PM	6/2/16 7:03 AM	None Detected	ND
1-E-F01-64	E Boy's Bathroom	6/1/16 10:30 PM	6/2/16 7:03 AM	None Detected	ND
1-E-F01-65	E Boy's Bathroom	6/1/16 10:30 PM	6/2/16 7:03 AM	None Detected	ND
1-S-CS01-71	S Room 110	6/1/16 10:30 PM	6/2/16 7:11 AM	None Detected	ND
1-S-CS01-72	S Room 110	6/1/16 10:30 PM	6/2/16 7:11 AM	None Detected	ND
1-S-CS01-73	S Room 110	6/1/16 10:30 PM	6/2/16 7:11 AM	None Detected	ND
1-S-CS01-74	S Room 110	6/1/16 10:30 PM	6/2/16 7:11 AM	None Detected	ND
1-S-CS01-75	S Room 110	6/1/16 10:30 PM	6/2/16 7:11 AM	None Detected	ND
1-S-F01-76	S Room 110	6/1/16 10:30 PM	6/2/16 7:12 AM	None Detected	ND
1-S-F01-77	S Room 110	6/1/16 10:30 PM	6/2/16 7:12 AM	None Detected	ND
1-S-F01-78	S Room 110	6/1/16 10:30 PM	6/2/16 7:12 AM	None Detected	ND
1-S-F01-79	S Room 110	6/1/16 10:30 PM	6/2/16 7:12 AM	None Detected	ND
1-S-F01-80	S Room 110	6/1/16 10:30 PM	6/2/16 7:12 AM	None Detected	ND
1-S-F02-86	S Room 108	6/1/16 10:30 PM	6/2/16 7:16 AM	None Detected	ND
1-S-F02-87	S Room 108	6/1/16 10:30 PM	6/2/16 7:16 AM	None Detected	ND
1-S-F02-88	S Room 108	6/1/16 10:30 PM	6/2/16 7:16 AM	None Detected	ND
1-S-F02-89	S Room 108	6/1/16 10:30 PM	6/2/16 7:16 AM	None Detected	ND
1-S-F02-90	S Room 108	6/1/16 10:30 PM	6/2/16 7:16 AM	None Detected	ND
2-N-F01-91	N Janitorial Closet	6/1/16 10:30 PM	6/2/16 7:27 AM	None Detected	ND
2-N-F01-92	N Janitorial Closet	6/1/16 10:30 PM	6/2/16 7:27 AM	None Detected	ND
2-N-F01-93	N Janitorial Closet	6/1/16 10:30 PM	6/2/16 7:27 AM	None Detected	ND
2-N-F01-94	N Janitorial Closet	6/1/16 10:30 PM	6/2/16 7:27 AM	None Detected	ND
2-N-F01-95	N Janitorial Closet	6/1/16 10:30 PM	6/2/16 7:27 AM	None Detected	ND
2-N-F02-96	N Janitorial Closet	6/1/16 10:30 PM	6/2/16 7:28 AM	None Detected	ND

Sample ID #	Sample Location	Water Last Used (Time & Date)	Sample Collection Time & Date	Test Result (ppb)	Test Results
2-N-F02-97	N Janitorial Closet	6/1/16 10:30 PM	6/2/16 7:28 AM	None Detected	ND
2-N-F02-98	N Janitorial Closet	6/1/16 10:30 PM	6/2/16 7:28 AM	None Detected	ND
2-N-F02-99	N Janitorial Closet	6/1/16 10:30 PM	6/2/16 7:28 AM	None Detected	ND
2-N-F02-100	N Janitorial Closet	6/1/16 10:30 PM	6/2/16 7:28 AM	None Detected	ND
2-N-F01-101	N Boy's Room	6/1/16 10:30 PM	6/2/16 7:34 AM	None Detected	ND
2-N-F01-102	N Boy's Room	6/1/16 10:30 PM	6/2/16 7:34 AM	None Detected	ND
2-N-F01-103	N Boy's Room	6/1/16 10:30 PM	6/2/16 7:34 AM	None Detected	ND
2-N-F01-104	N Boy's Room	6/1/16 10:30 PM	6/2/16 7:34 AM	None Detected	ND
2-N-F01-105	N Boy's Room	6/1/16 10:30 PM	6/2/16 7:34 AM	None Detected	ND
2-N-F02-106	N Boy's Room	6/1/16 10:30 PM	6/2/16 7:35 AM	None Detected	ND
2-N-F02-107	N Boy's Room	6/1/16 10:30 PM	6/2/16 7:35 AM	None Detected	ND
2-N-F02-108	N Boy's Room	6/1/16 10:30 PM	6/2/16 7:35 AM	None Detected	ND
2-N-F02-109	N Boy's Room	6/1/16 10:30 PM	6/2/16 7:35 AM	None Detected	ND
2-N-F02-110	N Boy's Room	6/1/16 10:30 PM	6/2/16 7:35 AM	None Detected	ND
2-S-F01-111	S Girl's Bathroom	6/1/16 10:30 PM	6/2/16 7:40 AM	None Detected	ND
2-S-F01-112	S Girl's Bathroom	6/1/16 10:30 PM	6/2/16 7:40 AM	None Detected	ND
2-S-F01-113	S Girl's Bathroom	6/1/16 10:30 PM	6/2/16 7:40 AM	None Detected	ND
2-S-F01-114	S Girl's Bathroom	6/1/16 10:30 PM	6/2/16 7:40 AM	None Detected	ND
2-S-F01-115	S Girl's Bathroom	6/1/16 10:30 PM	6/2/16 7:40 AM	None Detected	ND
1-S-CS01-116	S Girl's Bathroom	6/1/16 10:30 PM	6/2/16 7:45 AM	None Detected	ND
1-S-CS01-117	S Girl's Bathroom	6/1/16 10:30 PM	6/2/16 7:45 AM	None Detected	ND
1-S-CS01-118	S Girl's Bathroom	6/1/16 10:30 PM	6/2/16 7:45 AM	None Detected	ND
1-S-CS01-119	S Girl's Bathroom	6/1/16 10:30 PM	6/2/16 7:45 AM	None Detected	ND
1-S-CS01-120	S Girl's Bathroom	6/1/16 10:30 PM	6/2/16 7:45 AM	None Detected	ND
2-S-CS02-121	S Girl's Bathroom	6/1/16 10:30 PM	6/2/16 7:46 AM	None Detected	ND
2-S-CS02-122	S Girl's Bathroom	6/1/16 10:30 PM	6/2/16 7:46 AM	None Detected	ND
2-S-CS02-123	S Girl's Bathroom	6/1/16 10:30 PM	6/2/16 7:46 AM	None Detected	ND
2-S-CS02-124	S Girl's Bathroom	6/1/16 10:30 PM	6/2/16 7:46 AM	None Detected	ND
2-S-CS02-125	S Girl's Bathroom	6/1/16 10:30 PM	6/2/16 7:46 AM	None Detected	ND
3-N-F01-126	N Janitorial Closet	6/1/16 10:30 PM	6/2/16 7:55 AM	None Detected	ND
3-N-F01-127	N Janitorial Closet	6/1/16 10:30 PM	6/2/16 7:55 AM	None Detected	ND
3-N-F01-128	N Janitorial Closet	6/1/16 10:30 PM	6/2/16 7:55 AM	None Detected	ND
3-N-F01-129	N Janitorial Closet	6/1/16 10:30 PM	6/2/16 7:55 AM	None Detected	ND
3-N-F01-130	N Janitorial Closet	6/1/16 10:30 PM	6/2/16 7:55 AM	None Detected	ND
3-N-F02-131	Janitorial Closet	6/1/16 10:30 PM	6/2/16 7:56 AM	None Detected	ND
3-N-F02-132	Janitorial Closet	6/1/16 10:30 PM	6/2/16 7:56 AM	None Detected	ND
3-N-F02-133	Janitorial Closet	6/1/16 10:30 PM	6/2/16 7:56 AM	None Detected	ND
3-N-F02-134	Janitorial Closet	6/1/16 10:30 PM	6/2/16 7:56 AM	None Detected	ND
3-N-F02-135	Janitorial Closet	6/1/16 10:30 PM	6/2/16 7:56 AM	None Detected	ND
3-N-F01-136	N Boy's Bathroom	6/1/16 10:30 PM	6/2/16 8:00 AM	None Detected	ND
3-N-F01-137	N Boy's Bathroom	6/1/16 10:30 PM	6/2/16 8:00 AM	None Detected	ND
3-N-F01-138	N Boy's Bathroom	6/1/16 10:30 PM	6/2/16 8:00 AM	None Detected	ND
3-N-F01-139	N Boy's Bathroom	6/1/16 10:30 PM	6/2/16 8:00 AM	None Detected	ND
3-N-F01-140	N Boy's Bathroom	6/1/16 10:30 PM	6/2/16 8:00 AM	None Detected	ND
3-N-F02-141	N Boy's Bathroom	6/1/16 10:30 PM	6/2/16 8:01 AM	None Detected	ND
3-N-F02-142	N Boy's Bathroom	6/1/16 10:30 PM	6/2/16 8:01 AM	None Detected	ND
3-N-F02-143	N Boy's Bathroom	6/1/16 10:30 PM	6/2/16 8:01 AM	None Detected	ND
3-N-F02-144	N Boy's Bathroom	6/1/16 10:30 PM	6/2/16 8:01 AM	None Detected	ND
3-N-F02-145	N Boy's Bathroom	6/1/16 10:30 PM	6/2/16 8:01 AM	None Detected	ND
3-S-F01-146	S Girl's Bathroom	6/1/16 10:30 PM	6/2/16 8:06 AM	None Detected	ND

Sample ID #	Sample Location	Water Last Used (Time & Date)	Sample Collection Time & Date	Test Result (ppb)	Test Results
3-S-F01-147	S Girl's Bathroom	6/1/16 10:30 PM	6/2/16 8:06 AM	None Detected	ND
3-S-F01-148	S Girl's Bathroom	6/1/16 10:30 PM	6/2/16 8:06 AM	None Detected	ND
3-S-F01-149	S Girl's Bathroom	6/1/16 10:30 PM	6/2/16 8:06 AM	None Detected	ND
3-S-F01-150	S Girl's Bathroom	6/1/16 10:30 PM	6/2/16 8:06 AM	None Detected	ND
3-S-F02-151	S Girl's Bathroom	6/1/16 10:30 PM	6/2/16 8:07 AM	None Detected	ND
3-S-F02-152	S Girl's Bathroom	6/1/16 10:30 PM	6/2/16 8:07 AM	None Detected	ND
3-S-F02-153	S Girl's Bathroom	6/1/16 10:30 PM	6/2/16 8:07 AM	None Detected	ND
3-S-F02-154	S Girl's Bathroom	6/1/16 10:30 PM	6/2/16 8:07 AM	None Detected	ND
3-S-F02-155	S Girl's Bathroom	6/1/16 10:30 PM	6/2/16 8:07 AM	None Detected	ND
B-S-F01-156	Basement Girl's Playroom	6/1/16 10:30 PM	6/2/16 8:17 AM	None Detected	ND
B-S-F01-157	Basement Girl's Playroom	6/1/16 10:30 PM	6/2/16 8:17 AM	None Detected	ND
B-S-F01-158	Basement Girl's Playroom	6/1/16 10:30 PM	6/2/16 8:17 AM	None Detected	ND
B-S-F01-159	Basement Girl's Playroom	6/1/16 10:30 PM	6/2/16 8:17 AM	None Detected	ND
B-S-F01-160	Basement Girl's Playroom	6/1/16 10:30 PM	6/2/16 8:17 AM	None Detected	ND
B-S-F04-161	Basement Girl's Playroom	6/1/16 10:30 PM	6/2/16 8:18 AM	None Detected	ND
B-S-F04-162	Basement Girl's Playroom	6/1/16 10:30 PM	6/2/16 8:18 AM	None Detected	ND
B-S-F04-163	Basement Girl's Playroom	6/1/16 10:30 PM	6/2/16 8:18 AM	None Detected	ND
B-S-F04-164	Basement Girl's Playroom	6/1/16 10:30 PM	6/2/16 8:18 AM	None Detected	ND
B-S-F04-165	Basement Girl's Playroom	6/1/16 10:30 PM	6/2/16 8:18 AM	None Detected	ND
1-N-CS01-01	N Room 115	8/9/16 10:00 PM	8/10/16 6:32 AM	0.521	BA
1-N-CS01-02	N Room 115	8/9/16 10:00 PM	8/10/16 6:32 AM	0.2	BA
1-N-CS01-03	N Room 115	8/9/16 10:00 PM	8/10/16 6:32 AM	0.196	BA
1-N-CS01-04	N Room 115	8/9/16 10:00 PM	8/10/16 6:32 AM	0.195	BA
1-N-CS01-05	N Room 115	8/9/16 10:00 PM	8/10/16 6:32 AM	0.262	BA
1-N-F01-06	N Room 115	8/9/16 10:00 PM	8/10/16 6:40 AM	0.443	BA
1-N-F01-07	N Room 115	8/9/16 10:00 PM	8/10/16 6:40 AM	0.314	BA
1-N-F01-08	N Room 115	8/9/16 10:00 PM	8/10/16 6:40 AM	0.182	BA
1-N-F01-09	N Room 115	8/9/16 10:00 PM	8/10/16 6:40 AM	0.143	BA
1-N-F01-10	N Room 115	8/9/16 10:00 PM	8/10/16 6:40 AM	0.151	BA
1-W-CS01-11	W Room 116	8/9/16 10:00 PM	8/10/16 6:45 AM	0.305	BA
1-W-CS01-12	W Room 116	8/9/16 10:00 PM	8/10/16 6:45 AM	0.274	BA
1-W-CS01-13	W Room 116	8/9/16 10:00 PM	8/10/16 6:45 AM	0.272	BA
1-W-CS01-14	W Room 116	8/9/16 10:00 PM	8/10/16 6:45 AM	0.277	BA
1-W-CS01-15	W Room 116	8/9/16 10:00 PM	8/10/16 6:45 AM	0.241	BA
1-W-CS02-16	W Room 116	8/9/16 10:00 PM	8/10/16 6:50 AM	<0.750	BA
1-W-CS02-17	W Room 116	8/9/16 10:00 PM	8/10/16 6:50 AM	0.342	BA
1-W-CS02-18	W Room 116	8/9/16 10:00 PM	8/10/16 6:50 AM	0.629	BA
1-W-CS02-19	W Room 116	8/9/16 10:00 PM	8/10/16 6:50 AM	0.345	BA
1-W-CS02-20	W Room 116	8/9/16 10:00 PM	8/10/16 6:50 AM	0.375	BA
1-W-F01-21	W Room 116	8/9/16 10:00 PM	8/10/16 6:55 AM	0.613	BA
1-W-F01-22	W Room 116	8/9/16 10:00 PM	8/10/16 6:55 AM	0.623	BA
1-W-F01-23	W Room 116	8/9/16 10:00 PM	8/10/16 6:55 AM	0.381	BA
1-W-F01-24	W Room 116	8/9/16 10:00 PM	8/10/16 6:55 AM	0.335	BA
1-W-F01-25	W Room 116	8/9/16 10:00 PM	8/10/16 6:55 AM	0.249	BA
1-N-CS01-26	N Room 117	8/9/16 10:00 PM	8/10/16 7:00 AM	<0.750	BA
1-N-CS01-27	N Room 117	8/9/16 10:00 PM	8/10/16 7:00 AM	0.203	BA
1-N-CS01-28	N Room 117	8/9/16 10:00 PM	8/10/16 7:00 AM	0.17	BA
1-N-CS01-29	N Room 117	8/9/16 10:00 PM	8/10/16 7:00 AM	0.16	BA
1-N-CS01-30	N Room 117	8/9/16 10:00 PM	8/10/16 7:00 AM	0.171	BA
1-E-F02-31	E Boy's Bathroom	8/9/16 10:00 PM	8/10/16 7:05 AM	5.14	BA
1-E-F02-32	E Boy's Bathroom	8/9/16 10:00 PM	8/10/16 7:05 AM	5.51	BA

Sample ID #	Sample Location	Water Last Used (Time & Date)	Sample Collection Time & Date	Test Result (ppb)	Test Results
1-E-F02-33	E Boy's Bathroom	8/9/16 10:00 PM	8/10/16 7:05 AM	6.85	BA
1-E-F02-34	E Boy's Bathroom	8/9/16 10:00 PM	8/10/16 7:05 AM	3.77	BA
1-E-F02-35	E Boy's Bathroom	8/9/16 10:00 PM	8/10/16 7:05 AM	2.86	BA
1-E-F01-36	E Janitorial Closet	8/9/16 10:00 PM	8/10/16 7:10 AM	3.97	BA
1-E-F01-37	E Janitorial Closet	8/9/16 10:00 PM	8/10/16 7:10 AM	1.45	BA
1-E-F01-38	E Janitorial Closet	8/9/16 10:00 PM	8/10/16 7:10 AM	1.2	BA
1-E-F01-39	E Janitorial Closet	8/9/16 10:00 PM	8/10/16 7:10 AM	1.01	BA
1-E-F01-40	E Janitorial Closet	8/9/16 10:00 PM	8/10/16 7:10 AM	0.837	BA
1-E-F02-41	E Janitorial Closet	8/9/16 10:00 PM	8/10/16 7:15 AM	2.58	BA
1-E-F02-42	E Janitorial Closet	8/9/16 10:00 PM	8/10/16 7:15 AM	2.2	BA
1-E-F02-43	E Janitorial Closet	8/9/16 10:00 PM	8/10/16 7:15 AM	1.26	BA
1-E-F02-44	E Janitorial Closet	8/9/16 10:00 PM	8/10/16 7:15 AM	1.34	BA
1-E-F02-45	E Janitorial Closet	8/9/16 10:00 PM	8/10/16 7:15 AM	0.941	BA
1-S-F01-46	S Room 110	8/9/16 10:00 PM	8/10/16 7:20 AM	0.198	BA
1-S-F01-47	S Room 110	8/9/16 10:00 PM	8/10/16 7:20 AM	<0.120	BA
1-S-F01-48	S Room 110	8/9/16 10:00 PM	8/10/16 7:20 AM	0.159	BA
1-S-F01-49	S Room 110	8/9/16 10:00 PM	8/10/16 7:20 AM	0.229	BA
1-S-F01-50	S Room 110	8/9/16 10:00 PM	8/10/16 7:20 AM	0.225	BA
1-S-F01-51	S Room 108	8/9/16 10:00 PM	8/10/16 7:25 AM	<0.120	BA
1-S-F01-52	S Room 108	8/9/16 10:00 PM	8/10/16 7:25 AM	<0.120	BA
1-S-F01-53	S Room 108	8/9/16 10:00 PM	8/10/16 7:25 AM	<0.120	BA
1-S-F01-54	S Room 108	8/9/16 10:00 PM	8/10/16 7:25 AM	<0.120	BA
1-S-F01-55	S Room 108	8/9/16 10:00 PM	8/10/16 7:25 AM	<0.120	BA

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit

BA-Below EPA Action Level of 15 ppb

AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations