



November 21, 2016

Dear CPS family,

In light of national events that have brought increased attention to the issue of water quality, the City of Chicago announced several additional precautionary measures that will be added to the City's water testing protocol, continuing the City's track record of complying with current state and federal regulations as well as exceeding industry standards.

As part of this announcement, Chicago Public Schools (CPS) began testing the water for levels of lead from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe. Schools are being tested based on a priority criteria that includes the age of the school, age of the students (with priority given to schools with pre-K programs), presence of a kitchen (where meals are prepared) and presence of pipes that could need repairs or replacement.

The results of all the schools are coming in on a rolling basis, and the majority have had levels under the EPA's action level of 15 parts per billion (ppb). We wanted to let you know that no lead was found above the action level in your child's school. The full results of your school's water samples can be found online at [cps.edu/leadtesting](http://cps.edu/leadtesting).

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician for testing. Additionally, CDPH's lead hotline can address any health related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

Forrest Claypool  
CEO, Chicago Public Schools

Dr. Julie Morita  
Commissioner, Chicago Department of Public Health





Estimadas familias de CPS,

Ante los eventos nacionales que han incrementado la atención en el tema de la calidad del agua, la Alcaldía de Chicago anunció varias medidas adicionales de precaución que serán agregadas al protocolo de prueba del agua de la ciudad, continuando con el cumplimiento de las regulaciones estatales y federales, que exceden los estándares industriales.

Como parte de este anuncio, las Escuelas Públicas de Chicago (CPS) comenzaron a medir los niveles de plomo en el agua de todas las escuelas del distrito. Nuestra principal prioridad es la salud y seguridad de todos nuestros estudiantes y personal, y estas pruebas fueron iniciadas solamente para extremar las precauciones y estar seguros de que el agua es segura. Las escuelas son examinadas con base a un criterio de prioridad que incluye la antigüedad del edificio, edad de los estudiantes (con prioridad para las escuelas con programas preescolares), presencia de una cocina (donde se preparan alimentos) y la presencia de cañerías que necesiten reparación o reemplazo.

Los resultados de todas las escuelas se están conociendo, y la mayoría ha registrado niveles por debajo del nivel de acción de la EPA, que es de 15 partículas por billón (ppb). Queremos hacerles saber que no se encontraron rastros de plomo por encima del nivel de acción en la escuela de su niño. Los resultados completos de las pruebas en su escuela se pueden ver en línea en [cps.edu/leadtesting](https://cps.edu/leadtesting).

Los lineamientos federales indican que los niños menores de seis años son los que corren mayores riesgos con la exposición al plomo, algo que puede ocurrir de varias fuentes, incluyendo pintura, tierra y algunos productos de consumo. Si están preocupados por la posible exposición de su hijo al plomo, el Departamento de Salud Pública de la ciudad de Chicago (CDPH) recomienda visitar a su pediatra o a alguno de los centros de salud listados en el material adjunto, para una prueba. Además, la línea directa del CDPH puede responder cualquier pregunta que tengan, o ayudarlos a decidir si su niño debe ser examinado; por preguntas o más información, llame por favor al 312-747-5323. Por información adicional sobre el plomo y los niños, visite [www.cdc.gov/lead](https://www.cdc.gov/lead).

La seguridad de sus hijos es nuestra principal prioridad, y hacemos todo lo que está en nuestro poder para resolver esta situación de una manera rápida y rigurosa. Continuaremos informándoles sobre este proceso.

Atentamente,

Forrest Claypool  
CEO, Escuelas Públicas de Chicago

Dra. Julie Morita, Comisionada  
Departamento de Salud Pública de Chicago





## School Lead Water Testing - Data Collection Form

School Short Name **Crane Medical HS**

Date of test 10/27/16

School Short Name	Facility ID	Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
Crane Medical HS	51564	51564-1-HAL-F02-001	1st Floor Hallway Outside Rm. 117 Left Fountain	10/27/16 6:00 AM	0.282	BA
Crane Medical HS	51564	51564-1-HAL-F02-002	1st Floor Hallway Outside Rm. 117 Left Fountain	10/27/16 6:00 AM	0.262	BA
Crane Medical HS	51564	51564-1-HAL-F02-003	1st Floor Hallway Outside Rm. 117 Left Fountain	10/27/16 6:00 AM	0.287	BA
Crane Medical HS	51564	51564-1-HAL-F02-004	1st Floor Hallway Outside Rm. 117 Left Fountain	10/27/16 6:00 AM	0.282	BA
Crane Medical HS	51564	51564-1-HAL-F02-005	1st Floor Hallway Outside Rm. 117 Left Fountain	10/27/16 6:00 AM	0.265	BA
Crane Medical HS	51564	51564-1-HAL-F03-001	1st Floor Hallway Outside Rm. 117 Right Fountain	10/27/16 6:00 AM	0.215	BA
Crane Medical HS	51564	51564-1-HAL-F03-002	1st Floor Hallway Outside Rm. 117 Right Fountain	10/27/16 6:00 AM	0.239	BA
Crane Medical HS	51564	51564-1-HAL-F03-003	1st Floor Hallway Outside Rm. 117 Right Fountain	10/27/16 6:00 AM	0.239	BA
Crane Medical HS	51564	51564-1-HAL-F03-004	1st Floor Hallway Outside Rm. 117 Right Fountain	10/27/16 6:00 AM	0.226	BA
Crane Medical HS	51564	51564-1-HAL-F03-005	1st Floor Hallway Outside Rm. 117 Right Fountain	10/27/16 6:00 AM	0.218	BA
Crane Medical HS	51564	51564-1-HAL-F04-001	1st Floor Hallway Outside Rm. 101 Right Fountain	10/27/16 6:00 AM	2.35	BA
Crane Medical HS	51564	51564-1-HAL-F04-002	1st Floor Hallway Outside Rm. 101 Right Fountain	10/27/16 6:00 AM	3.55	BA
Crane Medical HS	51564	51564-1-HAL-F04-003	1st Floor Hallway Outside Rm. 101 Right Fountain	10/27/16 6:00 AM	2.15	BA
Crane Medical HS	51564	51564-1-HAL-F04-004	1st Floor Hallway Outside Rm. 101 Right Fountain	10/27/16 6:00 AM	1.87	BA
Crane Medical HS	51564	51564-1-HAL-F04-005	1st Floor Hallway Outside Rm. 101 Right Fountain	10/27/16 6:00 AM	2.81	BA
Crane Medical HS	51564	51564-1-HAL-F05-001	1st Floor Hallway Outside Rm. 101 Left Fountain	10/27/16 6:00 AM	1.63	BA
Crane Medical HS	51564	51564-1-HAL-F05-002	1st Floor Hallway Outside Rm. 101 Left Fountain	10/27/16 6:00 AM	2	BA
Crane Medical HS	51564	51564-1-HAL-F05-003	1st Floor Hallway Outside Rm. 101 Left Fountain	10/27/16 6:00 AM	0.766	BA
Crane Medical HS	51564	51564-1-HAL-F05-004	1st Floor Hallway Outside Rm. 101 Left Fountain	10/27/16 6:00 AM	0.419	BA
Crane Medical HS	51564	51564-1-HAL-F05-005	1st Floor Hallway Outside Rm. 101 Left Fountain	10/27/16 6:00 AM	0.367	BA
Crane Medical HS	51564	51564-1-HAL-F06-001	1st Floor Hallway Across Rm. 105 Single Fountain	10/27/16 6:00 AM	0.232	BA
Crane Medical HS	51564	51564-1-HAL-F06-002	1st Floor Hallway Across Rm. 105 Single Fountain	10/27/16 6:00 AM	0.174	BA
Crane Medical HS	51564	51564-1-HAL-F06-003	1st Floor Hallway Across Rm. 105 Single Fountain	10/27/16 6:00 AM	0.167	BA
Crane Medical HS	51564	51564-1-HAL-F06-004	1st Floor Hallway Across Rm. 105 Single Fountain	10/27/16 6:00 AM	0.162	BA
Crane Medical HS	51564	51564-1-HAL-F06-005	1st Floor Hallway Across Rm. 105 Single Fountain	10/27/16 6:00 AM	0.177	BA
Crane Medical HS	51564	51564-1-HAL-F07-001	1st Floor Hallway Across Rm. 110 Single Fountain	10/27/16 6:00 AM	1.66	BA
Crane Medical HS	51564	51564-1-HAL-F07-002	1st Floor Hallway Across Rm. 110 Single Fountain	10/27/16 6:00 AM	1.26	BA
Crane Medical HS	51564	51564-1-HAL-F07-003	1st Floor Hallway Across Rm. 110 Single Fountain	10/27/16 6:00 AM	0.75	BA
Crane Medical HS	51564	51564-1-HAL-F07-004	1st Floor Hallway Across Rm. 110 Single Fountain	10/27/16 6:00 AM	1.55	BA
Crane Medical HS	51564	51564-1-HAL-F07-005	1st Floor Hallway Across Rm. 110 Single Fountain	10/27/16 6:00 AM	3.3	BA
Crane Medical HS	51564	51564-1-153-WC08-001	1st Floor Inside Rm. 153 Single Water Cooler	10/27/16 6:00 AM	0.475	BA
Crane Medical HS	51564	51564-1-153-WC08-002	1st Floor Inside Rm. 153 Single Water Cooler	10/27/16 6:00 AM	0.443	BA
Crane Medical HS	51564	51564-1-153-WC08-003	1st Floor Inside Rm. 153 Single Water Cooler	10/27/16 6:00 AM	0.403	BA
Crane Medical HS	51564	51564-1-153-WC08-004	1st Floor Inside Rm. 153 Single Water Cooler	10/27/16 6:00 AM	0.395	BA
Crane Medical HS	51564	51564-1-153-WC08-005	1st Floor Inside Rm. 153 Single Water Cooler	10/27/16 6:00 AM	0.385	BA
Crane Medical HS	51564	51564-1-GYM-F09-001	1st Floor Inside Gym Right Fountain	10/27/16 6:00 AM	2.85	BA
Crane Medical HS	51564	51564-1-GYM-F09-002	1st Floor Inside Gym Right Fountain	10/27/16 6:00 AM	2.96	BA
Crane Medical HS	51564	51564-1-GYM-F09-003	1st Floor Inside Gym Right Fountain	10/27/16 6:00 AM	2.11	BA
Crane Medical HS	51564	51564-1-GYM-F09-004	1st Floor Inside Gym Right Fountain	10/27/16 6:00 AM	1.82	BA
Crane Medical HS	51564	51564-1-GYM-F09-005	1st Floor Inside Gym Right Fountain	10/27/16 6:00 AM	1.84	BA
Crane Medical HS	51564	51564-1-LR-F13-001	1st Floor Inside Boys Locker Rm. Single Fountain	10/27/16 6:00 AM	1.04	BA

Crane Medical HS	51564	51564-1-LR-F13-002	1st Floor Inside Boys Locker Rm. Single Fountain	10/27/16 6:00 AM	0.716	BA
Crane Medical HS	51564	51564-1-LR-F13-003	1st Floor Inside Boys Locker Rm. Single Fountain	10/27/16 6:00 AM	0.715	BA
Crane Medical HS	51564	51564-1-LR-F13-004	1st Floor Inside Boys Locker Rm. Single Fountain	10/27/16 6:00 AM	0.702	BA
Crane Medical HS	51564	51564-1-LR-F13-005	1st Floor Inside Boys Locker Rm. Single Fountain	10/27/16 6:00 AM	0.63	BA
Crane Medical HS	51564	51564-2-HAL-F01-001	2nd Floor Hallway Across Rm. 214 Single Fountain	10/27/16 6:00 AM	<0.120	ND
Crane Medical HS	51564	51564-2-HAL-F01-002	2nd Floor Hallway Across Rm. 214 Single Fountain	10/27/16 6:00 AM	<0.120	ND
Crane Medical HS	51564	51564-2-HAL-F01-003	2nd Floor Hallway Across Rm. 214 Single Fountain	10/27/16 6:00 AM	<0.120	ND
Crane Medical HS	51564	51564-2-HAL-F01-004	2nd Floor Hallway Across Rm. 214 Single Fountain	10/27/16 6:00 AM	<0.120	ND
Crane Medical HS	51564	51564-2-HAL-F01-005	2nd Floor Hallway Across Rm. 214 Single Fountain	10/27/16 6:00 AM	<0.120	ND
Crane Medical HS	51564	51564-2-HAL-F03-001	2nd Floor Hallway Next to Rm. 201 Single Fountain	10/27/16 6:00 AM	7.24	BA
Crane Medical HS	51564	51564-2-HAL-F03-002	2nd Floor Hallway Next to Rm. 201 Single Fountain	10/27/16 6:00 AM	4.4	BA
Crane Medical HS	51564	51564-2-HAL-F03-003	2nd Floor Hallway Next to Rm. 201 Single Fountain	10/27/16 6:00 AM	4.24	BA
Crane Medical HS	51564	51564-2-HAL-F03-004	2nd Floor Hallway Next to Rm. 201 Single Fountain	10/27/16 6:00 AM	4.01	BA
Crane Medical HS	51564	51564-2-HAL-F03-005	2nd Floor Hallway Next to Rm. 201 Single Fountain	10/27/16 6:00 AM	13.7	BA
Crane Medical HS	51564	51564-2-HAL-F04-001	2nd Floor Hallway Across Rm. 204 Single Fountain	10/27/16 6:00 AM	<0.120	ND
Crane Medical HS	51564	51564-2-HAL-F04-002	2nd Floor Hallway Across Rm. 204 Single Fountain	10/27/16 6:00 AM	<0.120	ND
Crane Medical HS	51564	51564-2-HAL-F04-003	2nd Floor Hallway Across Rm. 204 Single Fountain	10/27/16 6:00 AM	<0.120	ND
Crane Medical HS	51564	51564-2-HAL-F04-004	2nd Floor Hallway Across Rm. 204 Single Fountain	10/27/16 6:00 AM	<0.120	ND
Crane Medical HS	51564	51564-2-HAL-F04-005	2nd Floor Hallway Across Rm. 204 Single Fountain	10/27/16 6:00 AM	<0.120	ND
Crane Medical HS	51564	51564-2-TL-S06-001	2nd Floor Sink Inside Teachers Lounge Rm. 206	10/27/16 6:00 AM	0.551	BA
Crane Medical HS	51564	51564-2-TL-S06-002	2nd Floor Sink Inside Teachers Lounge Rm. 206	10/27/16 6:00 AM	0.791	BA
Crane Medical HS	51564	51564-2-TL-S06-003	2nd Floor Sink Inside Teachers Lounge Rm. 206	10/27/16 6:00 AM	0.751	BA
Crane Medical HS	51564	51564-2-TL-S06-004	2nd Floor Sink Inside Teachers Lounge Rm. 206	10/27/16 6:00 AM	0.698	BA
Crane Medical HS	51564	51564-2-TL-S06-005	2nd Floor Sink Inside Teachers Lounge Rm. 206	10/27/16 6:00 AM	0.665	BA
Crane Medical HS	51564	51564-3-KIT-KS01-001	3rd Floor Kitchen Triple Basin E. Wall Left Sink	10/27/16 6:00 AM	0.859	BA
Crane Medical HS	51564	51564-3-KIT-KS01-002	3rd Floor Kitchen Triple Basin E. Wall Left Sink	10/27/16 6:00 AM	1.1	BA
Crane Medical HS	51564	51564-3-KIT-KS01-003	3rd Floor Kitchen Triple Basin E. Wall Left Sink	10/27/16 6:00 AM	0.863	BA
Crane Medical HS	51564	51564-3-KIT-KS01-004	3rd Floor Kitchen Triple Basin E. Wall Left Sink	10/27/16 6:00 AM	0.751	BA
Crane Medical HS	51564	51564-3-KIT-KS01-005	3rd Floor Kitchen Triple Basin E. Wall Left Sink	10/27/16 6:00 AM	0.799	BA
Crane Medical HS	51564	51564-3-KIT-KS02-001	3rd Floor Kitchen Triple Basin E. Wall Center Sink	10/27/16 6:00 AM	0.879	BA
Crane Medical HS	51564	51564-3-KIT-KS02-002	3rd Floor Kitchen Triple Basin E. Wall Center Sink	10/27/16 6:00 AM	1.3	BA
Crane Medical HS	51564	51564-3-KIT-KS02-003	3rd Floor Kitchen Triple Basin E. Wall Center Sink	10/27/16 6:00 AM	1.7	BA
Crane Medical HS	51564	51564-3-KIT-KS02-004	3rd Floor Kitchen Triple Basin E. Wall Center Sink	10/27/16 6:00 AM	0.743	BA
Crane Medical HS	51564	51564-3-KIT-KS02-005	3rd Floor Kitchen Triple Basin E. Wall Center Sink	10/27/16 6:00 AM	0.841	BA
Crane Medical HS	51564	51564-3-KIT-KS03-001	3rd Floor Kitchen Triple Basin E. Wall Right Sink	10/27/16 6:00 AM	4.49	BA
Crane Medical HS	51564	51564-3-KIT-KS03-002	3rd Floor Kitchen Triple Basin E. Wall Right Sink	10/27/16 6:00 AM	3.45	BA
Crane Medical HS	51564	51564-3-KIT-KS03-003	3rd Floor Kitchen Triple Basin E. Wall Right Sink	10/27/16 6:00 AM	1.52	BA
Crane Medical HS	51564	51564-3-KIT-KS03-004	3rd Floor Kitchen Triple Basin E. Wall Right Sink	10/27/16 6:00 AM	1.56	BA
Crane Medical HS	51564	51564-3-KIT-KS03-005	3rd Floor Kitchen Triple Basin E. Wall Right Sink	10/27/16 6:00 AM	1.28	BA
Crane Medical HS	51564	51564-3-KIT-KS04-001	3rd Floor Kitchen E. Triple Basin S. Wall Left Sink	10/27/16 6:00 AM	1.09	BA
Crane Medical HS	51564	51564-3-KIT-KS04-002	3rd Floor Kitchen E. Triple Basin S. Wall Left Sink	10/27/16 6:00 AM	1.35	BA
Crane Medical HS	51564	51564-3-KIT-KS04-003	3rd Floor Kitchen E. Triple Basin S. Wall Left Sink	10/27/16 6:00 AM	0.499	BA
Crane Medical HS	51564	51564-3-KIT-KS04-004	3rd Floor Kitchen E. Triple Basin S. Wall Left Sink	10/27/16 6:00 AM	0.446	BA
Crane Medical HS	51564	51564-3-KIT-KS04-005	3rd Floor Kitchen E. Triple Basin S. Wall Left Sink	10/27/16 6:00 AM	0.712	BA
Crane Medical HS	51564	51564-3-KIT-KS05-001	3rd Floor Kitchen E. Triple Basin S. Wall Right Sink	10/27/16 6:00 AM	0.649	BA
Crane Medical HS	51564	51564-3-KIT-KS05-002	3rd Floor Kitchen E. Triple Basin S. Wall Right Sink	10/27/16 6:00 AM	0.578	BA
Crane Medical HS	51564	51564-3-KIT-KS05-003	3rd Floor Kitchen E. Triple Basin S. Wall Right Sink	10/27/16 6:00 AM	0.46	BA
Crane Medical HS	51564	51564-3-KIT-KS05-004	3rd Floor Kitchen E. Triple Basin S. Wall Right Sink	10/27/16 6:00 AM	0.48	BA
Crane Medical HS	51564	51564-3-KIT-KS05-005	3rd Floor Kitchen E. Triple Basin S. Wall Right Sink	10/27/16 6:00 AM	0.336	BA
Crane Medical HS	51564	51564-3-KIT-KS06-001	3rd Floor Kitchen W. Triple Basin S. Wall Left Sink	10/27/16 6:00 AM	0.579	BA
Crane Medical HS	51564	51564-3-KIT-KS06-002	3rd Floor Kitchen W. Triple Basin S. Wall Left Sink	10/27/16 6:00 AM	0.573	BA
Crane Medical HS	51564	51564-3-KIT-KS06-003	3rd Floor Kitchen W. Triple Basin S. Wall Left Sink	10/27/16 6:00 AM	0.495	BA
Crane Medical HS	51564	51564-3-KIT-KS06-004	3rd Floor Kitchen W. Triple Basin S. Wall Left Sink	10/27/16 6:00 AM	0.24	BA
Crane Medical HS	51564	51564-3-KIT-KS06-005	3rd Floor Kitchen W. Triple Basin S. Wall Left Sink	10/27/16 6:00 AM	0.189	BA

Crane Medical HS	51564	51564-3-KIT-KS07-001	3rd Floor Kitchen W. Triple Basin S. Wall Right Sink	10/27/16 6:00 AM	1.43	BA
Crane Medical HS	51564	51564-3-KIT-KS07-002	3rd Floor Kitchen W. Triple Basin S. Wall Right Sink	10/27/16 6:00 AM	0.326	BA
Crane Medical HS	51564	51564-3-KIT-KS07-003	3rd Floor Kitchen W. Triple Basin S. Wall Right Sink	10/27/16 6:00 AM	1.78	BA
Crane Medical HS	51564	51564-3-KIT-KS07-004	3rd Floor Kitchen W. Triple Basin S. Wall Right Sink	10/27/16 6:00 AM	4.44	BA
Crane Medical HS	51564	51564-3-KIT-KS07-005	3rd Floor Kitchen W. Triple Basin S. Wall Right Sink	10/27/16 6:00 AM	1	BA
Crane Medical HS	51564	51564-3-KIT-KS08-001	3rd Floor Kitchen Island Sink	10/27/16 6:00 AM	5.87	BA
Crane Medical HS	51564	51564-3-KIT-KS08-002	3rd Floor Kitchen Island Sink	10/27/16 6:00 AM	2.6	BA
Crane Medical HS	51564	51564-3-KIT-KS08-003	3rd Floor Kitchen Island Sink	10/27/16 6:00 AM	1.76	BA
Crane Medical HS	51564	51564-3-KIT-KS08-004	3rd Floor Kitchen Island Sink	10/27/16 6:00 AM	1.27	BA
Crane Medical HS	51564	51564-3-KIT-KS08-005	3rd Floor Kitchen Island Sink	10/27/16 6:00 AM	1.16	BA
Crane Medical HS	51564	51564-3-HAL-F13-001	3rd Floor Hallway Outside Rm. 313	10/27/16 6:00 AM	0.215	BA
Crane Medical HS	51564	51564-3-HAL-F13-002	3rd Floor Hallway Outside Rm. 313	10/27/16 6:00 AM	0.171	BA
Crane Medical HS	51564	51564-3-HAL-F13-003	3rd Floor Hallway Outside Rm. 313	10/27/16 6:00 AM	0.145	BA
Crane Medical HS	51564	51564-3-HAL-F13-004	3rd Floor Hallway Outside Rm. 313	10/27/16 6:00 AM	0.135	BA
Crane Medical HS	51564	51564-3-HAL-F13-005	3rd Floor Hallway Outside Rm. 313	10/27/16 6:00 AM	0.13	BA
Crane Medical HS	51564	51564-3-HAL-F16-001	3rd Floor Hallway Across Rm. 306	10/27/16 6:00 AM	<0.120	ND
Crane Medical HS	51564	51564-3-HAL-F16-002	3rd Floor Hallway Across Rm. 306	10/27/16 6:00 AM	<0.120	ND
Crane Medical HS	51564	51564-3-HAL-F16-003	3rd Floor Hallway Across Rm. 306	10/27/16 6:00 AM	<0.120	ND
Crane Medical HS	51564	51564-3-HAL-F16-004	3rd Floor Hallway Across Rm. 306	10/27/16 6:00 AM	<0.120	ND
Crane Medical HS	51564	51564-3-HAL-F16-005	3rd Floor Hallway Across Rm. 306	10/27/16 6:00 AM	<0.120	ND
Crane Medical HS	51564	51564-4-HAL-F04-001	4th Floor Hallway Across Rm. 408	10/27/16 6:00 AM	<0.120	ND
Crane Medical HS	51564	51564-4-HAL-F04-002	4th Floor Hallway Across Rm. 408	10/27/16 6:00 AM	<0.120	ND
Crane Medical HS	51564	51564-4-HAL-F04-003	4th Floor Hallway Across Rm. 408	10/27/16 6:00 AM	0.13	BA
Crane Medical HS	51564	51564-4-HAL-F04-004	4th Floor Hallway Across Rm. 408	10/27/16 6:00 AM	0.14	BA
Crane Medical HS	51564	51564-4-HAL-F04-005	4th Floor Hallway Across Rm. 408	10/27/16 6:00 AM	0.131	BA
Crane Medical HS	51564	51564-4-HAL-F02-001	4th Floor Hallway Across Rm. 437 N. Wall	10/27/16 6:00 AM	7.94	BA
Crane Medical HS	51564	51564-4-HAL-F02-002	4th Floor Hallway Across Rm. 437 N. Wall	10/27/16 6:00 AM	9.14	BA
Crane Medical HS	51564	51564-4-HAL-F02-003	4th Floor Hallway Across Rm. 437 N. Wall	10/27/16 6:00 AM	11.4	BA
Crane Medical HS	51564	51564-4-HAL-F02-004	4th Floor Hallway Across Rm. 437 N. Wall	10/27/16 6:00 AM	13.2	BA
Crane Medical HS	51564	51564-4-HAL-F02-005	4th Floor Hallway Across Rm. 437 N. Wall	10/27/16 6:00 AM	13.5	BA

#### SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit

BA-Below EPA Action Level of 15 ppb

AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations