



School Lead Water Testing - Data Collection Form

School Name **Fernwood**

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
23201-1-N01-F-001	Outside Room 106, Fountain	5/24/16 5:00 AM	0.487	BA
23201-1-N01-F-002	Outside Room 106, Fountain	5/24/16 5:00 AM	0.49	BA
23201-1-N01-F-003	Outside Room 106, Fountain	5/24/16 5:00 AM	0.488	BA
23201-1-N01-F-004	Outside Room 106, Fountain	5/24/16 5:00 AM	0.479	BA
23201-1-N01-F-005	Outside Room 106, Fountain	5/24/16 5:00 AM	0.328	BA
23201-2-E01-F-001	Outside Room 201, Fountain	5/24/16 5:00 AM	24	AA
23201-2-E01-F-002	Outside Room 201, Fountain	5/24/16 5:00 AM	7.31	BA
23201-2-E01-F-003	Outside Room 201, Fountain	5/24/16 5:00 AM	2.13	BA
23201-2-E01-F-004	Outside Room 201, Fountain	5/24/16 5:00 AM	4.64	BA
23201-2-E01-F-005	Outside Room 201, Fountain	5/24/16 5:00 AM	2.69	BA
23201-2-N01-F-001	Outside Room 206, Fountain	5/24/16 5:00 AM	0.203	BA
23201-2-N01-F-002	Outside Room 206, Fountain	5/24/16 5:00 AM	0.331	BA
23201-2-N01-F-003	Outside Room 206, Fountain	5/24/16 5:00 AM	0.417	BA
23201-2-N01-F-004	Outside Room 206, Fountain	5/24/16 5:00 AM	0.529	BA
23201-2-N01-F-005	Outside Room 206, Fountain	5/24/16 5:00 AM	0.242	BA
23201-3-E01-F-001	Outside Room 303, Fountain	5/24/16 5:00 AM	6.79	BA
23201-3-E01-F-002	Outside Room 303, Fountain	5/24/16 5:00 AM	8.34	BA
23201-3-E01-F-003	Outside Room 303, Fountain	5/24/16 5:00 AM	7.05	BA
23201-3-E01-F-004	Outside Room 303, Fountain	5/24/16 5:00 AM	7.42	BA
23201-3-E01-F-005	Outside Room 303, Fountain	5/24/16 5:00 AM	7.36	BA
23201-3-N01-F-001	Outside Room 306, Fountain	5/24/16 5:00 AM	0.295	BA
23201-3-N01-F-002	Outside Room 306, Fountain	5/24/16 5:00 AM	0.665	BA
23201-3-N01-F-003	Outside Room 306, Fountain	5/24/16 5:00 AM	0.701	BA
23201-3-N01-F-004	Outside Room 306, Fountain	5/24/16 5:00 AM	0.672	BA
23201-3-N01-F-005	Outside Room 306, Fountain	5/24/16 5:00 AM	0.675	BA
23201-B-E01-F-001	Outside Room G2 Basement, Fountain	5/24/16 5:00 AM	1.83	BA
23201-B-E01-F-002	Outside Room G2 Basement, Fountain	5/24/16 5:00 AM	2.04	BA
23201-B-E01-F-003	Outside Room G2 Basement, Fountain	5/24/16 5:00 AM	34.7	AA
23201-B-E01-F-004	Outside Room G2 Basement, Fountain	5/24/16 5:00 AM	1.96	BA
23201-B-E01-F-005	Outside Room G2 Basement, Fountain	5/24/16 5:00 AM	1.81	BA
23201-B-K-S-001	Kitchen Sink	5/24/16 5:00 AM	0.673	BA
23201-B-K-S-002	Kitchen Sink	5/24/16 5:00 AM	0.628	BA
23201-B-K-S-003	Kitchen Sink	5/24/16 5:00 AM	0.621	BA
23201-B-K-S-004	Kitchen Sink	5/24/16 5:00 AM	1.00	BA
23201-B-K-S-005	Kitchen Sink	5/24/16 5:00 AM	1.10	BA
609917-1-C-F03-001	Across from Main Office West, Fountain 2	6/21/16 6:15 AM	3.59	BA
609917-1-C-F03-002	Across from Main Office West, Fountain 2	6/21/16 6:15 AM	2.23	BA
609917-1-C-F03-003	Across from Main Office West, Fountain 2	6/21/16 6:15 AM	2.35	BA
609917-1-C-F03-004	Across from Main Office West, Fountain 2	6/21/16 6:15 AM	1.96	BA
609917-1-C-F03-005	Across from Main Office West, Fountain 2	6/21/16 6:15 AM	1.69	BA
609917-1-C-F04-001	Across from Main Office East, Fountain 1	6/21/16 6:20 AM	5.51	BA
609917-1-C-F04-002	Across from Main Office East, Fountain 1	6/21/16 6:20 AM	4.06	BA
609917-1-C-F04-003	Across from Main Office East, Fountain 1	6/21/16 6:20 AM	3.37	BA
609917-1-C-F04-004	Across from Main Office East, Fountain 1	6/21/16 6:20 AM	3.44	BA
609917-1-C-F04-005	Across from Main Office East, Fountain 1	6/21/16 6:20 AM	2.31	BA
609917-1-NW-F01-001	Across from Room 107 North, Fountain 1	6/21/16 6:05 AM	0.676	BA
609917-1-NW-F01-002	Across from Room 107 North, Fountain 1	6/21/16 6:05 AM	0.721	BA
609917-1-NW-F01-003	Across from Room 107 North, Fountain 1	6/21/16 6:05 AM	0.492	BA
609917-1-NW-F01-004	Across from Room 107 North, Fountain 1	6/21/16 6:05 AM	0.402	BA
609917-1-NW-F01-005	Across from Room 107 North, Fountain 1	6/21/16 6:05 AM	0.334	BA
609917-1-NW-F02-001	Across from Room 107 South, Fountain 1	6/21/16 6:10 AM	<0.120	ND
609917-1-NW-F02-002	Across from Room 107 South, Fountain 1	6/21/16 6:10 AM	0.232	BA
609917-1-NW-F02-003	Across from Room 107 South, Fountain 1	6/21/16 6:10 AM	0.212	BA
609917-1-NW-F02-004	Across from Room 107 South, Fountain 1	6/21/16 6:10 AM	0.213	BA
609917-1-NW-F02-005	Across from Room 107 South, Fountain 1	6/21/16 6:10 AM	0.202	BA
609917-2-NW-F01-001	Across from Room 207 North, Fountain 1	6/21/16 6:25 AM	0.257	BA
609917-2-NW-F01-002	Across from Room 207 North, Fountain 1	6/21/16 6:25 AM	0.27	BA
609917-2-NW-F01-003	Across from Room 207 North, Fountain 1	6/21/16 6:25 AM	0.266	BA
609917-2-NW-F01-004	Across from Room 207 North, Fountain 1	6/21/16 6:25 AM	0.248	BA
609917-2-NW-F01-005	Across from Room 207 North, Fountain 1	6/21/16 6:25 AM	0.244	BA
609917-2-NW-F02-001	Across from Room 207 Center, Fountain 2	6/21/16 6:30 AM	0.203	BA
609917-2-NW-F02-002	Across from Room 207 Center, Fountain 2	6/21/16 6:30 AM	0.241	BA

609917-2-NW-F02-003	Across from Room 207 Center, Fountain 2	6/21/16 6:30 AM	0.231	BA
609917-2-NW-F02-004	Across from Room 207 Center, Fountain 2	6/21/16 6:30 AM	0.237	BA
609917-2-NW-F02-005	Across from Room 207 Center, Fountain 2	6/21/16 6:30 AM	0.223	BA
609917-2-NW-F03-001	Across from Room 207 South, Fountain 3	6/21/16 6:35 AM	0.198	BA
609917-2-NW-F03-002	Across from Room 207 South, Fountain 3	6/21/16 6:35 AM	0.209	BA
609917-2-NW-F03-003	Across from Room 207 South, Fountain 3	6/21/16 6:35 AM	0.201	BA
609917-2-NW-F03-004	Across from Room 207 South, Fountain 3	6/21/16 6:35 AM	0.194	BA
609917-2-NW-F03-005	Across from Room 207 South, Fountain 3	6/21/16 6:35 AM	0.193	BA
609917-3-C-F03-001	Across from Room 303 West, Fountain 2	6/21/16 6:50 AM	7	BA
609917-3-C-F03-002	Across from Room 303 West, Fountain 2	6/21/16 6:50 AM	7.19	BA
609917-3-C-F03-003	Across from Room 303 West, Fountain 2	6/21/16 6:50 AM	7.07	BA
609917-3-C-F03-004	Across from Room 303 West, Fountain 2	6/21/16 6:50 AM	7.25	BA
609917-3-C-F03-005	Across from Room 303 West, Fountain 2	6/21/16 6:50 AM	7.72	BA
609917-3-C-F04-001	Across from Room 303 East, Fountain 1	6/21/16 6:55 AM	21.1	AA
609917-3-C-F04-002	Across from Room 303 East, Fountain 1	6/21/16 6:55 AM	18.1	AA
609917-3-C-F04-003	Across from Room 303 East, Fountain 1	6/21/16 6:55 AM	22.3	AA
609917-3-C-F04-004	Across from Room 303 East, Fountain 1	6/21/16 6:55 AM	13.9	BA
609917-3-C-F04-005	Across from Room 303 East, Fountain 1	6/21/16 6:55 AM	15.1	AA
609917-3-W-F01-001	Across from Room 307 North, Fountain 1	6/21/16 6:40 AM	0.351	BA
609917-3-W-F01-002	Across from Room 307 North, Fountain 1	6/21/16 6:40 AM	0.424	BA
609917-3-W-F01-003	Across from Room 307 North, Fountain 1	6/21/16 6:40 AM	0.407	BA
609917-3-W-F01-004	Across from Room 307 North, Fountain 1	6/21/16 6:40 AM	0.373	BA
609917-3-W-F01-005	Across from Room 307 North, Fountain 1	6/21/16 6:40 AM	0.329	BA
609917-3-W-F02-001	Across from Room 307 South, Fountain 2	6/21/16 6:45 AM	0.325	BA
609917-3-W-F02-002	Across from Room 307 South, Fountain 2	6/21/16 6:45 AM	0.376	BA
609917-3-W-F02-003	Across from Room 307 South, Fountain 2	6/21/16 6:45 AM	0.39	BA
609917-3-W-F02-004	Across from Room 307 South, Fountain 2	6/21/16 6:45 AM	0.409	BA
609917-3-W-F02-005	Across from Room 307 South, Fountain 2	6/21/16 6:45 AM	0.428	BA
609917-B-W-F01-001	Outside Room 063, Fountain	6/21/16 6:00 AM	2.05	BA
609917-B-W-F01-002	Outside Room 063, Fountain	6/21/16 6:00 AM	1.94	BA
609917-B-W-F01-003	Outside Room 063, Fountain	6/21/16 6:00 AM	1.96	BA
609917-B-W-F01-004	Outside Room 063, Fountain	6/21/16 6:00 AM	1.5	BA
609917-B-W-F01-005	Outside Room 063, Fountain	6/21/16 6:00 AM	1.35	BA

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit

BA-Below EPA Action Level of 15 ppb

AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations