



October 21, 2016

Dear Foreman families,

In light of national events that have brought increased attention to the issue of water quality, the City of Chicago announced several additional precautionary measures that will be added to the City's water testing protocol, continuing the City's track record of complying with current state and federal regulations as well as exceeding industry standards.

As part of this announcement, Chicago Public Schools (CPS) began testing the water for levels of lead from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe. Schools are being tested based on a priority criteria that includes the age of the school, age of the students (with priority given to schools with pre-K programs), presence of a kitchen (where meals are prepared) and presence of pipes that could need repairs or replacement.

The results of all the schools are coming in on a rolling basis, and the majority have had levels under the EPA's action level of 15 parts per billion (ppb). At Foreman samples were tested from 36 sites and the water sampled from one sink on the main floor was above the action level of 15 ppb. The water from the sink has been turned off and remediation plans are being created.

Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why only one of the samples at Foreman returned with elevated results – the issue is not system-wide, but is specific to the fixtures or pipes for that sink and will be addressed through the remediation plan. The full results of every school's water samples can be found online at [cps.edu/leadtesting](http://cps.edu/leadtesting).

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

Forrest Claypool  
CEO, Chicago Public Schools

Dr. Julie Morita  
Commissioner, Chicago Department of Public Health



21 de octubre de 2016

Estimadas familias de la escuela Foreman,

Ante recientes eventos nacionales que han aumentado la atención sobre el tema de la calidad del agua, la ciudad de Chicago anunció varias medidas de precaución adicionales que se sumarán al protocolo de la ciudad sobre control del agua, en cumplimiento de las regulaciones estatales y federales, así como de los estándares industriales

Como parte de este anuncio, las Escuelas Públicas de Chicago (CPS) comenzaron a examinar los niveles de plomo en el agua de las escuelas de todo el distrito. Nuestra prioridad máxima es la salud y seguridad de los estudiantes y del personal, y estas pruebas se iniciaron como precaución para estar seguros de la calidad del agua de las escuelas. Las pruebas se realizan según un criterio de prioridad que incluye la edad del edificio, edad de los estudiantes (con prioridad para las escuelas con programas de preescolares), la presencia de una cocina (donde se preparan alimentos) y de cañerías que puedan necesitar reparación o reemplazo.

Los resultados de todas las escuelas se han ido conociendo, y la mayoría registró niveles por debajo del nivel de acción de EPA que es de 15 partículas por billón (ppb). En Foreman, se tomaron muestras en 36 lugares y el agua de una pileta tenía rastros de plomo por encima del nivel de acción de 15 ppb. El suministro de agua de la pileta fue interrumpido y se están creando medidas para remediar la situación.

El agua de Chicago no tiene plomo cuando sale de la planta de tratamiento. Sin embargo, se puede encontrar en algunas cañerías internas y materiales, y el plomo encontrado en el agua potable es provocado usualmente por la corrosión de las cañerías. Esto explica por qué solamente uno de las muestras de Foreman registró un nivel elevado. Este no es problema general, sino específico de la cañería de la pileta, y será solucionado. Los resultados completos de cada escuela se pueden ver en línea en [cps.edu/leadtesting](http://cps.edu/leadtesting).


Los lineamientos federales indican que los niños menores de seis años son los que corren mayores riesgos con la exposición al plomo, algo que puede ocurrir de varias fuentes, incluyendo pintura, tierra y algunos productos de consumo. Si están preocupados por la posible exposición de su hijo al plomo, el Departamento de Salud Pública de la ciudad de Chicago (CDPH) recomienda visitar a su pediatra o a alguno de los centros de salud listados en el material adjunto, para una prueba. Además, la línea directa del CDPH puede responder cualquier pregunta que tengan, o ayudarlos a decidir si su niño debe ser examinado; por preguntas o más información, llame por favor al 312-747-5323. Por información adicional sobre el plomo y los niños, visite [www.cdc.gov/lead](http://www.cdc.gov/lead).

La seguridad de sus hijos es nuestra principal prioridad, y hacemos todo lo que está en nuestro poder para resolver esta situación de una manera rápida y rigurosa. Continuaremos informándoles sobre este proceso.

Atentamente,



Forrest Claypool  
CEO, Escuelas Públicas de Chicago



Dra. Julie Morita, Comisionada  
Departamento de Salud Pública de Chicago



## School Lead Water Testing - Data Collection Form

School Short Name **Foreman H.S.**  
 Date of test **09/30/16**

School Short Name	Facility ID	Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
Foreman H.S.	51532	51532-1-HAL-F01-001	Main-Fountain (Right) Across from 130 Assembly	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-1-HAL-F01-002	Main-Fountain (Right) Across from 130 Assembly	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-1-HAL-F01-003	Main-Fountain (Right) Across from 130 Assembly	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-1-HAL-F01-004	Main-Fountain (Right) Across from 130 Assembly	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-1-HAL-F01-005	Main-Fountain (Right) Across from 130 Assembly	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-1-HAL-F03-001	Main-Fountain (Left) By 120 Main Office	9/30/16 6:00 AM	0.38	BA
Foreman H.S.	51532	51532-1-HAL-F03-002	Main-Fountain (Left) By 120 Main Office	9/30/16 6:00 AM	0.542	BA
Foreman H.S.	51532	51532-1-HAL-F03-003	Main-Fountain (Left) By 120 Main Office	9/30/16 6:00 AM	0.403	BA
Foreman H.S.	51532	51532-1-HAL-F03-004	Main-Fountain (Left) By 120 Main Office	9/30/16 6:00 AM	0.347	BA
Foreman H.S.	51532	51532-1-HAL-F03-005	Main-Fountain (Left) By 120 Main Office	9/30/16 6:00 AM	0.325	BA
Foreman H.S.	51532	51532-1-HAL-F04-001	Main-Fountain (Right) By 120 Main Office	9/30/16 6:00 AM	0.724	BA
Foreman H.S.	51532	51532-1-HAL-F04-002	Main-Fountain (Right) By 120 Main Office	9/30/16 6:00 AM	0.638	BA
Foreman H.S.	51532	51532-1-HAL-F04-003	Main-Fountain (Right) By 120 Main Office	9/30/16 6:00 AM	0.738	BA
Foreman H.S.	51532	51532-1-HAL-F04-004	Main-Fountain (Right) By 120 Main Office	9/30/16 6:00 AM	0.724	BA
Foreman H.S.	51532	51532-1-HAL-F04-005	Main-Fountain (Right) By 120 Main Office	9/30/16 6:00 AM	0.942	BA
Foreman H.S.	51532	51532-1-HAL-F05-001	Main-Fountain (Left) By 118 Library	9/30/16 6:00 AM	0.584	BA
Foreman H.S.	51532	51532-1-HAL-F05-002	Main-Fountain (Left) By 118 Library	9/30/16 6:00 AM	0.976	BA
Foreman H.S.	51532	51532-1-HAL-F05-003	Main-Fountain (Left) By 118 Library	9/30/16 6:00 AM	0.586	BA
Foreman H.S.	51532	51532-1-HAL-F05-004	Main-Fountain (Left) By 118 Library	9/30/16 6:00 AM	0.475	BA
Foreman H.S.	51532	51532-1-HAL-F05-005	Main-Fountain (Left) By 118 Library	9/30/16 6:00 AM	0.448	BA
Foreman H.S.	51532	51532-1-HAL-F06-001	Main-Fountain (Right) By 118 Library	9/30/16 6:00 AM	0.716	BA
Foreman H.S.	51532	51532-1-HAL-F06-002	Main-Fountain (Right) By 118 Library	9/30/16 6:00 AM	0.996	BA
Foreman H.S.	51532	51532-1-HAL-F06-003	Main-Fountain (Right) By 118 Library	9/30/16 6:00 AM	1.11	BA
Foreman H.S.	51532	51532-1-HAL-F06-004	Main-Fountain (Right) By 118 Library	9/30/16 6:00 AM	1.55	BA
Foreman H.S.	51532	51532-1-HAL-F06-005	Main-Fountain (Right) By 118 Library	9/30/16 6:00 AM	3.03	BA
Foreman H.S.	51532	51532-1-HAL-F07-001	Main-Fountain (Left) Across from Room 110	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-1-HAL-F07-002	Main-Fountain (Left) Across from Room 110	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-1-HAL-F07-003	Main-Fountain (Left) Across from Room 110	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-1-HAL-F07-004	Main-Fountain (Left) Across from Room 110	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-1-HAL-F07-005	Main-Fountain (Left) Across from Room 110	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-1-HAL-F08-001	Main-Fountain (Right) Across from Room 110	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-1-HAL-F08-002	Main-Fountain (Right) Across from Room 110	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-1-HAL-F08-003	Main-Fountain (Right) Across from Room 110	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-1-HAL-F08-004	Main-Fountain (Right) Across from Room 110	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-1-HAL-F08-005	Main-Fountain (Right) Across from Room 110	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-1-HAL-F09-001	Main-Fountain (Left) Across from Room 101	9/30/16 6:00 AM	2.1	BA
Foreman H.S.	51532	51532-1-HAL-F09-002	Main-Fountain (Left) Across from Room 101	9/30/16 6:00 AM	1.48	BA
Foreman H.S.	51532	51532-1-HAL-F09-003	Main-Fountain (Left) Across from Room 101	9/30/16 6:00 AM	1.17	BA
Foreman H.S.	51532	51532-1-HAL-F09-004	Main-Fountain (Left) Across from Room 101	9/30/16 6:00 AM	0.741	BA
Foreman H.S.	51532	51532-1-HAL-F09-005	Main-Fountain (Left) Across from Room 101	9/30/16 6:00 AM	0.647	BA

Foreman H.S.	51532	51532-1-HAL-F10-001	Main-Fountain (Right) Across from Room 101	9/30/16 6:00 AM	0.793	BA
Foreman H.S.	51532	51532-1-HAL-F10-002	Main-Fountain (Right) Across from Room 101	9/30/16 6:00 AM	0.374	BA
Foreman H.S.	51532	51532-1-HAL-F10-003	Main-Fountain (Right) Across from Room 101	9/30/16 6:00 AM	0.389	BA
Foreman H.S.	51532	51532-1-HAL-F10-004	Main-Fountain (Right) Across from Room 101	9/30/16 6:00 AM	0.37	BA
Foreman H.S.	51532	51532-1-HAL-F10-005	Main-Fountain (Right) Across from Room 101	9/30/16 6:00 AM	0.375	BA
Foreman H.S.	51532	51532-1-112B-S11-001	Main-Sink Inside Social Room Kitchen 112B	9/30/16 6:00 AM	16.2	AA
Foreman H.S.	51532	51532-1-112B-S11-002	Main-Sink Inside Social Room Kitchen 112B	9/30/16 6:00 AM	3.82	BA
Foreman H.S.	51532	51532-1-112B-S11-003	Main-Sink Inside Social Room Kitchen 112B	9/30/16 6:00 AM	4.32	BA
Foreman H.S.	51532	51532-1-112B-S11-004	Main-Sink Inside Social Room Kitchen 112B	9/30/16 6:00 AM	3.43	BA
Foreman H.S.	51532	51532-1-112B-S11-005	Main-Sink Inside Social Room Kitchen 112B	9/30/16 6:00 AM	2.3	BA
Foreman H.S.	51532	51532-2-HAL-F01-001	Main-Fountain (Left) By Room 227	9/30/16 6:00 AM	0.319	BA
Foreman H.S.	51532	51532-2-HAL-F01-002	Main-Fountain (Left) By Room 227	9/30/16 6:00 AM	0.173	BA
Foreman H.S.	51532	51532-2-HAL-F01-003	Main-Fountain (Left) By Room 227	9/30/16 6:00 AM	0.164	BA
Foreman H.S.	51532	51532-2-HAL-F01-004	Main-Fountain (Left) By Room 227	9/30/16 6:00 AM	0.157	BA
Foreman H.S.	51532	51532-2-HAL-F01-005	Main-Fountain (Left) By Room 227	9/30/16 6:00 AM	0.165	BA
Foreman H.S.	51532	51532-2-HAL-F03-001	Main-Fountain (Left) By Room 222	9/30/16 6:00 AM	0.194	BA
Foreman H.S.	51532	51532-2-HAL-F03-002	Main-Fountain (Left) By Room 222	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-2-HAL-F03-003	Main-Fountain (Left) By Room 222	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-2-HAL-F03-004	Main-Fountain (Left) By Room 222	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-2-HAL-F03-005	Main-Fountain (Left) By Room 222	9/30/16 6:00 AM	0.373	BA
Foreman H.S.	51532	51532-2-HAL-F04-001	Main-Fountain (Right) By Room 222	9/30/16 6:00 AM	0.33	BA
Foreman H.S.	51532	51532-2-HAL-F04-002	Main-Fountain (Right) By Room 222	9/30/16 6:00 AM	0.266	BA
Foreman H.S.	51532	51532-2-HAL-F04-003	Main-Fountain (Right) By Room 222	9/30/16 6:00 AM	0.441	BA
Foreman H.S.	51532	51532-2-HAL-F04-004	Main-Fountain (Right) By Room 222	9/30/16 6:00 AM	0.168	BA
Foreman H.S.	51532	51532-2-HAL-F04-005	Main-Fountain (Right) By Room 222	9/30/16 6:00 AM	0.387	BA
Foreman H.S.	51532	51532-2-HAL-F05-001	Main-Fountain (Left) By Room 216	9/30/16 6:00 AM	0.345	BA
Foreman H.S.	51532	51532-2-HAL-F05-002	Main-Fountain (Left) By Room 216	9/30/16 6:00 AM	0.228	BA
Foreman H.S.	51532	51532-2-HAL-F05-003	Main-Fountain (Left) By Room 216	9/30/16 6:00 AM	0.16	BA
Foreman H.S.	51532	51532-2-HAL-F05-004	Main-Fountain (Left) By Room 216	9/30/16 6:00 AM	0.325	BA
Foreman H.S.	51532	51532-2-HAL-F05-005	Main-Fountain (Left) By Room 216	9/30/16 6:00 AM	0.14	BA
Foreman H.S.	51532	51532-2-HAL-F06-001	Main-Fountain (Right) By Room 216	9/30/16 6:00 AM	0.19	BA
Foreman H.S.	51532	51532-2-HAL-F06-002	Main-Fountain (Right) By Room 216	9/30/16 6:00 AM	0.701	BA
Foreman H.S.	51532	51532-2-HAL-F06-003	Main-Fountain (Right) By Room 216	9/30/16 6:00 AM	0.592	BA
Foreman H.S.	51532	51532-2-HAL-F06-004	Main-Fountain (Right) By Room 216	9/30/16 6:00 AM	0.681	BA
Foreman H.S.	51532	51532-2-HAL-F06-005	Main-Fountain (Right) By Room 216	9/30/16 6:00 AM	0.657	BA
Foreman H.S.	51532	51532-2-HAL-F07-001	Main-Fountain (Left) By Room 209	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-2-HAL-F07-002	Main-Fountain (Left) By Room 209	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-2-HAL-F07-003	Main-Fountain (Left) By Room 209	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-2-HAL-F07-004	Main-Fountain (Left) By Room 209	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-2-HAL-F07-005	Main-Fountain (Left) By Room 209	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-2-HAL-F08-001	Main-Fountain (Right) By Room 209	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-2-HAL-F08-002	Main-Fountain (Right) By Room 209	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-2-HAL-F08-003	Main-Fountain (Right) By Room 209	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-2-HAL-F08-004	Main-Fountain (Right) By Room 209	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-2-HAL-F08-005	Main-Fountain (Right) By Room 209	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-2-HAL-F09-001	Main-Fountain By Room 202	9/30/16 6:00 AM	1.6	BA
Foreman H.S.	51532	51532-2-HAL-F09-002	Main-Fountain By Room 202	9/30/16 6:00 AM	0.74	BA
Foreman H.S.	51532	51532-2-HAL-F09-003	Main-Fountain By Room 202	9/30/16 6:00 AM	0.692	BA
Foreman H.S.	51532	51532-2-HAL-F09-004	Main-Fountain By Room 202	9/30/16 6:00 AM	0.635	BA
Foreman H.S.	51532	51532-2-HAL-F09-005	Main-Fountain By Room 202	9/30/16 6:00 AM	1.53	BA
Foreman H.S.	51532	51532-3-KIT-KS01-001	Main-Kitchen Sink (Right A) W. Wall	9/30/16 6:00 AM	0.329	BA
Foreman H.S.	51532	51532-3-KIT-KS01-002	Main-Kitchen Sink (Right A) W. Wall	9/30/16 6:00 AM	0.165	BA

Foreman H.S.	51532	51532-3-KIT-KS01-003	Main-Kitchen Sink (Right A) W. Wall	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-3-KIT-KS01-004	Main-Kitchen Sink (Right A) W. Wall	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-3-KIT-KS01-005	Main-Kitchen Sink (Right A) W. Wall	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-3-KIT-KS02-001	Main-Kitchen Sink (Right B, 2nd from the right) W. Wall	9/30/16 6:00 AM	0.138	BA
Foreman H.S.	51532	51532-3-KIT-KS02-002	Main-Kitchen Sink (Right B, 2nd from the right) W. Wall	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-3-KIT-KS02-003	Main-Kitchen Sink (Right B, 2nd from the right) W. Wall	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-3-KIT-KS02-004	Main-Kitchen Sink (Right B, 2nd from the right) W. Wall	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-3-KIT-KS02-005	Main-Kitchen Sink (Right B, 2nd from the right) W. Wall	9/30/16 6:00 AM	0.135	BA
Foreman H.S.	51532	51532-3-KIT-KS03-001	Main-Kitchen Sink (Center) W. Wall	9/30/16 6:00 AM	0.128	BA
Foreman H.S.	51532	51532-3-KIT-KS03-002	Main-Kitchen Sink (Center) W. Wall	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-3-KIT-KS03-003	Main-Kitchen Sink (Center) W. Wall	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-3-KIT-KS03-004	Main-Kitchen Sink (Center) W. Wall	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-3-KIT-KS03-005	Main-Kitchen Sink (Center) W. Wall	9/30/16 6:00 AM	0.136	BA
Foreman H.S.	51532	51532-3-KIT-KS04-001	Main-Kitchen Sink (Left A) W. Wall	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-3-KIT-KS04-002	Main-Kitchen Sink (Left A) W. Wall	9/30/16 6:00 AM	0.22	BA
Foreman H.S.	51532	51532-3-KIT-KS04-003	Main-Kitchen Sink (Left A) W. Wall	9/30/16 6:00 AM	0.128	BA
Foreman H.S.	51532	51532-3-KIT-KS04-004	Main-Kitchen Sink (Left A) W. Wall	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-3-KIT-KS04-005	Main-Kitchen Sink (Left A) W. Wall	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-3-KIT-KS05-001	Main-Kitchen Sink (Left B, 2nd from the left) W. Wall	9/30/16 6:00 AM	0.288	BA
Foreman H.S.	51532	51532-3-KIT-KS05-002	Main-Kitchen Sink (Left B, 2nd from the left) W. Wall	9/30/16 6:00 AM	0.199	BA
Foreman H.S.	51532	51532-3-KIT-KS05-003	Main-Kitchen Sink (Left B, 2nd from the left) W. Wall	9/30/16 6:00 AM	0.189	BA
Foreman H.S.	51532	51532-3-KIT-KS05-004	Main-Kitchen Sink (Left B, 2nd from the left) W. Wall	9/30/16 6:00 AM	0.162	BA
Foreman H.S.	51532	51532-3-KIT-KS05-005	Main-Kitchen Sink (Left B, 2nd from the left) W. Wall	9/30/16 6:00 AM	0.865	BA
Foreman H.S.	51532	51532-3-KIT-KS06-001	Main-Kitchen Island Sink	9/30/16 6:00 AM	0.854	BA
Foreman H.S.	51532	51532-3-KIT-KS06-002	Main-Kitchen Island Sink	9/30/16 6:00 AM	0.843	BA
Foreman H.S.	51532	51532-3-KIT-KS06-003	Main-Kitchen Island Sink	9/30/16 6:00 AM	0.554	BA
Foreman H.S.	51532	51532-3-KIT-KS06-004	Main-Kitchen Island Sink	9/30/16 6:00 AM	0.574	BA
Foreman H.S.	51532	51532-3-KIT-KS06-005	Main-Kitchen Island Sink	9/30/16 6:00 AM	0.535	BA
Foreman H.S.	51532	51532-3-HAL-F07-001	Main-Fountain (Right) N. Corridor S. Wall	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-3-HAL-F07-002	Main-Fountain (Right) N. Corridor S. Wall	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-3-HAL-F07-003	Main-Fountain (Right) N. Corridor S. Wall	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-3-HAL-F07-004	Main-Fountain (Right) N. Corridor S. Wall	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-3-HAL-F07-005	Main-Fountain (Right) N. Corridor S. Wall	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-3-HAL-F08-001	Main-Fountain (Left) N. Corridor S. Wall	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-3-HAL-F08-002	Main-Fountain (Left) N. Corridor S. Wall	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-3-HAL-F08-003	Main-Fountain (Left) N. Corridor S. Wall	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-3-HAL-F08-004	Main-Fountain (Left) N. Corridor S. Wall	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-3-HAL-F08-005	Main-Fountain (Left) N. Corridor S. Wall	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-3-HAL-F09-001	Main-Fountain (Right) W. Corridor S. Wall Across from Room 323	9/30/16 6:00 AM	0.805	BA
Foreman H.S.	51532	51532-3-HAL-F09-002	Main-Fountain (Right) W. Corridor S. Wall Across from Room 323	9/30/16 6:00 AM	0.824	BA
Foreman H.S.	51532	51532-3-HAL-F09-003	Main-Fountain (Right) W. Corridor S. Wall Across from Room 323	9/30/16 6:00 AM	0.757	BA
Foreman H.S.	51532	51532-3-HAL-F09-004	Main-Fountain (Right) W. Corridor S. Wall Across from Room 323	9/30/16 6:00 AM	0.844	BA
Foreman H.S.	51532	51532-3-HAL-F09-005	Main-Fountain (Right) W. Corridor S. Wall Across from Room 323	9/30/16 6:00 AM	0.95	BA
Foreman H.S.	51532	51532-3-HAL-F10-001	Main-Fountain (Left) W. Corridor S. Wall Across from Room 323	9/30/16 6:00 AM	0.527	BA
Foreman H.S.	51532	51532-3-HAL-F10-002	Main-Fountain (Left) W. Corridor S. Wall Across from Room 323	9/30/16 6:00 AM	0.612	BA
Foreman H.S.	51532	51532-3-HAL-F10-003	Main-Fountain (Left) W. Corridor S. Wall Across from Room 323	9/30/16 6:00 AM	0.44	BA
Foreman H.S.	51532	51532-3-HAL-F10-004	Main-Fountain (Left) W. Corridor S. Wall Across from Room 323	9/30/16 6:00 AM	0.331	BA
Foreman H.S.	51532	51532-3-HAL-F10-005	Main-Fountain (Left) W. Corridor S. Wall Across from Room 323	9/30/16 6:00 AM	0.312	BA
Foreman H.S.	51532	51532-3-HAL-F11-01	Main-Fountain (Right) W. Corridor Across from Room 317	9/30/16 6:00 AM	1.88	BA
Foreman H.S.	51532	51532-3-HAL-F11-02	Main-Fountain (Right) W. Corridor Across from Room 317	9/30/16 6:00 AM	2.04	BA
Foreman H.S.	51532	51532-3-HAL-F11-03	Main-Fountain (Right) W. Corridor Across from Room 317	9/30/16 6:00 AM	0.8	BA
Foreman H.S.	51532	51532-3-HAL-F11-04	Main-Fountain (Right) W. Corridor Across from Room 317	9/30/16 6:00 AM	0.569	BA

Foreman H.S.	51532	51532-3-HAL-F11-05	Main-Fountain (Right) W. Corridor Across from Room 317	9/30/16 6:00 AM	0.496	BA
Foreman H.S.	51532	51532-3-HAL-F12-01	Main-Fountain (Left) W. Corridor Across from Room 317	9/30/16 6:00 AM	1.16	BA
Foreman H.S.	51532	51532-3-HAL-F12-02	Main-Fountain (Left) W. Corridor Across from Room 317	9/30/16 6:00 AM	0.754	BA
Foreman H.S.	51532	51532-3-HAL-F12-03	Main-Fountain (Left) W. Corridor Across from Room 317	9/30/16 6:00 AM	0.662	BA
Foreman H.S.	51532	51532-3-HAL-F12-04	Main-Fountain (Left) W. Corridor Across from Room 317	9/30/16 6:00 AM	0.474	BA
Foreman H.S.	51532	51532-3-HAL-F12-05	Main-Fountain (Left) W. Corridor Across from Room 317	9/30/16 6:00 AM	0.414	BA
Foreman H.S.	51532	51532-3-HAL-F13-01	Main-Fountain (Right) S. Corridor N. Wall Next to Room 307	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-3-HAL-F13-02	Main-Fountain (Right) S. Corridor N. Wall Next to Room 307	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-3-HAL-F13-03	Main-Fountain (Right) S. Corridor N. Wall Next to Room 307	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-3-HAL-F13-04	Main-Fountain (Right) S. Corridor N. Wall Next to Room 307	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-3-HAL-F13-05	Main-Fountain (Right) S. Corridor N. Wall Next to Room 307	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-3-HAL-F14-01	Main-Fountain (Left) S. Corridor N. Wall Next to Room 307	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-3-HAL-F14-02	Main-Fountain (Left) S. Corridor N. Wall Next to Room 307	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-3-HAL-F14-03	Main-Fountain (Left) S. Corridor N. Wall Next to Room 307	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-3-HAL-F14-04	Main-Fountain (Left) S. Corridor N. Wall Next to Room 307	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-3-HAL-F14-05	Main-Fountain (Left) S. Corridor N. Wall Next to Room 307	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	51532	51532-3-HAL-F15-01	Main-Fountain (Right) S. Corridor S. Wall Across from Room 301	9/30/16 6:00 AM	1.35	BA
Foreman H.S.	51532	51532-3-HAL-F15-02	Main-Fountain (Right) S. Corridor S. Wall Across from Room 301	9/30/16 6:00 AM	1.27	BA
Foreman H.S.	51532	51532-3-HAL-F15-03	Main-Fountain (Right) S. Corridor S. Wall Across from Room 301	9/30/16 6:00 AM	1.17	BA
Foreman H.S.	51532	51532-3-HAL-F15-04	Main-Fountain (Right) S. Corridor S. Wall Across from Room 301	9/30/16 6:00 AM	1.27	BA
Foreman H.S.	51532	51532-3-HAL-F15-05	Main-Fountain (Right) S. Corridor S. Wall Across from Room 301	9/30/16 6:00 AM	1.35	BA
Foreman H.S.	51532	51532-3-HAL-F16-01	Main-Fountain (Left) S. Corridor S. Wall Across from Room 301	9/30/16 6:00 AM	1.49	BA
Foreman H.S.	51532	51532-3-HAL-F16-02	Main-Fountain (Left) S. Corridor S. Wall Across from Room 301	9/30/16 6:00 AM	1.58	BA
Foreman H.S.	51532	51532-3-HAL-F16-03	Main-Fountain (Left) S. Corridor S. Wall Across from Room 301	9/30/16 6:00 AM	1.61	BA
Foreman H.S.	51532	51532-3-HAL-F16-04	Main-Fountain (Left) S. Corridor S. Wall Across from Room 301	9/30/16 6:00 AM	1.55	BA
Foreman H.S.	51532	51532-3-HAL-F16-05	Main-Fountain (Left) S. Corridor S. Wall Across from Room 301	9/30/16 6:00 AM	1.56	BA
Foreman H.S.	53806	53806-1-HAL-F02-001	Modular-Fountain (Right) E. Wall Next to Room 151	9/30/16 6:00 AM	0.122	BA
Foreman H.S.	53806	53806-1-HAL-F02-002	Modular-Fountain (Right) E. Wall Next to Room 151	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	53806	53806-1-HAL-F02-003	Modular-Fountain (Right) E. Wall Next to Room 151	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	53806	53806-1-HAL-F02-004	Modular-Fountain (Right) E. Wall Next to Room 151	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	53806	53806-1-HAL-F02-005	Modular-Fountain (Right) E. Wall Next to Room 151	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	53806	53806-1-HAL-F03-001	Modular-Fountain (Left) E. Wall Next to Room 155	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	53806	53806-1-HAL-F03-002	Modular-Fountain (Left) E. Wall Next to Room 155	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	53806	53806-1-HAL-F03-003	Modular-Fountain (Left) E. Wall Next to Room 155	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	53806	53806-1-HAL-F03-004	Modular-Fountain (Left) E. Wall Next to Room 155	9/30/16 6:00 AM	<.120	ND
Foreman H.S.	53806	53806-1-HAL-F03-005	Modular-Fountain (Left) E. Wall Next to Room 155	9/30/16 6:00 AM	<.120	ND

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

**SPREADSHEET LEGEND**

ND-Not Detected at the Reporting Limit

BA-Below EPA Action Level of 15 ppb

AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations