



School Lead Water Testing Summary

School Short Name Jamieson
Address 5650 N. Mozart
Facility ID 51063
CPS Team Member Prins Sales
MEC Team Member Evan Christian

Length of time water remained in pipes before sampled Approx. 8-10 hours
Water last used (Time and date) Evening of 4/25/16
Date of test 4/26/2016
Report based on lab results dated 5/2/2016, 5/18/2016

Sample ID #	Sample Location	Sample Collection Time & Date	Test Results (ppb)	ppb Level
51063-3-W-WC-01	Hallway by Room 306	6:25 AM 4/26/16	ND	-
51063-3-E-WC-02	Hallway by Room 300	6:27 AM 4/26/16	ND	-
51063-2-E-WC-03	Hallway by Room 202	6:31 AM 4/26/16	ND	-
51063-2-W-F-04	Hallway by Room 208	6:33 AM 4/26/16	ND	-
51063-2-N-F-05	Hallway by Room 210	6:35 AM 4/26/16	ND	-
51063-2-N-CS-06	Hallway by 2nd Floor Kitchen	6:37 AM 4/26/16	ND	-
51063-1-N-F-07	Hallway by Room 110	6:41 AM 4/26/16	ND	-
51063-1-W-WC-08	Hallway by Room 117	6:43 AM 4/26/16	ND	-
51063-1-E-WC-09	Hallway by Room 102	6:45 AM 4/26/16	ND	-

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit
BA-Below EPA Action Level of 15 ppb
AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations