



School Lead Water Testing - Data Collection Form

School Short Name **Vick**

Length of time water remained in pipes before sampled (hours) **8-9 hrs**

Facility ID **51429**

Date of test **05/25/16**
Water last used (Time and date) **5/24/16 10pm**

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
51429-1-N-CS01-01	Room 106	5/25/16 6:27 AM	<0.120	BA
51429-1-N-CS01-02	Room 106	5/25/16 6:27 AM	0.618	BA
51429-1-N-CS01-03	Room 106	5/25/16 6:28 AM	<0.120	BA
51429-1-N-CS01-04	Room 106	5/25/16 6:28 AM	<0.120	BA
51429-1-N-CS01-05	Room 106	5/25/16 6:28 AM	0.192	BA
51429-1-N-CS01-06	Room 105	5/25/16 6:30 AM	0.280	BA
51429-1-N-CS01-07	Room 105	5/25/16 6:30 AM	<0.120	BA
51429-1-N-CS01-08	Room 105	5/25/16 6:31 AM	<0.120	BA
51429-1-N-CS01-09	Room 105	5/25/16 6:31 AM	<0.120	BA
51429-1-N-CS01-10	Room 105	5/25/16 6:31 AM	<0.120	BA
51429-1-C-CS01-11	Room 104	5/25/16 6:33 AM	1.20	BA
51429-1-C-CS01-12	Room 104	5/25/16 6:33 AM	1.33	BA
51429-1-C-CS01-13	Room 104	5/25/16 6:34 AM	0.297	BA
51429-1-C-CS01-14	Room 104	5/25/16 6:34 AM	0.223	BA
51429-1-C-CS01-15	Room 104	5/25/16 6:34 AM	0.180	BA
51429-1-S-CS01-16	Room 103	5/25/16 6:36 AM	0.154	BA
51429-1-S-CS01-17	Room 103	5/25/16 6:36 AM	0.188	BA
51429-1-S-CS01-18	Room 103	5/25/16 6:37 AM	0.131	BA
51429-1-S-CS01-19	Room 103	5/25/16 6:37 AM	<0.120	BA
51429-1-S-CS01-20	Room 103	5/25/16 6:37 AM	<0.120	BA
51429-1-S-CS01-21	Room 102	5/25/16 6:39 AM	0.380	BA
51429-1-S-CS01-22	Room 102	5/25/16 6:39 AM	0.882	BA
51429-1-S-CS01-23	Room 102	5/25/16 6:40 AM	0.132	BA
51429-1-S-CS01-24	Room 102	5/25/16 6:40 AM	<0.120	BA
51429-1-S-CS01-25	Room 102	5/25/16 6:40 AM	0.181	BA
51429-1-S-CS01-26	Room 101	5/25/16 6:42 AM	1.34	BA
51429-1-S-CS01-27	Room 101	5/25/16 6:42 AM	3.35	BA
51429-1-S-CS01-28	Room 101	5/25/16 6:43 AM	3.18	BA
51429-1-S-CS01-29	Room 101	5/25/16 6:43 AM	3.66	BA
51429-1-S-CS01-30	Room 101	5/25/16 6:43 AM	3.11	BA
51429-1-C-WC01-31	Hallway by RR	5/25/16 6:53 AM	0.898	BA
51429-1-C-WC01-32	Hallway by RR	5/25/16 6:53 AM	1.27	BA

51429-1-C-WC01-33	Hallway by RR	5/25/16 6:54 AM	1.05	BA
51429-1-C-WC01-34	Hallway by RR	5/25/16 6:54 AM	0.934	BA
51429-1-C-WC01-35	Hallway by RR	5/25/16 6:54 AM	0.723	BA
52310-1-W-F01-36	Hallway by Main Office	5/25/16 7:40 AM	3.93	BA
52310-1-W-F01-37	Hallway by Main Office	5/25/16 7:40 AM	2.98	BA
52310-1-W-F01-38	Hallway by Main Office	5/25/16 7:41 AM	4.91	BA
52310-1-W-F01-39	Hallway by Main Office	5/25/16 7:41 AM	3.01	BA
52310-1-W-F01-40	Hallway by Main Office	5/25/16 7:41 AM	3.05	BA
52310-2-N-F01-41	Hallway by Teachers Lounge	5/25/16 7:43 AM	1.69	BA
52310-2-N-F01-42	Hallway by Teachers Lounge	5/25/16 7:43 AM	1.58	BA
52310-2-N-F01-43	Hallway by Teachers Lounge	5/25/16 7:44 AM	1.36	BA
52310-2-N-F01-44	Hallway by Teachers Lounge	5/25/16 7:44 AM	1.21	BA
52310-2-N-F01-45	Hallway by Teachers Lounge	5/25/16 7:44 AM	1.22	BA

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit

BA-Below EPA Action Level of 15 ppb

AA-Above EPA Action Level