



July 18, 2016

Dear CPS family,

In light of national events that have brought increased attention to the issue of water quality, the City of Chicago announced several additional precautionary measures that will be added to the City's water testing protocol, continuing the City's track record of complying with current state and federal regulations as well as exceeding industry standards.

As part of this announcement, Chicago Public Schools (CPS) began testing the water for levels of lead from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe. Schools are being tested based on a priority criteria that includes the age of the school, age of the students (with priority given to schools with pre-K programs), presence of a kitchen (where meals are prepared) and presence of pipes that could need repairs or replacement.

The results of all the schools are coming in on a rolling basis, and the majority have had levels under the EPA's action level of 15 parts per billion (ppb). We wanted to let you know that no lead was found above the action level in your child's school. The full results of your school's water samples can be found online at cps.edu/leadtesting.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician for testing. Additionally, CDPH's lead hotline can address any health related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

Forrest Claypool
CEO, Chicago Public Schools

Dr. Julie Morita
Commissioner, Chicago Department of Public Health





18 de julio de 2016

Estimadas familias de CPS,

Ante los eventos nacionales que han incrementado la atención en el tema de la calidad del agua, la Alcaldía de Chicago anunció varias medidas adicionales de precaución que serán agregadas al protocolo de prueba del agua de la ciudad, continuando con el cumplimiento de las regulaciones estatales y federales, que exceden los estándares industriales.

Como parte de este anuncio, las Escuelas Públicas de Chicago (CPS) comenzaron a medir los niveles de plomo en el agua de todas las escuelas del distrito. Nuestra principal prioridad es la salud y seguridad de todos nuestros estudiantes y personal, y estas pruebas fueron iniciadas solamente para extremar las precauciones y estar seguros de que el agua es segura. Las escuelas son examinadas con base a un criterio de prioridad que incluye la antigüedad del edificio, edad de los estudiantes (con prioridad para las escuelas con programas preescolares), presencia de una cocina (donde se preparan alimentos) y la presencia de cañerías que necesiten reparación o reemplazo.

Los resultados de todas las escuelas se están conociendo, y la mayoría ha registrado niveles por debajo del nivel de acción de la EPA, que es de 15 partículas por billón (ppb). Queremos hacerles saber que no se encontraron rastros de plomo por encima del nivel de acción en la escuela de su niño. Los resultados completos de las pruebas en su escuela se pueden ver en línea en cps.edu/leadtesting.

Los lineamientos federales indican que los niños menores de seis años son los que corren mayores riesgos con la exposición al plomo, algo que puede ocurrir de varias fuentes, incluyendo pintura, tierra y algunos productos de consumo. Si están preocupados por la posible exposición de su hijo al plomo, el Departamento de Salud Pública de la ciudad de Chicago (CDPH) recomienda visitar a su pediatra o a alguno de los centros de salud listados en el material adjunto, para una prueba. Además, la línea directa del CDPH puede responder cualquier pregunta que tengan, o ayudarlos a decidir si su niño debe ser examinado; por preguntas o más información, llame por favor al 312-747-5323. Por información adicional sobre el plomo y los niños, visite www.cdc.gov/lead.

La seguridad de sus hijos es nuestra principal prioridad, y hacemos todo lo que está en nuestro poder para resolver esta situación de una manera rápida y rigurosa. Continuaremos informándoles sobre este proceso.

Atentamente,

Forrest Claypool
CEO, Escuelas Públicas de Chicago

Dra. Julie Morita, Comisionada
Departamento de Salud Pública de Chicago





School Lead Water Testing - Data Collection Form

School Name

Brighton Park

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
51285-1-N-S01-001	Addition- Kitchen, Sink 1	6/15/16 5:00 AM	1.17	BA
51285-1-N-S01-002	Addition- Kitchen, Sink 1	6/15/16 5:01 AM	1.83	BA
51285-1-N-S01-003	Addition- Kitchen, Sink 1	6/15/16 5:02 AM	0.72	BA
51285-1-N-S01-004	Addition- Kitchen, Sink 1	6/15/16 5:03 AM	0.585	BA
51285-1-N-S01-005	Addition- Kitchen, Sink 1	6/15/16 5:04 AM	0.655	BA
51285-1-N-S02-001	Addition- Kitchen, Island Sink 3	6/15/16 5:05 AM	0.838	BA
51285-1-N-S02-002	Addition- Kitchen, Island Sink 3	6/15/16 5:06 AM	0.484	BA
51285-1-N-S02-003	Addition- Kitchen, Island Sink 3	6/15/16 5:07 AM	0.327	BA
51285-1-N-S02-004	Addition- Kitchen, Island Sink 3	6/15/16 5:08 AM	0.312	BA
51285-1-N-S02-005	Addition- Kitchen, Island Sink 3	6/15/16 5:09 AM	0.329	BA
51285-1-N-S03-001	Addition- Kitchen, Sink 2	6/15/16 5:10 AM	0.237	BA
51285-1-N-S03-002	Addition- Kitchen, Sink 2	6/15/16 5:11 AM	0.136	BA
51285-1-N-S03-003	Addition- Kitchen, Sink 2	6/15/16 5:12 AM	0.141	BA
51285-1-N-S03-004	Addition- Kitchen, Sink 2	6/15/16 5:13 AM	0.168	BA
51285-1-N-S03-005	Addition- Kitchen, Sink 2	6/15/16 5:14 AM	0.189	BA
51285-1-N-S04-001	Addition- Kitchen Near Dishwasher, Sink 4	6/15/16 5:15 AM	0.405	BA
51285-1-N-S04-002	Addition- Kitchen Near Dishwasher, Sink 4	6/15/16 5:16 AM	0.388	BA
51285-1-N-S04-003	Addition- Kitchen Near Dishwasher, Sink 4	6/15/16 5:17 AM	0.312	BA
51285-1-N-S04-004	Addition- Kitchen Near Dishwasher, Sink 4	6/15/16 5:18 AM	0.518	BA
51285-1-N-S04-005	Addition- Kitchen Near Dishwasher, Sink 4	6/15/16 5:19 AM	0.638	BA
51285-1-N-F05-001	Addition- Outside Room 114, North Fountain 1	6/15/16 5:20 AM	0.175	BA
51285-1-N-F05-002	Addition- Outside Room 114, North Fountain 1	6/15/16 5:21 AM	0.127	BA
51285-1-N-F05-003	Addition- Outside Room 114, North Fountain 1	6/15/16 5:22 AM	0.277	BA
51285-1-N-F05-004	Addition- Outside Room 114, North Fountain 1	6/15/16 5:23 AM	0.319	BA
51285-1-N-F05-005	Addition- Outside Room 114, North Fountain 1	6/15/16 5:24 AM	0.315	BA
51285-1-N-F06-001	Addition- Outside Room 114, South Fountain 2	6/15/16 5:25 AM	0.234	BA
51285-1-N-F06-002	Addition- Outside Room 114, South Fountain 2	6/15/16 5:26 AM	0.295	BA
51285-1-N-F06-003	Addition- Outside Room 114, South Fountain 2	6/15/16 5:27 AM	0.292	BA
51285-1-N-F06-004	Addition- Outside Room 114, South Fountain 2	6/15/16 5:28 AM	0.304	BA
51285-1-N-F06-005	Addition- Outside Room 114, South Fountain 2	6/15/16 5:29 AM	0.308	BA
51285-2-N-F01-001	Addition- Outside Gym, North Fountain 1	6/15/16 5:30 AM	0.161	BA
51285-2-N-F01-002	Addition- Outside Gym, North Fountain 1	6/15/16 5:31 AM	0.501	BA
51285-2-N-F01-003	Addition- Outside Gym, North Fountain 1	6/15/16 5:32 AM	0.526	BA
51285-2-N-F01-004	Addition- Outside Gym, North Fountain 1	6/15/16 5:33 AM	0.528	BA
51285-2-N-F01-005	Addition- Outside Gym, North Fountain 1	6/15/16 5:34 AM	0.562	BA
51285-2-N-F02-001	Addition- Outside Gym, South Fountain 2	6/15/16 5:35 AM	0.213	BA
51285-2-N-F02-002	Addition- Outside Gym, South Fountain 2	6/15/16 5:36 AM	0.556	BA
51285-2-N-F02-003	Addition- Outside Gym, South Fountain 2	6/15/16 5:37 AM	0.541	BA
51285-2-N-F02-004	Addition- Outside Gym, South Fountain 2	6/15/16 5:38 AM	0.548	BA
51285-2-N-F02-005	Addition- Outside Gym, South Fountain 2	6/15/16 5:39 AM	0.554	BA
51285-3-N-F01-001	Addition- Outside Restroom, North Fountain 1	6/15/16 5:40 AM	<0.120	ND
51285-3-N-F01-002	Addition- Outside Restroom, North Fountain 1	6/15/16 5:41 AM	<0.120	ND
51285-3-N-F01-003	Addition- Outside Restroom, North Fountain 1	6/15/16 5:42 AM	<0.120	ND
51285-3-N-F01-004	Addition- Outside Restroom, North Fountain 1	6/15/16 5:43 AM	<0.120	ND
51285-3-N-F01-005	Addition- Outside Restroom, North Fountain 1	6/15/16 5:44 AM	0.137	BA
51285-3-N-F02-001	Addition- Outside Restroom, South Fountain 2	6/15/16 5:45 AM	0.154	BA
51285-3-N-F02-002	Addition- Outside Restroom, South Fountain 2	6/15/16 5:46 AM	0.234	BA
51285-3-N-F02-003	Addition- Outside Restroom, South Fountain 2	6/15/16 5:47 AM	0.301	BA
51285-3-N-F02-004	Addition- Outside Restroom, South Fountain 2	6/15/16 5:48 AM	0.391	BA
51285-3-N-F02-005	Addition- Outside Restroom, South Fountain 2	6/15/16 5:49 AM	0.448	BA
51285-1-E-F01-001	Main- Outside Room 130, Fountain	6/15/16 6:00 AM	0.347	BA
51285-1-E-F01-002	Main- Outside Room 130, Fountain	6/15/16 6:01 AM	3.01	BA
51285-1-E-F01-003	Main- Outside Room 130, Fountain	6/15/16 6:02 AM	3	BA
51285-1-E-F01-004	Main- Outside Room 130, Fountain	6/15/16 6:03 AM	2.64	BA
51285-1-E-F01-005	Main- Outside Room 130, Fountain	6/15/16 6:04 AM	2.21	BA
51285-1-E-F02-001	Main- Outside Room 101, Fountain	6/15/16 6:05 AM	1.08	BA
51285-1-E-F02-002	Main- Outside Room 101, Fountain	6/15/16 6:06 AM	0.552	BA
51285-1-E-F02-003	Main- Outside Room 101, Fountain	6/15/16 6:07 AM	0.881	BA
51285-1-E-F02-004	Main- Outside Room 101, Fountain	6/15/16 6:08 AM	0.969	BA
51285-1-E-F02-005	Main- Outside Room 101, Fountain	6/15/16 6:09 AM	0.748	BA
51285-2-E-F01-001	Main- Outside Room 225 Fountain	6/15/16 6:15 AM	7.8	BA
51285-2-E-F01-002	Main- Outside Room 225 Fountain	6/15/16 6:16 AM	8.02	BA
51285-2-E-F01-003	Main- Outside Room 225 Fountain	6/15/16 6:17 AM	7.25	BA
51285-2-E-F01-004	Main- Outside Room 225 Fountain	6/15/16 6:18 AM	6.97	BA
51285-2-E-F01-005	Main- Outside Room 225 Fountain	6/15/16 6:19 AM	6.01	BA
51285-2-E-F02-001	Main- Outside Room 235, Fountain	6/15/16 6:45 AM	2.94	BA
51285-2-E-F02-002	Main- Outside Room 235, Fountain	6/15/16 6:46 AM	2.7	BA
51285-2-E-F02-003	Main- Outside Room 235, Fountain	6/15/16 6:47 AM	2.33	BA
51285-2-E-F02-004	Main- Outside Room 235, Fountain	6/15/16 6:48 AM	1.63	BA
51285-2-E-F02-005	Main- Outside Room 235, Fountain	6/15/16 6:49 AM	1.38	BA
51285-1-S-F01-001	Main- Additional Lunchroom, Fountain	6/15/16 6:10 AM	<0.120	ND
51285-1-S-F01-002	Main- Additional Lunchroom, Fountain	6/15/16 6:11 AM	<0.120	ND
51285-1-S-F01-003	Main- Additional Lunchroom, Fountain	6/15/16 6:12 AM	<0.120	ND
51285-1-S-F01-004	Main- Additional Lunchroom, Fountain	6/15/16 6:13 AM	<0.120	ND
51285-1-S-F01-005	Main- Additional Lunchroom, Fountain	6/15/16 6:14 AM	<0.120	ND

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit

BA-Below EPA Action Level of 15 ppb

AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations