



November 7, 2016

Dear Tilden families,

In light of national events that have brought increased attention to the issue of water quality, the City of Chicago announced several additional precautionary measures that will be added to the City's water testing protocol, continuing the City's track record of complying with current state and federal regulations as well as exceeding industry standards.

As part of this announcement, Chicago Public Schools (CPS) began testing the water for levels of lead from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe. Schools are being tested based on a priority criteria that includes the age of the school, age of the students (with priority given to schools with pre-K programs), presence of a kitchen (where meals are prepared) and presence of pipes that could need repairs or replacement.

The results of all the schools are coming in on a rolling basis, and the majority have had levels under the EPA's action level of 15 parts per billion (ppb). At Tilden samples were tested from 28 sites and the water sampled from a drinking fountain on the second floor next to Room 239B was above the action level of 15 ppb. The water from the fountain has been turned off and remediation plans are being created.

Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why only one of the samples at Tilden returned with elevated results – the issue is not system-wide, but is specific to the fixtures or pipes for that fountain and will be addressed through the remediation plan. The full results of every school's water samples can be found online at cps.edu/leadtesting.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

Forrest Claypool
CEO, Chicago Public Schools

Dr. Julie Morita
Commissioner, Chicago Department of Public Health





7 de noviembre de 2016

Estimadas familias de la escuela Tilden,

Ante recientes eventos nacionales que han aumentado la atención sobre el tema de la calidad del agua, la ciudad de Chicago anunció varias medidas de precaución adicionales que se sumarán al protocolo de la ciudad sobre control del agua, en cumplimiento de las regulaciones estatales y federales, así como de los estándares industriales

Como parte de este anuncio, las Escuelas Públicas de Chicago (CPS) comenzaron a examinar los niveles de plomo en el agua de las escuelas de todo el distrito. Nuestra prioridad máxima es la salud y seguridad de los estudiantes y del personal, y estas pruebas se iniciaron como precaución para estar seguros de la calidad del agua de las escuelas. Las pruebas se realizan según un criterio de prioridad que incluye la edad del edificio, edad de los estudiantes (con prioridad para las escuelas con programas de preescolares), la presencia de una cocina (donde se preparan alimentos) y de cañerías que puedan necesitar reparación o reemplazo.

Los resultados de todas las escuelas se han ido conociendo, y la mayoría registró niveles por debajo del nivel de acción de EPA que es de 15 partículas por billón (ppb). En Tilden se tomaron muestras en 28 lugares y el agua de un bebedero del segundo piso, cerca del salón 239B, tenía rastros de plomo por encima del nivel de acción de 15 ppb. El suministro de agua del dispositivo fue interrumpido y se están creando planes para remediar la situación.

El agua de Chicago no tiene plomo cuando sale de la planta de tratamiento. Sin embargo, se puede encontrar en algunas cañerías internas y materiales, y el plomo encontrado en el agua potable es provocado usualmente por la corrosión de las cañerías. Esto explica por qué solamente una de las muestras de Tilden registró un nivel elevado. Este no es problema general sino específico de la cañería de ese dispositivo, y será solucionado. Los resultados completos de cada escuela se pueden ver en línea en cps.edu/leadtesting.

Los lineamientos federales indican que los niños menores de seis años son los que corren mayores riesgos con la exposición al plomo, algo que puede ocurrir de varias fuentes, incluyendo pintura, tierra y algunos productos de consumo. Si están preocupados por la posible exposición de su hijo al plomo, el Departamento de Salud Pública de la ciudad de Chicago (CDPH) recomienda visitar a su pediatra o a alguno de los centros de salud listados en el material adjunto, para una prueba. Además, la línea directa del CDPH puede responder cualquier pregunta que tengan, o ayudarlos a decidir si su niño debe ser examinado; por preguntas o más información, llame por favor al 312-747-5323. Por información adicional sobre el plomo y los niños, visite www.cdc.gov/lead.

La seguridad de sus hijos es nuestra principal prioridad, y hacemos todo lo que está en nuestro poder para resolver esta situación de una manera rápida y rigurosa. Continuaremos informándoles sobre este proceso.

Atentamente,

Forrest Claypool
CEO, Escuelas Públicas de Chicago

Dra. Julie Morita, Comisionada
Departamento de Salud Pública de Chicago





School Lead Water Testing - Data Collection Form

School Short Name **Tilden HS**
 Date of test **10/19/16**

School Short Name	Facility ID	Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
Tilden HS	51584	51584-3-KIT-KS01-001	Main- 3rd Floor Kitchen, South Wall 3-Basin, Left Faucet	10/20/16 6:00 AM	0.322	BA
Tilden HS	51584	51584-3-KIT-KS01-002	Main- 3rd Floor Kitchen, South Wall 3-Basin, Left Faucet	10/20/16 6:00 AM	0.248	BA
Tilden HS	51584	51584-3-KIT-KS01-003	Main- 3rd Floor Kitchen, South Wall 3-Basin, Left Faucet	10/20/16 6:00 AM	0.232	BA
Tilden HS	51584	51584-3-KIT-KS01-004	Main- 3rd Floor Kitchen, South Wall 3-Basin, Left Faucet	10/20/16 6:00 AM	0.261	BA
Tilden HS	51584	51584-3-KIT-KS01-005	Main- 3rd Floor Kitchen, South Wall 3-Basin, Left Faucet	10/20/16 6:00 AM	0.259	BA
Tilden HS	51584	51584-3-KIT-KS02-001	Main- 3rd Floor Kitchen, South Wall 3-Basin, Center Faucet	10/20/16 6:00 AM	0.637	BA
Tilden HS	51584	51584-3-KIT-KS02-002	Main- 3rd Floor Kitchen, South Wall 3-Basin, Center Faucet	10/20/16 6:00 AM	0.421	BA
Tilden HS	51584	51584-3-KIT-KS02-003	Main- 3rd Floor Kitchen, South Wall 3-Basin, Center Faucet	10/20/16 6:00 AM	0.331	BA
Tilden HS	51584	51584-3-KIT-KS02-004	Main- 3rd Floor Kitchen, South Wall 3-Basin, Center Faucet	10/20/16 6:00 AM	0.363	BA
Tilden HS	51584	51584-3-KIT-KS02-005	Main- 3rd Floor Kitchen, South Wall 3-Basin, Center Faucet	10/20/16 6:00 AM	0.333	BA
Tilden HS	51584	51584-3-KIT-KS03-001	Main- 3rd Floor Kitchen, South Wall 3-Basin, Right Faucet	10/20/16 6:00 AM	1.89	BA
Tilden HS	51584	51584-3-KIT-KS03-002	Main- 3rd Floor Kitchen, South Wall 3-Basin, Right Faucet	10/20/16 6:00 AM	0.568	BA
Tilden HS	51584	51584-3-KIT-KS03-003	Main- 3rd Floor Kitchen, South Wall 3-Basin, Right Faucet	10/20/16 6:00 AM	0.48	BA
Tilden HS	51584	51584-3-KIT-KS03-004	Main- 3rd Floor Kitchen, South Wall 3-Basin, Right Faucet	10/20/16 6:00 AM	0.461	BA
Tilden HS	51584	51584-3-KIT-KS03-005	Main- 3rd Floor Kitchen, South Wall 3-Basin, Right Faucet	10/20/16 6:00 AM	0.421	BA
Tilden HS	51584	51584-3-KIT-KS04-001	Main- 3rd Floor Kitchen, South Wall 2-Basin, Left Faucet	10/20/16 6:00 AM	1.07	BA
Tilden HS	51584	51584-3-KIT-KS04-002	Main- 3rd Floor Kitchen, South Wall 2-Basin, Left Faucet	10/20/16 6:00 AM	0.674	BA
Tilden HS	51584	51584-3-KIT-KS04-003	Main- 3rd Floor Kitchen, South Wall 2-Basin, Left Faucet	10/20/16 6:00 AM	0.358	BA
Tilden HS	51584	51584-3-KIT-KS04-004	Main- 3rd Floor Kitchen, South Wall 2-Basin, Left Faucet	10/20/16 6:00 AM	0.373	BA
Tilden HS	51584	51584-3-KIT-KS04-005	Main- 3rd Floor Kitchen, South Wall 2-Basin, Left Faucet	10/20/16 6:00 AM	0.374	BA
Tilden HS	51584	51584-3-KIT-KS05-001	Main- 3rd Floor Kitchen, South Wall 2-Basin, Right Faucet	10/20/16 6:00 AM	0.944	BA
Tilden HS	51584	51584-3-KIT-KS05-002	Main- 3rd Floor Kitchen, South Wall 2-Basin, Right Faucet	10/20/16 6:00 AM	0.428	BA
Tilden HS	51584	51584-3-KIT-KS05-003	Main- 3rd Floor Kitchen, South Wall 2-Basin, Right Faucet	10/20/16 6:00 AM	0.352	BA
Tilden HS	51584	51584-3-KIT-KS05-004	Main- 3rd Floor Kitchen, South Wall 2-Basin, Right Faucet	10/20/16 6:00 AM	0.33	BA
Tilden HS	51584	51584-3-KIT-KS05-005	Main- 3rd Floor Kitchen, South Wall 2-Basin, Right Faucet	10/20/16 6:00 AM	0.309	BA
Tilden HS	51584	51584-3-KIT-KS06-001	Main- 3rd Floor Kitchen, West Wall, Sink	10/20/16 6:00 AM	6.75	BA
Tilden HS	51584	51584-3-KIT-KS06-002	Main- 3rd Floor Kitchen, West Wall, Sink	10/20/16 6:00 AM	3.96	BA
Tilden HS	51584	51584-3-KIT-KS06-003	Main- 3rd Floor Kitchen, West Wall, Sink	10/20/16 6:00 AM	2.27	BA
Tilden HS	51584	51584-3-KIT-KS06-004	Main- 3rd Floor Kitchen, West Wall, Sink	10/20/16 6:00 AM	3.72	BA
Tilden HS	51584	51584-3-KIT-KS06-005	Main- 3rd Floor Kitchen, West Wall, Sink	10/20/16 6:00 AM	6.22	BA
Tilden HS	51584	51584-3-KIT-KS07-001	Main- 3rd Floor Kitchen, North Wall, Left Sink	10/20/16 6:00 AM	1.61	BA
Tilden HS	51584	51584-3-KIT-KS07-002	Main- 3rd Floor Kitchen, North Wall, Left Sink	10/20/16 6:00 AM	2.57	BA
Tilden HS	51584	51584-3-KIT-KS07-003	Main- 3rd Floor Kitchen, North Wall, Left Sink	10/20/16 6:00 AM	2.06	BA
Tilden HS	51584	51584-3-KIT-KS07-004	Main- 3rd Floor Kitchen, North Wall, Left Sink	10/20/16 6:00 AM	2.38	BA
Tilden HS	51584	51584-3-KIT-KS07-005	Main- 3rd Floor Kitchen, North Wall, Left Sink	10/20/16 6:00 AM	1.74	BA
Tilden HS	51584	51584-3-KIT-KS08-001	Main- 3rd Floor Kitchen, North Wall, Right Sink	10/20/16 6:00 AM	2.15	BA
Tilden HS	51584	51584-3-KIT-KS08-002	Main- 3rd Floor Kitchen, North Wall, Right Sink	10/20/16 6:00 AM	8.46	BA

Tilden HS	51584	51584-3-KIT-KS08-003	Main- 3rd Floor Kitchen, North Wall, Right Sink	10/20/16 6:00 AM	0.746	BA
Tilden HS	51584	51584-3-KIT-KS08-004	Main- 3rd Floor Kitchen, North Wall, Right Sink	10/20/16 6:00 AM	0.578	BA
Tilden HS	51584	51584-3-KIT-KS08-005	Main- 3rd Floor Kitchen, North Wall, Right Sink	10/20/16 6:00 AM	0.469	BA
Tilden HS	51584	51584-3-KIT-KS09-001	Main- 3rd Floor Kitchen, South West Center Sink	10/20/16 6:00 AM	0.419	BA
Tilden HS	51584	51584-3-KIT-KS09-002	Main- 3rd Floor Kitchen, South West Center Sink	10/20/16 6:00 AM	0.329	BA
Tilden HS	51584	51584-3-KIT-KS09-003	Main- 3rd Floor Kitchen, South West Center Sink	10/20/16 6:00 AM	0.261	BA
Tilden HS	51584	51584-3-KIT-KS09-004	Main- 3rd Floor Kitchen, South West Center Sink	10/20/16 6:00 AM	0.384	BA
Tilden HS	51584	51584-3-KIT-KS09-005	Main- 3rd Floor Kitchen, South West Center Sink	10/20/16 6:00 AM	0.406	BA
Tilden HS	51584	51584-3-KIT-KS10-001	Main- 3rd Floor Kitchen, Northeast Center Sink	10/20/16 6:00 AM	0.274	BA
Tilden HS	51584	51584-3-KIT-KS10-002	Main- 3rd Floor Kitchen, Northeast Center Sink	10/20/16 6:00 AM	0.91	BA
Tilden HS	51584	51584-3-KIT-KS10-003	Main- 3rd Floor Kitchen, Northeast Center Sink	10/20/16 6:00 AM	0.893	BA
Tilden HS	51584	51584-3-KIT-KS10-004	Main- 3rd Floor Kitchen, Northeast Center Sink	10/20/16 6:00 AM	0.686	BA
Tilden HS	51584	51584-3-KIT-KS10-005	Main- 3rd Floor Kitchen, Northeast Center Sink	10/20/16 6:00 AM	0.683	BA
Tilden HS	51584	51584-3-HAL-F11-001	Main- Outside Room 301, Fountain	10/20/16 6:00 AM	3.75	BA
Tilden HS	51584	51584-3-HAL-F11-002	Main- Outside Room 301, Fountain	10/20/16 6:00 AM	3.34	BA
Tilden HS	51584	51584-3-HAL-F11-003	Main- Outside Room 301, Fountain	10/20/16 6:00 AM	3.52	BA
Tilden HS	51584	51584-3-HAL-F11-004	Main- Outside Room 301, Fountain	10/20/16 6:00 AM	3.12	BA
Tilden HS	51584	51584-3-HAL-F11-005	Main- Outside Room 301, Fountain	10/20/16 6:00 AM	2.85	BA
Tilden HS	51584	51584-3-HAL-F12-001	Main- Outside Room 308, Fountain	10/20/16 6:00 AM	0.555	BA
Tilden HS	51584	51584-3-HAL-F12-002	Main- Outside Room 308, Fountain	10/20/16 6:00 AM	0.482	BA
Tilden HS	51584	51584-3-HAL-F12-003	Main- Outside Room 308, Fountain	10/20/16 6:00 AM	0.422	BA
Tilden HS	51584	51584-3-HAL-F12-004	Main- Outside Room 308, Fountain	10/20/16 6:00 AM	0.51	BA
Tilden HS	51584	51584-3-HAL-F12-005	Main- Outside Room 308, Fountain	10/20/16 6:00 AM	0.484	BA
Tilden HS	51584	51584-3-HAL-F13-001	Main- Across From Room 318, Fountain	10/20/16 6:00 AM	3.62	BA
Tilden HS	51584	51584-3-HAL-F13-002	Main- Across From Room 318, Fountain	10/20/16 6:00 AM	0.757	BA
Tilden HS	51584	51584-3-HAL-F13-003	Main- Across From Room 318, Fountain	10/20/16 6:00 AM	0.818	BA
Tilden HS	51584	51584-3-HAL-F13-004	Main- Across From Room 318, Fountain	10/20/16 6:00 AM	0.731	BA
Tilden HS	51584	51584-3-HAL-F13-005	Main- Across From Room 318, Fountain	10/20/16 6:00 AM	0.647	BA
Tilden HS	51584	51584-3-HAL-F14-001	Main- Outside Room 333, Fountain	10/20/16 6:00 AM	1.45	BA
Tilden HS	51584	51584-3-HAL-F14-002	Main- Outside Room 333, Fountain	10/20/16 6:00 AM	1.94	BA
Tilden HS	51584	51584-3-HAL-F14-003	Main- Outside Room 333, Fountain	10/20/16 6:00 AM	2.53	BA
Tilden HS	51584	51584-3-HAL-F14-004	Main- Outside Room 333, Fountain	10/20/16 6:00 AM	2.65	BA
Tilden HS	51584	51584-3-HAL-F14-005	Main- Outside Room 333, Fountain	10/20/16 6:00 AM	2.83	BA
Tilden HS	51584	51584-4-437-KS01-001	Main- Culinary Arts Room 437, West Wall, Left Sink	10/20/16 6:00 AM	1.94	BA
Tilden HS	51584	51584-4-437-KS01-002	Main- Culinary Arts Room 437, West Wall, Left Sink	10/20/16 6:00 AM	0.678	BA
Tilden HS	51584	51584-4-437-KS01-003	Main- Culinary Arts Room 437, West Wall, Left Sink	10/20/16 6:00 AM	0.653	BA
Tilden HS	51584	51584-4-437-KS01-004	Main- Culinary Arts Room 437, West Wall, Left Sink	10/20/16 6:00 AM	0.473	BA
Tilden HS	51584	51584-4-437-KS01-005	Main- Culinary Arts Room 437, West Wall, Left Sink	10/20/16 6:00 AM	0.539	BA
Tilden HS	51584	51584-4-437-KS02-001	Main- Culinary Arts Room 437, West Wall, Right Sink	10/20/16 6:00 AM	0.578	BA
Tilden HS	51584	51584-4-437-KS02-002	Main- Culinary Arts Room 437, West Wall, Right Sink	10/20/16 6:00 AM	0.788	BA
Tilden HS	51584	51584-4-437-KS02-003	Main- Culinary Arts Room 437, West Wall, Right Sink	10/20/16 6:00 AM	0.49	BA
Tilden HS	51584	51584-4-437-KS02-004	Main- Culinary Arts Room 437, West Wall, Right Sink	10/20/16 6:00 AM	0.884	BA
Tilden HS	51584	51584-4-437-KS02-005	Main- Culinary Arts Room 437, West Wall, Right Sink	10/20/16 6:00 AM	0.936	BA
Tilden HS	51584	51584-4-437-KS03-001	Main- Culinary Arts Room 437, South Wall, Left Sink	10/20/16 6:00 AM	0.372	BA
Tilden HS	51584	51584-4-437-KS03-002	Main- Culinary Arts Room 437, South Wall, Left Sink	10/20/16 6:00 AM	0.284	BA
Tilden HS	51584	51584-4-437-KS03-003	Main- Culinary Arts Room 437, South Wall, Left Sink	10/20/16 6:00 AM	0.252	BA
Tilden HS	51584	51584-4-437-KS03-004	Main- Culinary Arts Room 437, South Wall, Left Sink	10/20/16 6:00 AM	0.207	BA
Tilden HS	51584	51584-4-437-KS03-005	Main- Culinary Arts Room 437, South Wall, Left Sink	10/20/16 6:00 AM	0.205	BA
Tilden HS	51584	51584-4-437-KS04-001	Main- Culinary Arts Room 437, South Wall, Right Sink	10/20/16 6:00 AM	1.19	BA
Tilden HS	51584	51584-4-437-KS04-002	Main- Culinary Arts Room 437, South Wall, Right Sink	10/20/16 6:00 AM	0.427	BA
Tilden HS	51584	51584-4-437-KS04-003	Main- Culinary Arts Room 437, South Wall, Right Sink	10/20/16 6:00 AM	0.395	BA

Tilden HS	51584	51584-4-437-KS04-004	Main- Culinary Arts Room 437, South Wall, Right Sink	10/20/16 6:00 AM	0.594	BA
Tilden HS	51584	51584-4-437-KS04-005	Main- Culinary Arts Room 437, South Wall, Right Sink	10/20/16 6:00 AM	0.672	BA
Tilden HS	51584	51584-4-HAL-F05-001	Main- Next to Room 401, Fountain	10/20/16 6:00 AM	3.39	BA
Tilden HS	51584	51584-4-HAL-F05-002	Main- Next to Room 401, Fountain	10/20/16 6:00 AM	3.63	BA
Tilden HS	51584	51584-4-HAL-F05-003	Main- Next to Room 401, Fountain	10/20/16 6:00 AM	3.89	BA
Tilden HS	51584	51584-4-HAL-F05-004	Main- Next to Room 401, Fountain	10/20/16 6:00 AM	3.64	BA
Tilden HS	51584	51584-4-HAL-F05-005	Main- Next to Room 401, Fountain	10/20/16 6:00 AM	3.65	BA
Tilden HS	51584	51584-4-HAL-F06-001	Main- Next to Room 410, Right Fountain	10/20/16 6:00 AM	0.652	BA
Tilden HS	51584	51584-4-HAL-F06-002	Main- Next to Room 410, Right Fountain	10/20/16 6:00 AM	0.535	BA
Tilden HS	51584	51584-4-HAL-F06-003	Main- Next to Room 410, Right Fountain	10/20/16 6:00 AM	0.548	BA
Tilden HS	51584	51584-4-HAL-F06-004	Main- Next to Room 410, Right Fountain	10/20/16 6:00 AM	0.573	BA
Tilden HS	51584	51584-4-HAL-F06-005	Main- Next to Room 410, Right Fountain	10/20/16 6:00 AM	0.545	BA
Tilden HS	51584	51584-1-HAL-F01-001	Main Across From Room 107A, Fountain	10/20/16 6:00 AM	5.89	BA
Tilden HS	51584	51584-1-HAL-F01-002	Main Across From Room 107A, Fountain	10/20/16 6:00 AM	3.34	BA
Tilden HS	51584	51584-1-HAL-F01-003	Main Across From Room 107A, Fountain	10/20/16 6:00 AM	1.41	BA
Tilden HS	51584	51584-1-HAL-F01-004	Main Across From Room 107A, Fountain	10/20/16 6:00 AM	1.3	BA
Tilden HS	51584	51584-1-HAL-F01-005	Main Across From Room 107A, Fountain	10/20/16 6:00 AM	1.24	BA
Tilden HS	51584	51584-2-HAL-F01-001	Main- Across From Room 228, Fountain	10/20/16 6:00 AM	2.09	BA
Tilden HS	51584	51584-2-HAL-F01-002	Main- Across From Room 228, Fountain	10/20/16 6:00 AM	1.02	BA
Tilden HS	51584	51584-2-HAL-F01-003	Main- Across From Room 228, Fountain	10/20/16 6:00 AM	1.14	BA
Tilden HS	51584	51584-2-HAL-F01-004	Main- Across From Room 228, Fountain	10/20/16 6:00 AM	0.946	BA
Tilden HS	51584	51584-2-HAL-F01-005	Main- Across From Room 228, Fountain	10/20/16 6:00 AM	0.789	BA
Tilden HS	51584	51584-2-HAL-F02-001	Main- Across From Room 215, Right Fountain	10/20/16 6:00 AM	0.61	BA
Tilden HS	51584	51584-2-HAL-F02-002	Main- Across From Room 215, Right Fountain	10/20/16 6:00 AM	0.747	BA
Tilden HS	51584	51584-2-HAL-F02-003	Main- Across From Room 215, Right Fountain	10/20/16 6:00 AM	0.672	BA
Tilden HS	51584	51584-2-HAL-F02-004	Main- Across From Room 215, Right Fountain	10/20/16 6:00 AM	0.486	BA
Tilden HS	51584	51584-2-HAL-F02-005	Main- Across From Room 215, Right Fountain	10/20/16 6:00 AM	0.433	BA
Tilden HS	51584	51584-2-HAL-F03-001	Main- Across From Room 215, Left Fountain	10/20/16 6:00 AM	0.726	BA
Tilden HS	51584	51584-2-HAL-F03-002	Main- Across From Room 215, Left Fountain	10/20/16 6:00 AM	0.751	BA
Tilden HS	51584	51584-2-HAL-F03-003	Main- Across From Room 215, Left Fountain	10/20/16 6:00 AM	0.636	BA
Tilden HS	51584	51584-2-HAL-F03-004	Main- Across From Room 215, Left Fountain	10/20/16 6:00 AM	0.664	BA
Tilden HS	51584	51584-2-HAL-F03-005	Main- Across From Room 215, Left Fountain	10/20/16 6:00 AM	0.704	BA
Tilden HS	51584	51584-2-HAL-F04-001	Main- Outside Room 232, Fountain	10/20/16 6:00 AM	1.35	BA
Tilden HS	51584	51584-2-HAL-F04-002	Main- Outside Room 232, Fountain	10/20/16 6:00 AM	2.05	BA
Tilden HS	51584	51584-2-HAL-F04-003	Main- Outside Room 232, Fountain	10/20/16 6:00 AM	1.83	BA
Tilden HS	51584	51584-2-HAL-F04-004	Main- Outside Room 232, Fountain	10/20/16 6:00 AM	2.3	BA
Tilden HS	51584	51584-2-HAL-F04-005	Main- Outside Room 232, Fountain	10/20/16 6:00 AM	1.22	BA
Tilden HS	51584	51584-2-HAL-F05-001	Main- Outside Room 203, Left Fountain	10/20/16 6:00 AM	0.383	BA
Tilden HS	51584	51584-2-HAL-F05-002	Main- Outside Room 203, Left Fountain	10/20/16 6:00 AM	0.388	BA
Tilden HS	51584	51584-2-HAL-F05-003	Main- Outside Room 203, Left Fountain	10/20/16 6:00 AM	0.41	BA
Tilden HS	51584	51584-2-HAL-F05-004	Main- Outside Room 203, Left Fountain	10/20/16 6:00 AM	0.361	BA
Tilden HS	51584	51584-2-HAL-F05-005	Main- Outside Room 203, Left Fountain	10/20/16 6:00 AM	0.394	BA
Tilden HS	51584	51584-2-HAL-F06-001	Main- Outside Room 203, Right Fountain	10/20/16 6:00 AM	1.25	BA
Tilden HS	51584	51584-2-HAL-F06-002	Main- Outside Room 203, Right Fountain	10/20/16 6:00 AM	1.43	BA
Tilden HS	51584	51584-2-HAL-F06-003	Main- Outside Room 203, Right Fountain	10/20/16 6:00 AM	1.53	BA
Tilden HS	51584	51584-2-HAL-F06-004	Main- Outside Room 203, Right Fountain	10/20/16 6:00 AM	1.18	BA
Tilden HS	51584	51584-2-HAL-F06-005	Main- Outside Room 203, Right Fountain	10/20/16 6:00 AM	0.815	BA
Tilden HS	51584	51584-2-HAL-F07-001	Main- Outside Room 239B, Fountain	10/20/16 6:00 AM	14.3	BA
Tilden HS	51584	51584-2-HAL-F07-002	Main- Outside Room 239B, Fountain	10/20/16 6:00 AM	20.1	AA
Tilden HS	51584	51584-2-HAL-F07-003	Main- Outside Room 239B, Fountain	10/20/16 6:00 AM	13.5	BA
Tilden HS	51584	51584-2-HAL-F07-004	Main- Outside Room 239B, Fountain	10/20/16 6:00 AM	5.71	BA

Tilden HS	51585	51584-2-HAL-F07-005	Main- Outside Room 239B, Fountain	10/20/16 6:00 AM	3.75	BA
-----------	-------	---------------------	-----------------------------------	------------------	------	----

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit

BA-Below EPA Action Level of 15 ppb

AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations