



School Lead Water Testing Summary

School Short Name [Coonley](#)
Address [4046 N. Leavitt](#)
Facility ID [51055](#)
CPS Team Member [Craig Edgerley](#)
MEC Team Member [Evan Christian](#)

Length of time water remained in pipes before sampled [Approx. 9 hours](#)
Water last used (Time and date) [Approx. 9 PM 4/27/16](#)
Date of test [04/28/16](#)
Report based on lab results dated [5/2/2016](#)

Sample ID #	Sample Location	Sample Collection Time & Date	Test Results (ppb)	ppb Level
51055-B-K-CS-01	Kitchen	6:09AM 4/28/16	ND	-
51055-B-C-F-02	Gym	6:13 AM 4/28/16	ND	-
51055-B-N-F-03	Hallway by Cafeteria	6:19 AM 4/28/16	ND	-
51055-1-C-F-04	Hallway by Room 101	6:22 AM 4/28/16	ND	-
51055-2-C-WC-05	Hallway by Room 201	6:24 AM 4/28/16	ND	-
51055-2-C-F-06	Hallway by Room 200E	6:26 AM 4/28/16	ND	-
51055-3-W-F-07	Hallway by Room 311	6:28 AM 4/28/16	ND	-

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit
BA-Below EPA Action Level of 15 ppb
AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations