



School Lead Water Testing Summary

School Short Name **Dett**

Address 2131 W. Monroe St.

Facility ID 51187

CPS Team Member Prins Sales

MEC Team Member Mark Wyco

Length of time water remained in pipes before sampled [Approx. 10 hours](#)

Water last used (Time and date) [Approx 10 PM 5/2/16](#)

Date of test [5/3/2016](#)

Report based on lab results dated [5/10/2016](#)

Sample ID #	Sample Location	Sample Collection Time & Date	Test Results (ppb)	ppb Level
51187-1-E-CS-01	Kitchen	6:15 AM 5/3/16	ND	-
51187-1-E-F-02	Hallway by Gymnasium	6:20 AM 5/3/16	ND	-
51187-1--C-F-03	Hallway by Room 101	6:23 AM 5/3/16	8.26	BA
51187-2-W-F-04	Hallway by West Restrooms	6:28 AM 5/3/16	ND	-
51187-3-W-F-05	Hallway by West Restrooms	6:30 AM 5/3/16	ND	-

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit

BA-Below EPA Action Level of 15 ppb

AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations