



School Lead Water Testing - Data Collection Form

School Short Name **Wentworth**

Length of time water remained in pipes before sampled (hours) 13.00
Report based on lab results dated 6/9/16
Date of test 05/25/16
Water last used (Time and date) Approx 4 PM 5/24/16

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
25811-B-E01-S-001	Basement Kitchen Sink east	5/25/2016 5:00AM	0.371	BA
25811-B-E01-S-002	Basement Kitchen Sink east	5/25/2016 5:00AM	0.342	BA
25811-B-E01-S-003	Basement Kitchen Sink east	5/25/2016 5:00AM	0.325	BA
25811-B-E01-S-004	Basement Kitchen Sink east	5/25/2016 5:00AM	0.383	BA
25811-B-E01-S-005	Basement Kitchen Sink East	5/25/2016 5:00AM	0.295	BA
25811-2-E02-F-001	2nd Floor Fountain #2	5/25/2016 5:00AM	15.3	AA
25811-2-E02-F-003	2nd Floor Fountain #2	5/25/2016 5:00AM	35.5	AA
25811-2-E02-F-005	2nd Floor Fountain #2	5/25/2016 5:00AM	20.1	AA
25811-3-E02-F-002	3rd Floor Fountain #2	5/25/2016 5:00AM	21	AA
25811-B-E03-F-001	Basement Fountain #2 East	5/25/2016 5:00AM	170	AA
25811-1-E02-F-001	1st Floor Fountain #2	5/25/2016 5:00AM	1.65	BA
25811-1-E02-F-002	1st Floor Fountain #2	5/25/2016 5:00AM	1.54	BA
25811-1-E02-F-003	1st Floor Fountain #2	5/25/2016 5:00AM	1.9	BA
25811-1-E02-F-004	1st Floor Fountain #2	5/25/2016 5:00AM	1.73	BA
25811-1-E02-F-005	1st Floor Fountain #2	5/25/2016 5:00AM	1.87	BA
25811-B-E03-F-002	Basement Fountain #2 East	5/25/2016 5:00AM	108	AA
25811-B-E03-F-003	Basement Fountain #2 East	5/25/2016 5:00AM	28.4	AA
25811-B-E03-F-004	Basement Fountain #2 East	5/25/2016 5:00AM	31	AA
25811-B-E03-F-005	Basement Fountain #2 East	5/25/2016 5:00AM	132	AA
25811-B-E02-F-001	Basement Fountain East	5/25/2016 5:00AM	28.2	AA
25811-1-E04-F-001	1st Floor Fountain #1	5/25/2016 5:00AM	0.817	BA
25811-1-E04-F-002	1st Floor Fountain #1	5/25/2016 5:00AM	1.54	BA
25811-1-E04-F-003	1st Floor Fountain #1	5/25/2016 5:00AM	1.9	BA
25811-1-E04-F-004	1st Floor Fountain #1	5/25/2016 5:00AM	1.73	BA
25811-1-E04-F-005	1st Floor Fountain #1	5/25/2016 5:00AM	1.87	BA
25811-2-E01-F-001	2nd Floor Fountain #1	5/25/2016 5:00AM	1.78	BA
25811-2-E01-F-002	2nd Floor Fountain #1	5/25/2016 5:00AM	2.1	BA
25811-2-E01-F-003	2nd Floor Fountain #1	5/25/2016 5:00AM	2.38	BA
25811-2-E01-F-004	2nd Floor Fountain #1	5/25/2016 5:00AM	2.29	BA
25811-2-E01-F-005	2nd Floor Fountain #1	5/25/2016 5:00AM	2.04	BA
25811-B-E02-F-002	Basement Fountain East	5/25/2016 5:00AM	47	AA
25811-2-E02-F-002	2nd Floor Fountain #2	5/25/2016 5:00AM	8.54	BA
25811-B-E02-F-003	Basement Fountain East	5/25/2016 5:00AM	89.2	AA
25811-2-E02-F-004	2nd Floor Fountain #2	5/25/2016 5:00AM	11.4	BA
25811-B-E02-F-004	Basement Fountain East	5/25/2016 5:00AM	110	AA
25811-3-E01-F-001	3rd Floor Fountain #1	5/25/2016 5:00AM	3.63	BA
25811-3-E01-F-002	3rd Floor Fountain #1	5/25/2016 5:00AM	3	BA
25811-3-E01-F-003	3rd Floor Fountain #1	5/25/2016 5:00AM	2.45	BA
25811-3-E01-F-004	3rd Floor Fountain #1	5/25/2016 5:00AM	2.38	BA
25811-3-E01-F-005	3rd Floor Fountain #1	5/25/2016 5:00AM	2.17	BA
25811-3-E02-F-001	3rd Floor Fountain #2	5/25/2016 5:00AM	6.27	BA
25811-B-E02-F-005	Basement Fountain East	5/25/2016 5:00AM	35.9	AA
25811-3-E02-F-003	3rd Floor Fountain #2	5/25/2016 5:00AM	2.95	BA
25811-3-E02-F-004	3rd Floor Fountain #2	5/25/2016 5:00AM	2.63	BA
25811-3-E02-F-005	3rd Floor Fountain #2	5/25/2016 5:00AM	3.83	BA
25811-1-N01-S-001	Annex 1st Floor Sink Room 125	5/25/2016 5:00AM	0.631	BA
25811-1-N01-S-002	Annex 1st Floor Sink Room 125	5/25/2016 5:00AM	0.25	BA
25811-1-N01-S-003	Annex 1st Floor Sink Room 125	5/25/2016 5:00AM	0.742	BA
25811-1-N01-S-004	Annex 1st Floor Sink Room 125	5/25/2016 5:00AM	0.761	BA
25811-1-N01-S-005	Annex 1st Floor Sink Room 125	5/25/2016 5:00AM	0.72	BA
25811-1-N02-F-001	Annex 1st Floor Fountain #1	5/25/2016 5:00AM	0.522	BA
25811-1-N02-F-002	Annex 1st Floor Fountain #1	5/25/2016 5:00AM	0.356	BA
25811-1-N02-F-003	Annex 1st Floor Fountain #1	5/25/2016 5:00AM	0.233	BA
25811-1-N02-F-004	Annex 1st Floor Fountain #1	5/25/2016 5:00AM	0.221	BA
25811-1-N02-F-005	Annex 1st Floor Fountain #1	5/25/2016 5:00AM	0.221	BA
25811-1-N03-F-001	Annex 1st Floor Fountain #2	5/25/2016 5:00AM	0.718	BA
25811-1-N03-F-002	Annex 1st Floor Fountain #2	5/25/2016 5:00AM	0.237	BA
25811-1-N03-F-003	Annex 1st Floor Fountain #2	5/25/2016 5:00AM	0.211	BA
25811-1-N03-F-004	Annex 1st Floor Fountain #2	5/25/2016 5:00AM	0.154	BA
25811-1-N03-F-005	Annex 1st Floor Fountain #2	5/25/2016 5:00AM	0.163	BA
25811-1-N04-S-001	Annex 1st Floor Kitch Sink	5/25/2016 5:00AM	0.74	BA
25811-1-N04-S-002	Annex 1st Floor Kitch Sink	5/25/2016 5:00AM	0.753	BA
25811-1-N04-S-003	Annex 1st Floor Kitch Sink	5/25/2016 5:00AM	0.726	BA
25811-1-N04-S-004	Annex 1st Floor Kitch Sink	5/25/2016 5:00AM	0.55	BA
25811-1-N04-S-005	Annex 1st Floor Kitch Sink	5/25/2016 5:00AM	0.834	BA
25811-1-N05-S-001	Annex 1st Floor Room 120 Sink	5/25/2016 5:00AM	2.74	BA
25811-1-N05-S-002	Annex 1st Floor Room 120 Sink	5/25/2016 5:00AM	2.59	BA
25811-1-N05-S-003	Annex 1st Floor Room 120 Sink	5/25/2016 5:00AM	1.07	BA
25811-1-N05-S-004	Annex 1st Floor Room 120 Sink	5/25/2016 5:00AM	1.33	BA
25811-1-N05-S-005	Annex 1st Floor Room 120 Sink	5/25/2016 5:00AM	1.02	BA
25811-2-N01-001	Annex 2nd Floor Fountain #1	5/25/2016 5:00AM	0.722	BA
25811-2-N01-002	Annex 2nd Floor Fountain #1	5/25/2016 5:00AM	0.233	BA
25811-2-N01-003	Annex 2nd Floor Fountain #1	5/25/2016 5:00AM	0.174	BA
25811-2-N01-004	Annex 2nd Floor Fountain #1	5/25/2016 5:00AM	0.174	BA
25811-2-N01-005	Annex 2nd Floor Fountain #1	5/25/2016 5:00AM	0.678	BA
25811-2-N02-001	Annex 2nd Floor Fountain #2	5/25/2016 5:00AM	0.411	BA
25811-2-N02-002	Annex 2nd Floor Fountain #2	5/25/2016 5:00AM	0.173	BA
25811-2-N02-003	Annex 2nd Floor Fountain #2	5/25/2016 5:00AM	0.168	BA
25811-2-N02-004	Annex 2nd Floor Fountain #2	5/25/2016 5:00AM	0.162	BA
25811-2-N02-005	Annex 2nd Floor Fountain #2	5/25/2016 5:00AM	0.183	BA

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit
BA-Below EPA Action Level of 15 ppb
AA-Above EPA Action Level