



August 2, 2016

Dear CPS family,

In light of national events that have brought increased attention to the issue of water quality, the City of Chicago announced several additional precautionary measures that will be added to the City's water testing protocol, continuing the City's track record of complying with current state and federal regulations as well as exceeding industry standards.

As part of this announcement, Chicago Public Schools (CPS) began testing the water for levels of lead from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe. Schools are being tested based on a priority criteria that includes the age of the school, age of the students (with priority given to schools with pre-K programs), presence of a kitchen (where meals are prepared) and presence of pipes that could need repairs or replacement.

The results of all the schools are coming in on a rolling basis, and the majority have had levels under the EPA's action level of 15 parts per billion (ppb). We wanted to let you know that no lead was found above the action level in your child's school. The full results of your school's water samples can be found online at cps.edu/leadtesting.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician for testing. Additionally, CDPH's lead hotline can address any health related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

Forrest Claypool
CEO, Chicago Public Schools

Dr. Julie Morita
Commissioner, Chicago Department of Public Health





2 de agosto de 2016

Estimadas familias de CPS,

Ante los eventos nacionales que han incrementado la atención en el tema de la calidad del agua, la Alcaldía de Chicago anunció varias medidas adicionales de precaución que serán agregadas al protocolo de prueba del agua de la ciudad, continuando con el cumplimiento de las regulaciones estatales y federales, que exceden los estándares industriales.

Como parte de este anuncio, las Escuelas Públicas de Chicago (CPS) comenzaron a medir los niveles de plomo en el agua de todas las escuelas del distrito. Nuestra principal prioridad es la salud y seguridad de todos nuestros estudiantes y personal, y estas pruebas fueron iniciadas solamente para extremar las precauciones y estar seguros de que el agua es segura. Las escuelas son examinadas con base a un criterio de prioridad que incluye la antigüedad del edificio, edad de los estudiantes (con prioridad para las escuelas con programas preescolares), presencia de una cocina (donde se preparan alimentos) y la presencia de cañerías que necesiten reparación o reemplazo.

Los resultados de todas las escuelas se están conociendo, y la mayoría ha registrado niveles por debajo del nivel de acción de la EPA, que es de 15 partículas por billón (ppb). Queremos hacerles saber que no se encontraron rastros de plomo por encima del nivel de acción en la escuela de su niño. Los resultados completos de las pruebas en su escuela se pueden ver en línea en cps.edu/leadtesting.

Los lineamientos federales indican que los niños menores de seis años son los que corren mayores riesgos con la exposición al plomo, algo que puede ocurrir de varias fuentes, incluyendo pintura, tierra y algunos productos de consumo. Si están preocupados por la posible exposición de su hijo al plomo, el Departamento de Salud Pública de la ciudad de Chicago (CDPH) recomienda visitar a su pediatra o a alguno de los centros de salud listados en el material adjunto, para una prueba. Además, la línea directa del CDPH puede responder cualquier pregunta que tengan, o ayudarlos a decidir si su niño debe ser examinado; por preguntas o más información, llame por favor al 312-747-5323. Por información adicional sobre el plomo y los niños, visite www.cdc.gov/lead.

La seguridad de sus hijos es nuestra principal prioridad, y hacemos todo lo que está en nuestro poder para resolver esta situación de una manera rápida y rigurosa. Continuaremos informándoles sobre este proceso.

Atentamente,

Forrest Claypool
CEO, Escuelas Públicas de Chicago

Dra. Julie Morita, Comisionada
Departamento de Salud Pública de Chicago





School Lead Water Testing - Data Collection Form

School Name Aldridge

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
51430-1-NW-F01-001	1st Floor Inside Room 100, Fountain	6/18/16 7:00 AM	0.779	BA
51430-1-NW-F01-002	1st Floor Inside Room 100, Fountain	6/18/16 7:01 AM	0.35	BA
51430-1-NW-F01-003	1st Floor Inside Room 100, Fountain	6/18/16 7:02 AM	0.833	BA
51430-1-NW-F01-004	1st Floor Inside Room 100, Fountain	6/18/16 7:03 AM	0.158	BA
51430-1-NW-F01-005	1st Floor Inside Room 100, Fountain	6/18/16 7:04 AM	0.336	BA
51430-1-NW-S02-001	1st Floor Inside Room 100, Sink	6/18/16 7:05 AM	0.224	BA
51430-1-NW-S02-002	1st Floor Inside Room 100, Sink	6/18/16 7:06 AM	0.23	BA
51430-1-NW-S02-003	1st Floor Inside Room 100, Sink	6/18/16 7:07 AM	0.226	BA
51430-1-NW-S02-004	1st Floor Inside Room 100, Sink	6/18/16 7:08 AM	0.235	BA
51430-1-NW-S02-005	1st Floor Inside Room 100, Sink	6/18/16 7:09 AM	1.14	BA
51430-1-NW-S03-001	1st Floor Kitchen, Sink	6/18/16 7:15 AM	1.09	BA
51430-1-NW-S03-002	1st Floor Kitchen, Sink	6/18/16 7:16 AM	2.45	BA
51430-1-NW-S03-003	1st Floor Kitchen, Sink	6/18/16 7:17 AM	3.72	BA
51430-1-NW-S03-004	1st Floor Kitchen, Sink	6/18/16 7:18 AM	0.378	BA
51430-1-NW-S03-005	1st Floor Kitchen, Sink	6/18/16 7:19 AM	0.364	BA
51430-1-SW-F04-001	1st Floor By Gym, Fountain 1	6/18/16 7:20 AM	<0.120	ND
51430-1-SW-F04-002	1st Floor By Gym, Fountain 1	6/18/16 7:21 AM	0.123	BA
51430-1-SW-F04-003	1st Floor By Gym, Fountain 1	6/18/16 7:22 AM	0.185	BA
51430-1-SW-F04-004	1st Floor By Gym, Fountain 1	6/18/16 7:23 AM	0.193	BA
51430-1-SW-F04-005	1st Floor By Gym, Fountain 1	6/18/16 7:24 AM	1.31	BA
51430-1-SW-F05-001	1st Floor By Gym, Fountain 2	6/18/16 7:30 AM	<0.120	ND
51430-1-SW-F05-002	1st Floor By Gym, Fountain 2	6/18/16 7:31 AM	0.302	BA
51430-1-SW-F05-003	1st Floor By Gym, Fountain 2	6/18/16 7:32 AM	<0.120	ND
51430-1-SW-F05-004	1st Floor By Gym, Fountain 2	6/18/16 7:33 AM	<0.120	ND
51430-1-SW-F05-005	1st Floor By Gym, Fountain 2	6/18/16 7:34 AM	<0.120	ND
51430-1-S-S06-001	1st Floor Inside Room 105, Sink	6/18/16 7:35 AM	1.34	BA
51430-1-S-S06-002	1st Floor Inside Room 105, Sink	6/18/16 7:36 AM	1.23	BA
51430-1-S-S06-003	1st Floor Inside Room 105, Sink	6/18/16 7:37 AM	0.804	BA
51430-1-S-S06-004	1st Floor Inside Room 105, Sink	6/18/16 7:38 AM	0.458	BA
51430-1-S-S06-005	1st Floor Inside Room 105, Sink	6/18/16 7:39 AM	1.4	BA
51430-1-S-F07-001	1st Floor By Room 105, Fountain 1	6/18/16 7:45 AM	<0.120	ND
51430-1-S-F07-002	1st Floor By Room 105, Fountain 1	6/18/16 7:46 AM	0.595	BA
51430-1-S-F07-003	1st Floor By Room 105, Fountain 1	6/18/16 7:47 AM	0.272	BA
51430-1-S-F07-004	1st Floor By Room 105, Fountain 1	6/18/16 7:48 AM	0.203	BA
51430-1-S-F07-005	1st Floor By Room 105, Fountain 1	6/18/16 7:49 AM	1.84	BA
51430-1-S-F08-001	1st Floor By Room 105, Fountain 2	6/18/16 7:50 AM	<0.120	ND
51430-1-S-F08-002	1st Floor By Room 105, Fountain 2	6/18/16 7:51 AM	<0.120	ND
51430-1-S-F08-003	1st Floor By Room 105, Fountain 2	6/18/16 7:52 AM	<0.120	ND
51430-1-S-F08-004	1st Floor By Room 105, Fountain 2	6/18/16 7:53 AM	<0.120	ND
51430-1-S-F08-005	1st Floor By Room 105, Fountain 2	6/18/16 7:54 AM	0.214	BA
51430-1-S-F09-001	1st Floor By Room 105, Fountain 3	6/18/16 8:00 AM	0.35	BA
51430-1-S-F09-002	1st Floor By Room 105, Fountain 3	6/18/16 8:01 AM	<0.120	ND
51430-1-S-F09-003	1st Floor By Room 105, Fountain 3	6/18/16 8:02 AM	<0.120	ND
51430-1-S-F09-004	1st Floor By Room 105, Fountain 3	6/18/16 8:03 AM	<0.120	ND
51430-1-S-F09-005	1st Floor By Room 105, Fountain 3	6/18/16 8:04 AM	<0.120	ND
51430-1-S-F10-001	1st Floor By Janitors Closet, Fountain 1	6/18/16 8:05 AM	1.71	BA
51430-1-S-F10-002	1st Floor By Janitors Closet, Fountain 1	6/18/16 8:06 AM	1.88	BA
51430-1-S-F10-003	1st Floor By Janitors Closet, Fountain 1	6/18/16 8:07 AM	1.75	BA
51430-1-S-F10-004	1st Floor By Janitors Closet, Fountain 1	6/18/16 8:08 AM	1.79	BA
51430-1-S-F10-005	1st Floor By Janitors Closet, Fountain 1	6/18/16 8:09 AM	1.77	BA
51430-1-S-F11-001	1st Floor By Janitors Closet, Fountain 2	6/18/16 8:15 AM	2.13	BA
51430-1-S-F11-002	1st Floor By Janitors Closet, Fountain 2	6/18/16 8:16 AM	1.81	BA
51430-1-S-F11-003	1st Floor By Janitors Closet, Fountain 2	6/18/16 8:17 AM	1.65	BA
51430-1-S-F11-004	1st Floor By Janitors Closet, Fountain 2	6/18/16 8:18 AM	1.84	BA
51430-1-S-F11-005	1st Floor By Janitors Closet, Fountain 2	6/18/16 8:19 AM	5.76	BA
51430-1-S-E-F12-001	1st Floor By Room 121, Fountain 1	6/18/16 8:20 AM	0.575	BA
51430-1-S-E-F12-002	1st Floor By Room 121, Fountain 1	6/18/16 8:21 AM	0.47	BA
51430-1-S-E-F12-003	1st Floor By Room 121, Fountain 1	6/18/16 8:22 AM	2.16	BA
51430-1-S-E-F12-004	1st Floor By Room 121, Fountain 1	6/18/16 8:23 AM	0.892	BA
51430-1-S-E-F12-005	1st Floor By Room 121, Fountain 1	6/18/16 8:24 AM	0.706	BA
51430-1-S-E-F13-001	1st Floor By Room 121, Fountain 2	6/18/16 8:30 AM	1.42	BA
51430-1-S-E-F13-002	1st Floor By Room 121, Fountain 2	6/18/16 8:31 AM	0.655	BA
51430-1-S-E-F13-003	1st Floor By Room 121, Fountain 2	6/18/16 8:32 AM	0.233	BA
51430-1-S-E-F13-004	1st Floor By Room 121, Fountain 2	6/18/16 8:33 AM	0.182	BA
51430-1-S-E-F13-005	1st Floor By Room 121, Fountain 2	6/18/16 8:34 AM	0.157	BA
51430-1-NE-F14-001	1st Floor By Boys Washroom, Fountain	6/18/16 8:35 AM	<0.120	ND
51430-1-NE-F14-002	1st Floor By Boys Washroom, Fountain	6/18/16 8:36 AM	0.125	BA
51430-1-NE-F14-003	1st Floor By Boys Washroom, Fountain	6/18/16 8:37 AM	0.247	BA
51430-1-NE-F14-004	1st Floor By Boys Washroom, Fountain	6/18/16 8:38 AM	0.952	BA
51430-1-NE-F14-005	1st Floor By Boys Washroom, Fountain	6/18/16 8:39 AM	0.207	BA
51430-1-NE-F15-001	1st Floor By Girls Washroom, Fountain	6/18/16 8:45 AM	0.536	BA
51430-1-NE-F15-002	1st Floor By Girls Washroom, Fountain	6/18/16 8:46 AM	0.58	BA
51430-1-NE-F15-003	1st Floor By Girls Washroom, Fountain	6/18/16 8:47 AM	0.497	BA
51430-1-NE-F15-004	1st Floor By Girls Washroom, Fountain	6/18/16 8:48 AM	0.591	BA
51430-1-NE-F15-005	1st Floor By Girls Washroom, Fountain	6/18/16 8:49 AM	1.39	BA
51430-2-NE-F01-001	2nd Floor By Boys Washroom, Fountain	6/18/16 8:50 AM	3.07	BA
51430-2-NE-F01-002	2nd Floor By Boys Washroom, Fountain	6/18/16 8:51 AM	5.62	BA
51430-2-NE-F01-003	2nd Floor By Boys Washroom, Fountain	6/18/16 8:52 AM	0.915	BA
51430-2-NE-F01-004	2nd Floor By Boys Washroom, Fountain	6/18/16 8:53 AM	0.982	BA
51430-2-NE-F01-005	2nd Floor By Boys Washroom, Fountain	6/18/16 8:54 AM	2.64	BA
51430-2-NE-F02-001	2nd Floor By Girls Washroom, Fountain	6/18/16 8:55 AM	0.849	BA
51430-2-NE-F02-002	2nd Floor By Girls Washroom, Fountain	6/18/16 8:56 AM	0.612	BA
51430-2-NE-F02-003	2nd Floor By Girls Washroom, Fountain	6/18/16 8:57 AM	0.356	BA
51430-2-NE-F02-004	2nd Floor By Girls Washroom, Fountain	6/18/16 8:58 AM	0.344	BA
51430-2-NE-F02-005	2nd Floor By Girls Washroom, Fountain	6/18/16 8:59 AM	0.332	BA

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit

BA-below EPA Action Level of 15 ppb

AA-Above EPA Action Level