

School Lead Water Testing - Data Collection Form

Length of time water remained in pipes before sampled (hours) Report based on lab results dated Date of test Water last used (Time and date) 8+ 05/17/16 5/16/16

Sample ID #	Sample Collection Time & Date	Test Result (ppb)	Test Results
B-S-CS-01	5/17/16 6:15 AM	ND	None Detected (ND)
B-N-F-02	5/17/16 6:20 AM	ND	None Detected (ND)
1-E-F-03	5/17/16 6:24 AM	ND	None Detected (ND)
2-E-F-04	5/17/16 6:28 AM	ND	None Detected (ND)
3-E-F-05	5/17/16 6:32 AM	ND	None Detected (ND)

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 μg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit

BA-Below EPA Action Level of 15 ppb

AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations