



School Lead Water Testing - Data Collection Form

School Name **Hayt**

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
1-W-F01-01	1st Floor Annex Hallway Drinking Fountains	5/28/16 7:00 AM	<0.120	BA
1-W-F01-02	1st Floor Annex Hallway Drinking Fountains	5/28/16 7:00 AM	<0.120	BA
1-W-F01-03	1st Floor Annex Hallway Drinking Fountains	5/28/16 7:00 AM	<0.120	BA
1-W-F01-04	1st Floor Annex Hallway Drinking Fountains	5/28/16 7:00 AM	<0.120	BA
1-W-F01-05	1st Floor Annex Hallway Drinking Fountains	5/28/16 7:00 AM	<0.120	BA
1-W-F02-06	1st Floor Annex Hallway Drinking Fountains	5/28/16 7:02 AM	<0.120	BA
1-W-F02-07	1st Floor Annex Hallway Drinking Fountains	5/28/16 7:02 AM	<0.120	BA
1-W-F02-08	1st Floor Annex Hallway Drinking Fountains	5/28/16 7:02 AM	<0.120	BA
1-W-F02-09	1st Floor Annex Hallway Drinking Fountains	5/28/16 7:02 AM	<0.120	BA
1-W-F02-10	1st Floor Annex Hallway Drinking Fountains	5/28/16 7:02 AM	<0.120	BA
1-W-F03-11	1st Floor Annex Hallway Drinking Fountains	5/28/16 7:05 AM	<0.120	BA
1-W-F03-12	1st Floor Annex Hallway Drinking Fountains	5/28/16 7:05 AM	<0.120	BA
1-W-F03-13	1st Floor Annex Hallway Drinking Fountains	5/28/16 7:05 AM	<0.120	BA
1-W-F03-14	1st Floor Annex Hallway Drinking Fountains	5/28/16 7:05 AM	<0.120	BA
1-W-F03-15	1st Floor Annex Hallway Drinking Fountains	5/28/16 7:05 AM	<0.120	BA
1-E-CS01-16	Room 112	5/28/16 7:07 AM	6.96	BA
1-E-CS01-17	Room 112	5/28/16 7:07 AM	1.36	BA
1-E-CS01-18	Room 112	5/28/16 7:07 AM	1.13	BA
1-E-CS01-19	Room 112	5/28/16 7:07 AM	0.94	BA
1-E-CS01-20	Room 112	5/28/16 7:07 AM	0.99	BA
1-E-CS02-21	Room 112	5/28/16 7:09 AM	2.1	BA
1-E-CS02-22	Room 112	5/28/16 7:09 AM	0.596	BA
1-E-CS02-23	Room 112	5/28/16 7:09 AM	0.56	BA
1-E-CS02-24	Room 112	5/28/16 7:09 AM	0.499	BA
1-E-CS02-25	Room 112	5/28/16 7:09 AM	0.571	BA
1-E-CS01-26	Room 114	5/28/16 7:12 AM	9.61	BA
1-E-CS01-27	Room 114	5/28/16 7:12 AM	2.09	BA
1-E-CS01-28	Room 114	5/28/16 7:12 AM	1.37	BA
1-E-CS01-29	Room 114	5/28/16 7:12 AM	1.22	BA
1-E-CS01-30	Room 114	5/28/16 7:12 AM	1.06	BA
1-E-CS02-31	Room 114	5/28/16 7:15 AM	2.52	BA
1-E-CS02-32	Room 114	5/28/16 7:15 AM	0.422	BA
1-E-CS02-33	Room 114	5/28/16 7:15 AM	0.361	BA
1-E-CS02-34	Room 114	5/28/16 7:15 AM	0.408	BA
1-E-CS02-35	Room 114	5/28/16 7:15 AM	0.349	BA
1-E-CS01-36	Room 116	5/28/16 7:18 AM	2.14	BA
1-E-CS01-37	Room 116	5/28/16 7:18 AM	0.52	BA
1-E-CS01-38	Room 116	5/28/16 7:18 AM	0.415	BA
1-E-CS01-39	Room 116	5/28/16 7:18 AM	0.413	BA
1-E-CS01-40	Room 116	5/28/16 7:18 AM	0.41	BA
1-E-CS02-41	Room 116	5/28/16 7:20 AM	1.52	BA
1-E-CS02-42	Room 116	5/28/16 7:20 AM	0.279	BA
1-E-CS02-43	Room 116	5/28/16 7:20 AM	0.255	BA
1-E-CS02-44	Room 116	5/28/16 7:20 AM	0.24	BA
1-E-CS02-45	Room 116	5/28/16 7:20 AM	0.258	BA
1-E-F01-46	Room 116	5/28/16 7:22 AM	0.551	BA
1-E-F01-47	Room 116	5/28/16 7:22 AM	<0.120	BA
1-E-F01-48	Room 116	5/28/16 7:22 AM	<0.120	BA
1-E-F01-49	Room 116	5/28/16 7:22 AM	<0.120	BA
1-E-F01-50	Room 116	5/28/16 7:22 AM	<0.120	BA
1-E-CS01-51	Room 118	5/28/16 7:24 AM	0.732	BA
1-E-CS01-52	Room 118	5/28/16 7:24 AM	0.198	BA
1-E-CS01-53	Room 118	5/28/16 7:24 AM	0.226	BA
1-E-CS01-54	Room 118	5/28/16 7:24 AM	0.181	BA
1-E-CS01-55	Room 118	5/28/16 7:24 AM	0.179	BA
1-E-CS02-56	Room 118	5/28/16 7:26 AM	0.771	BA
1-E-CS02-57	Room 118	5/28/16 7:26 AM	0.907	BA
1-E-CS02-58	Room 118	5/28/16 7:26 AM	0.512	BA
1-E-CS02-59	Room 118	5/28/16 7:26 AM	0.734	BA
1-E-CS02-60	Room 118	5/28/16 7:26 AM	0.53	BA
1-E-CS01-61	Room 120	5/28/16 7:28 AM	1.72	BA
1-E-CS01-62	Room 120	5/28/16 7:28 AM	0.367	BA
1-E-CS01-63	Room 120	5/28/16 7:28 AM	0.321	BA
1-E-CS01-64	Room 120	5/28/16 7:28 AM	0.264	BA
1-E-CS01-65	Room 120	5/28/16 7:28 AM	0.302	BA
1-E-CS02-66	Room 120	5/28/16 7:30 AM	1.4	BA
1-E-CS02-67	Room 120	5/28/16 7:31 AM	0.643	BA
1-E-CS02-68	Room 120	5/28/16 7:31 AM	0.689	BA
1-E-CS02-69	Room 120	5/28/16 7:31 AM	1.37	BA
1-E-CS02-70	Room 120	5/28/16 7:31 AM	1.62	BA
2-W-F01-71	2nd Floor Annex Hallway Drinking Fountains	5/28/16 7:33 AM	<0.120	BA
2-W-F01-72	2nd Floor Annex Hallway Drinking Fountains	5/28/16 7:33 AM	<0.120	BA
2-W-F01-73	2nd Floor Annex Hallway Drinking Fountains	5/28/16 7:33 AM	<0.120	BA
2-W-F01-74	2nd Floor Annex Hallway Drinking Fountains	5/28/16 7:35 AM	0.253	BA
2-W-F01-75	2nd Floor Annex Hallway Drinking Fountains	5/28/16 7:35 AM	<0.120	BA
2-W-F02-76	2nd Floor Annex Hallway Drinking Fountains	5/28/16 7:35 AM	<0.120	BA
2-W-F02-77	2nd Floor Annex Hallway Drinking Fountains	5/28/16 7:35 AM	<0.120	BA
2-W-F02-78	2nd Floor Annex Hallway Drinking Fountains	5/28/16 7:35 AM	<0.120	BA
2-W-F02-79	2nd Floor Annex Hallway Drinking Fountains	5/28/16 7:35 AM	<0.120	BA
2-W-F02-80	2nd Floor Annex Hallway Drinking Fountains	5/28/16 7:35 AM	<0.120	BA
2-W-F03-81	2nd Floor Annex Hallway Drinking Fountains	5/28/16 7:38 AM	<0.120	BA
2-W-F03-82	2nd Floor Annex Hallway Drinking Fountains	5/28/16 7:38 AM	0.212	BA
2-W-F03-83	2nd Floor Annex Hallway Drinking Fountains	5/28/16 7:38 AM	<0.120	BA
2-W-F03-84	2nd Floor Annex Hallway Drinking Fountains	5/28/16 7:38 AM	0.155	BA
2-W-F03-85	2nd Floor Annex Hallway Drinking Fountains	5/28/16 7:38 AM	0.149	BA
3-N-F01-86	Main Building - 3rd Floor Hall	5/28/16 8:00 AM	0.24	BA
3-N-F01-87	Main Building - 3rd Floor Hall	5/28/16 8:00 AM	0.587	BA
3-N-F01-88	Main Building - 3rd Floor Hall	5/28/16 8:00 AM	0.653	BA
3-N-F01-89	Main Building - 3rd Floor Hall	5/28/16 8:00 AM	0.452	BA
3-N-F01-90	Main Building - 3rd Floor Hall	5/28/16 8:00 AM	0.373	BA
3-N-F02-91	Main Building - 3rd Floor Hall	5/28/16 8:02 AM	0.308	BA
3-N-F02-92	Main Building - 3rd Floor Hall	5/28/16 8:02 AM	0.311	BA
3-N-F02-93	Main Building - 3rd Floor Hall	5/28/16 8:02 AM	0.32	BA
3-N-F02-94	Main Building - 3rd Floor Hall	5/28/16 8:02 AM	0.385	BA
3-N-F02-95	Main Building - 3rd Floor Hall	5/28/16 8:02 AM	0.16	BA
3-N-F03-96	Main Building - 3rd Floor Hall	5/28/16 8:04 AM	0.182	BA

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
1-N-F03-97	Main Building - 3rd Floor Hall	5/29/16 8:04 AM	0.157	BA
1-N-F03-98	Main Building - 3rd Floor Hall	5/29/16 8:04 AM	<0.120	BA
1-N-F03-99	Main Building - 3rd Floor Hall	5/29/16 8:04 AM	<0.120	BA
1-N-F03-100	Main Building - 3rd Floor Hall	5/29/16 8:04 AM	<0.120	BA
2-N-F01-101	Main Building - 2nd Floor Hall - Drinking Fountains	5/29/16 8:06 AM	<0.120	BA
2-N-F01-102	Main Building - 2nd Floor Hall - Drinking Fountains	5/29/16 8:06 AM	<0.120	BA
2-N-F01-103	Main Building - 2nd Floor Hall - Drinking Fountains	5/29/16 8:06 AM	<0.120	BA
2-N-F01-104	Main Building - 2nd Floor Hall - Drinking Fountains	5/29/16 8:06 AM	<0.120	BA
2-N-F01-105	Main Building - 2nd Floor Hall - Drinking Fountains	5/29/16 8:06 AM	<0.120	BA
2-N-F02-106	Main Building - 2nd Floor Hall - Drinking Fountains	5/29/16 8:08 AM	<0.120	BA
2-N-F02-107	Main Building - 2nd Floor Hall - Drinking Fountains	5/29/16 8:08 AM	<0.120	BA
2-N-F02-108	Main Building - 2nd Floor Hall - Drinking Fountains	5/29/16 8:08 AM	<0.120	BA
2-N-F02-109	Main Building - 2nd Floor Hall - Drinking Fountains	5/29/16 8:08 AM	<0.120	BA
2-N-F02-110	Main Building - 2nd Floor Hall - Drinking Fountains	5/29/16 8:08 AM	<0.120	BA
2-N-F03-111	Main Building - 2nd Floor Hall - Drinking Fountains	5/29/16 8:10 AM	<0.120	BA
2-N-F03-112	Main Building - 2nd Floor Hall - Drinking Fountains	5/29/16 8:10 AM	<0.120	BA
2-N-F03-113	Main Building - 2nd Floor Hall - Drinking Fountains	5/29/16 8:10 AM	<0.120	BA
2-N-F03-114	Main Building - 2nd Floor Hall - Drinking Fountains	5/29/16 8:10 AM	<0.120	BA
2-N-F03-115	Main Building - 2nd Floor Hall - Drinking Fountains	5/29/16 8:10 AM	<0.120	BA
1-N-F01-116	Main Building - 1st Floor Hall	5/29/16 8:12 AM	0.371	BA
1-N-F01-117	Main Building - 1st Floor Hall	5/29/16 8:12 AM	0.697	BA
1-N-F01-118	Main Building - 1st Floor Hall	5/30/16 8:12 AM	0.125	BA
1-N-F01-119	Main Building - 1st Floor Hall	5/31/16 8:12 AM	<0.120	BA
1-N-F01-120	Main Building - 1st Floor Hall	6/1/16 8:12 AM	<0.120	BA
1-N-F02-121	Main Building - 1st Floor Hall	5/29/16 8:15 AM	<0.120	BA
1-N-F02-122	Main Building - 1st Floor Hall	5/29/16 8:15 AM	<0.120	BA
1-N-F02-123	Main Building - 1st Floor Hall	5/29/16 8:15 AM	<0.120	BA
1-N-F02-124	Main Building - 1st Floor Hall	5/29/16 8:15 AM	<0.120	BA
1-N-F02-125	Main Building - 1st Floor Hall	5/29/16 8:15 AM	<0.120	BA
1-N-F03-126	Main Building - 1st Floor Hall	5/29/16 8:17 AM	<0.120	BA
1-N-F03-127	Main Building - 1st Floor Hall	5/29/16 8:17 AM	<0.120	BA
1-N-F03-128	Main Building - 1st Floor Hall	5/29/16 8:17 AM	<0.120	BA
1-N-F03-129	Main Building - 1st Floor Hall	5/29/16 8:17 AM	<0.120	BA
1-N-F03-130	Main Building - 1st Floor Hall	5/29/16 8:17 AM	<0.120	BA
B-E-F01-131	Basement East Outside Kitchen Lunchroom	5/29/16 8:19 AM	None Detected	ND
B-E-F01-132	Basement East Outside Kitchen Lunchroom	5/29/16 8:19 AM	None Detected	ND
B-E-F01-133	Basement East Outside Kitchen Lunchroom	5/29/16 8:19 AM	None Detected	ND
B-E-F01-134	Basement East Outside Kitchen Lunchroom	5/29/16 8:19 AM	None Detected	ND
B-E-F01-135	Basement East Outside Kitchen Lunchroom	5/29/16 8:19 AM	None Detected	ND
B-E-F01-136	Basement East Outside Kitchen Lunchroom	5/29/16 8:22 AM	None Detected	ND
B-E-F02-137	Basement East Outside Kitchen Lunchroom	5/29/16 8:22 AM	None Detected	ND
B-E-F02-138	Basement East Outside Kitchen Lunchroom	5/29/16 8:22 AM	None Detected	ND
B-E-F02-139	Basement East Outside Kitchen Lunchroom	5/29/16 8:22 AM	None Detected	ND
B-E-F02-140	Basement East Outside Kitchen Lunchroom	5/29/16 8:22 AM	None Detected	ND
B-E-F03-141	Basement East Outside Kitchen Lunchroom	5/29/16 8:24 AM	None Detected	ND
B-E-F03-142	Basement East Outside Kitchen Lunchroom	5/29/16 8:24 AM	None Detected	ND
B-E-F03-143	Basement East Outside Kitchen Lunchroom	5/29/16 8:24 AM	None Detected	ND
B-E-F03-144	Basement East Outside Kitchen Lunchroom	5/29/16 8:24 AM	None Detected	ND
B-E-F03-145	Basement East Outside Kitchen Lunchroom	5/29/16 8:24 AM	None Detected	ND
B-E-F04-146	Basement East Outside Kitchen Lunchroom	5/29/16 8:26 AM	None Detected	ND
B-E-F04-147	Basement East Outside Kitchen Lunchroom	5/29/16 8:26 AM	None Detected	ND
B-E-F04-148	Basement East Outside Kitchen Lunchroom	5/29/16 8:26 AM	None Detected	ND
B-E-F04-149	Basement East Outside Kitchen Lunchroom	5/29/16 8:26 AM	None Detected	ND
B-E-F04-150	Basement East Outside Kitchen Lunchroom	5/29/16 8:26 AM	None Detected	ND
B-E-F05-151	Basement East Outside Kitchen Lunchroom	5/29/16 8:28 AM	None Detected	ND
B-E-F05-152	Basement East Outside Kitchen Lunchroom	5/29/16 8:28 AM	None Detected	ND
B-E-F05-153	Basement East Outside Kitchen Lunchroom	5/29/16 8:28 AM	None Detected	ND
B-E-F05-154	Basement East Outside Kitchen Lunchroom	5/29/16 8:28 AM	None Detected	ND
B-E-F05-155	Basement East Outside Kitchen Lunchroom	5/29/16 8:28 AM	None Detected	ND
B-E-F06-156	Basement East Outside Kitchen Lunchroom	5/29/16 8:30 AM	None Detected	ND
B-E-F06-157	Basement East Outside Kitchen Lunchroom	5/29/16 8:30 AM	None Detected	ND
B-E-F06-158	Basement East Outside Kitchen Lunchroom	5/29/16 8:30 AM	None Detected	ND
B-E-F06-159	Basement East Outside Kitchen Lunchroom	5/29/16 8:30 AM	None Detected	ND
B-E-F06-160	Basement East Outside Kitchen Lunchroom	5/29/16 8:30 AM	None Detected	ND
B-E-F07-161	Basement Outside Kitchen	5/29/16 8:33 AM	None Detected	ND
B-E-F07-162	Basement Outside Kitchen	5/29/16 8:33 AM	None Detected	ND
B-E-F07-163	Basement Outside Kitchen	5/29/16 8:33 AM	0.689	BA
B-E-F07-164	Basement Outside Kitchen	5/29/16 8:33 AM	0.745	BA
B-E-F07-165	Basement Outside Kitchen	5/29/16 8:33 AM	0.703	BA
B-E-F08-166	Basement Outside Kitchen	5/29/16 8:35 AM	0.709	BA
B-E-F08-167	Basement Outside Kitchen	5/29/16 8:35 AM	0.676	BA
B-E-F08-168	Basement Outside Kitchen	5/29/16 8:35 AM	0.724	BA
B-E-F08-169	Basement Outside Kitchen	5/29/16 8:35 AM	0.980	BA
B-E-F08-170	Basement Outside Kitchen	5/29/16 8:35 AM	0.176	BA
B-S-C001-171	Kitchen	5/29/16 8:37 AM	0.126	BA
B-S-C001-172	Kitchen	5/29/16 8:37 AM	<0.120	BA
B-S-C001-173	Kitchen	5/29/16 8:37 AM	<0.120	BA
B-S-C001-174	Kitchen	5/29/16 8:37 AM	<0.120	BA
B-S-C001-175	Kitchen	5/29/16 8:37 AM	<0.120	BA
B-S-C002-176	Kitchen	5/29/16 8:39 AM	0.212	BA
B-S-C002-177	Kitchen	5/29/16 8:39 AM	<0.120	BA
B-S-C002-178	Kitchen	5/29/16 8:39 AM	<0.120	BA
B-S-C002-179	Kitchen	5/29/16 8:39 AM	<0.120	BA
B-S-C002-180	Kitchen	5/29/16 8:39 AM	<0.120	BA

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

**SPREADSHEET LEGEND**

ND-Not Detected at the Reporting Limit

BA-Below EPA Action Level of 15 ppb

AA-Above EPA Action Level