



School Lead Water Testing - Data Collection Form

School Short Name **Burroughs**

Length of time water remained in pipes before sampled (hours) **8.5 hrs**

Facility ID **22481**

Report based on lab results dated

Date of test **05/24/16**

Water last used (Time and date) **5/23/16 10pm**

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
1-SW-CS01-01	Kitchen/Lunch	5/24/16 6:28 AM	0.707	BA
1-SW-CS01-02	Kitchen/Lunch	5/24/16 6:28 AM	0.698	BA
1-SW-CS01-03	Kitchen/Lunch	5/24/16 6:28 AM	0.679	BA
1-SW-CS01-04	Kitchen/Lunch	5/24/16 6:28 AM	0.678	BA
1-SW-CS01-05	Kitchen/Lunch	5/24/16 6:28 AM	0.684	BA
1-S-F01-06	1st Floor Corridor	5/24/16 6:40 AM	1.14	BA
1-S-F01-07	1st Floor Corridor	5/24/16 6:40 AM	0.863	BA
1-S-F01-08	1st Floor Corridor	5/24/16 6:40 AM	0.544	BA
1-S-F01-09	1st Floor Corridor	5/24/16 6:40 AM	0.456	BA
1-S-F01-10	1st Floor Corridor	5/24/16 6:40 AM	0.413	BA
2-S-F01-11	2nd Floor Corridor	5/24/16 6:54 AM	1.84	BA
2-S-F01-12	2nd Floor Corridor	5/24/16 6:54 AM	1.16	BA
2-S-F01-13	2nd Floor Corridor	5/24/16 6:54 AM	0.991	BA
2-S-F01-14	2nd Floor Corridor	5/24/16 6:54 AM	0.930	BA
2-S-F01-15	2nd Floor Corridor	5/24/16 6:54 AM	0.929	BA
2-N-F01-16	2nd Floor Corridor	5/24/16 6:57 AM	0.995	BA
2-N-F01-17	2nd Floor Corridor	5/24/16 6:57 AM	0.804	BA
2-N-F01-18	2nd Floor Corridor	5/24/16 6:57 AM	0.788	BA
2-N-F01-19	2nd Floor Corridor	5/24/16 6:57 AM	0.702	BA
2-N-F01-20	2nd Floor Corridor	5/24/16 6:57 AM	0.684	BA
B-S-F01-21	Basement S. Corridor	5/24/16 7:06 AM	1.72	BA
B-S-F01-22	Basement S. Corridor	5/24/16 7:06 AM	1.65	BA
B-S-F01-23	Basement S. Corridor	5/24/16 7:06 AM	1.16	BA
B-S-F01-24	Basement S. Corridor	5/24/16 7:06 AM	1.26	BA
B-S-F01-25	Basement S. Corridor	5/24/16 7:06 AM	1.35	BA
B-S-F02-26	Basement S. Corridor	5/24/16 7:10 AM	2.17	BA
B-S-F02-27	Basement S. Corridor	5/24/16 7:10 AM	1.88	BA
B-S-F02-28	Basement S. Corridor	5/24/16 7:10 AM	1.79	BA
B-S-F02-29	Basement S. Corridor	5/24/16 7:10 AM	1.69	BA
B-S-F02-30	Basement S. Corridor	5/24/16 7:10 AM	1.84	BA
B-NE-F01-31	Basement N. Corridor	5/24/16 7:16 AM	0.895	BA
B-NE-F01-32	Basement N. Corridor	5/24/16 7:16 AM	0.937	BA

B-NE-F01-33	Basement N. Corridor	5/24/16 7:16 AM	1.03	BA
B-NE-F01-34	Basement N. Corridor	5/24/16 7:16 AM	1.08	BA
B-NE-F01-35	Basement N. Corridor	5/24/16 7:16 AM	1.11	BA
M-SE-WC01-36	Modular Building Hallway	5/24/16 7:31 AM	0.249	BA
M-SE-WC01-37	Modular Building Hallway	5/24/16 7:31 AM	<0.120	BA
M-SE-WC01-38	Modular Building Hallway	5/24/16 7:31 AM	<0.120	BA
M-SE-WC01-39	Modular Building Hallway	5/24/16 7:31 AM	<0.120	BA
M-SE-WC01-40	Modular Building Hallway	5/24/16 7:31 AM	<0.120	BA
M-SE-WC02-41	Modular Building Hallway	5/24/16 7:31 AM	<0.120	BA
M-SE-WC02-42	Modular Building Hallway	5/24/16 7:31 AM	<0.120	BA
M-SE-WC02-43	Modular Building Hallway	5/24/16 7:31 AM	<0.120	BA
M-SE-WC02-44	Modular Building Hallway	5/24/16 7:31 AM	<0.120	BA
M-SE-WC02-45	Modular Building Hallway	5/24/16 7:31 AM	<0.120	BA

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit

BA-Below EPA Action Level of 15 ppb

AA-Above EPA Action Level