



School Lead Water Testing Summary

School Short Name [Mays](#)
Address [6656 S Normal](#)
Facility ID [51389](#)
CPS Team Member [Craig Edgerley](#)
MEC Team Member [Evan Christian](#)

Length of time water remained in pipes before sampled [Approx 9 hours](#)
Water last used (Time and date) [Approx 10 PM 5/4/16](#)
Date of test [5/5/2016](#)
Report based on lab results dated [5/10/2016](#)

Sample ID #	Sample Location	Sample Collection Time & Date	Test Results (ppb)	ppb Level
51389-1-N-CS-01	Kitchen	6:02 AM 5/5/16	ND	-
51389-1-N-F-02	Hallway by Main Office	6:04 AM 5/5/16	ND	-
51389-1-C-F-03	Hallway by Room 102	6:06 AM 5/5/16	ND	-
51389-2-W-F-04	Hallway by Room 203	6:08 AM 5/5/16	ND	-
51389-3-W-F-05	Hallway by Room 303	6:11 AM 5/5/16	ND	-

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit
BA-Below EPA Action Level of 15 ppb
AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations