



School Lead Water Testing - Data Collection Form

School Short Name **Mayer**

Length of time water remained in pipes before sampled (hours) 13.00
Report based on lab results dated 6/8/16
Date of test 05/27/16
Water last used (Time and date) Approx 4 PM 5/26/16

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
51168-1-W-S01-001	1st Floor Kitchen, Sink	5/27/2016 5:00AM	0.838	BA
51168-1-W-S01-002	1st Floor Kitchen, Sink	5/27/2016 5:00AM	0.644	BA
51168-1-W-S01-003	1st Floor Kitchen, Sink	5/27/2016 5:00AM	0.589	BA
51168-1-W-S01-004	1st Floor Kitchen, Sink	5/27/2016 5:00AM	0.844	BA
51168-1-W-S01-005	1st Floor Kitchen, Sink	5/27/2016 5:00AM	0.803	BA
51168-1-N-S02-001	1st Floor Room 101, Sink	5/27/2016 5:00AM	0.49	BA
51168-1-N-S02-002	1st Floor Room 101, Sink	5/27/2016 5:00AM	0.608	BA
51168-1-N-S02-003	1st Floor Room 101, Sink	5/27/2016 5:00AM	0.549	BA
51168-1-N-S02-004	1st Floor Room 101, Sink	5/27/2016 5:00AM	0.597	BA
51168-1-N-S02-005	1st Floor Room 101, Sink	5/27/2016 5:00AM	0.46	BA
51168-1-S-S03-001	1st Floor Room 102, Sink	5/27/2016 5:00AM	1.09	BA
51168-1-S-S03-002	1st Floor Room 102, Sink	5/27/2016 5:00AM	1.12	BA
51168-1-S-S03-003	1st Floor Room 102, Sink	5/27/2016 5:00AM	1.2	BA
51168-1-S-S03-004	1st Floor Room 102, Sink	5/27/2016 5:00AM	1.3	BA
51168-1-S-S03-005	1st Floor Room 102, Sink	5/27/2016 5:00AM	1.35	BA
51168-1-N-F04-001	1st Floor Across Room 101, Fountain	5/27/2016 5:00AM	0.456	BA
51168-1-N-F04-002	1st Floor Across Room 101, Fountain	5/27/2016 5:00AM	0.458	BA
51168-1-N-F04-003	1st Floor Across Room 101, Fountain	5/27/2016 5:00AM	0.472	BA
51168-1-N-F04-004	1st Floor Across Room 101, Fountain	5/27/2016 5:00AM	0.454	BA
51168-1-N-F04-005	1st Floor Across Room 101, Fountain	5/27/2016 5:00AM	0.454	BA
51168-1-S-S05-001	1st Floor Room 105, Sink	5/27/2016 5:00AM	0.657	BA
51168-1-S-S05-002	1st Floor Room 105, Sink	5/27/2016 5:00AM	0.544	BA
51168-1-S-S05-003	1st Floor Room 105, Sink	5/27/2016 5:00AM	0.562	BA
51168-1-S-S05-004	1st Floor Room 105, Sink	5/27/2016 5:00AM	0.62	BA
51168-1-S-S05-005	1st Floor Room 105, Sink	5/27/2016 5:00AM	0.347	BA
51168-1-S-S06-001	1st Floor Room 104, Sink	5/27/2016 5:00AM	0.573	BA
51168-1-S-S06-002	1st Floor Room 104, Sink	5/27/2016 5:00AM	0.575	BA
51168-1-S-S06-003	1st Floor Room 104, Sink	5/27/2016 5:00AM	0.627	BA
51168-1-S-S06-004	1st Floor Room 104, Sink	5/27/2016 5:00AM	0.513	BA
51168-1-S-S06-005	1st Floor Room 104, Sink	5/27/2016 5:00AM	0.57	BA
51168-1-S-S07-001	1st Floor Room 106, Sink	5/27/2016 5:00AM	4.65	BA
51168-1-S-S07-002	1st Floor Room 106, Sink	5/27/2016 5:00AM	2.3	BA
51168-1-S-S07-003	1st Floor Room 106, Sink	5/27/2016 5:00AM	1.74	BA
51168-1-S-S07-004	1st Floor Room 106, Sink	5/27/2016 5:00AM	1.53	BA
51168-1-S-S07-005	1st Floor Room 106, Sink	5/27/2016 5:00AM	1.73	BA
51168-1-N-F08-001	1st Floor Next To Room 106, Fountain	5/27/2016 5:00AM	0.217	BA
51168-1-N-F08-002	1st Floor Next To Room 106, Fountain	5/27/2016 5:00AM	0.327	BA
51168-1-N-F08-003	1st Floor Next To Room 106, Fountain	5/27/2016 5:00AM	0.296	BA
51168-1-N-F08-004	1st Floor Next To Room 106, Fountain	5/27/2016 5:00AM	0.292	BA
51168-1-N-F08-005	1st Floor Next To Room 106, Fountain	5/27/2016 5:00AM	0.29	BA
51168-1-W-S09-001	1st Floor Room 107, Sink	5/27/2016 5:00AM	0.434	BA
51168-1-W-S09-002	1st Floor Room 107, Sink	5/27/2016 5:00AM	0.157	BA
51168-1-W-S09-003	1st Floor Room 107, Sink	5/27/2016 5:00AM	0.168	BA
51168-1-W-S09-004	1st Floor Room 107, Sink	5/27/2016 5:00AM	<0.120	ND
51168-1-W-S09-005	1st Floor Room 107, Sink	5/27/2016 5:00AM	<0.120	ND
51168-1-W-F10-001	1st Floor Room 107, Fountain	5/27/2016 5:00AM	<0.120	ND
51168-1-W-F10-002	1st Floor Room 107, Fountain	5/27/2016 5:00AM	<0.120	ND
51168-1-W-F10-003	1st Floor Room 107, Fountain	5/27/2016 5:00AM	<0.120	ND
51168-1-W-F10-004	1st Floor Room 107, Fountain	5/27/2016 5:00AM	<0.120	ND
51168-1-W-F10-005	1st Floor Room 107, Fountain	5/27/2016 5:00AM	<0.120	ND
51168-1-W-S11-001	1st Floor Room 109, Sink	5/27/2016 5:00AM	0.177	BA
51168-1-W-S11-002	1st Floor Room 109, Sink	5/27/2016 5:00AM	0.131	BA
51168-1-W-S11-003	1st Floor Room 109, Sink	5/27/2016 5:00AM	0.337	BA
51168-1-W-S11-004	1st Floor Room 109, Sink	5/27/2016 5:00AM	0.247	BA
51168-1-W-S11-005	1st Floor Room 109, Sink	5/27/2016 5:00AM	0.258	BA
51168-1-W-S12-001	1st Floor Room 111, Sink	5/27/2016 5:00AM	0.258	BA
51168-1-W-S12-002	1st Floor Room 111, Sink	5/27/2016 5:00AM	<0.120	ND
51168-1-W-S12-003	1st Floor Room 111, Sink	5/27/2016 5:00AM	0.226	BA
51168-1-W-S12-004	1st Floor Room 111, Sink	5/27/2016 5:00AM	0.52	BA
51168-1-W-S12-005	1st Floor Room 111, Sink	5/27/2016 5:00AM	0.619	BA
51168-1-E-F13-001	1st Floor Room 108, Fountain	5/27/2016 5:00AM	0.508	BA
51168-1-E-F13-002	1st Floor Room 108, Fountain	5/27/2016 5:00AM	0.533	BA
51168-1-E-F13-003	1st Floor Room 108, Fountain	5/27/2016 5:00AM	0.326	BA
51168-1-E-F13-004	1st Floor Room 108, Fountain	5/27/2016 5:00AM	0.286	BA
51168-1-E-F13-005	1st Floor Room 108, Fountain	5/27/2016 5:00AM	0.238	BA
51168-1-S-F14-001	1st Floor Across Room 125, Fountain	5/27/2016 5:00AM	2.59	BA
51168-1-S-F14-002	1st Floor Across Room 125, Fountain	5/27/2016 5:00AM	0.725	BA
51168-1-S-F14-003	1st Floor Across Room 125, Fountain	5/27/2016 5:00AM	0.399	BA
51168-1-S-F14-004	1st Floor Across Room 125, Fountain	5/27/2016 5:00AM	0.531	BA
51168-1-S-F14-005	1st Floor Across Room 125, Fountain	5/27/2016 5:00AM	0.274	BA
51168-1-E-F15-001	1st Floor By North Entrance, Fountain	5/27/2016 5:00AM	0.845	BA
51168-1-E-F15-002	1st Floor By North Entrance, Fountain	5/27/2016 5:00AM	0.548	BA
51168-1-E-F15-003	1st Floor By North Entrance, Fountain	5/27/2016 5:00AM	0.161	BA
51168-1-E-F15-004	1st Floor By North Entrance, Fountain	5/27/2016 5:00AM	<0.120	ND
51168-1-E-F15-005	1st Floor By North Entrance, Fountain	5/27/2016 5:00AM	<0.120	ND
51168-2-N-F01-001	2nd Floor By Room 206, Fountain	5/27/2016 5:00AM	0.267	BA
51168-2-N-F01-002	2nd Floor By Room 206, Fountain	5/27/2016 5:00AM	0.404	BA
51168-2-N-F01-003	2nd Floor By Room 206, Fountain	5/27/2016 5:00AM	0.403	BA
51168-2-N-F01-004	2nd Floor By Room 206, Fountain	5/27/2016 5:00AM	0.408	BA
51168-2-N-F01-005	2nd Floor By Room 206, Fountain	5/27/2016 5:00AM	0.387	BA
51168-2-E-F02-001	2nd Floor Across Room 210, Fountain	5/27/2016 5:00AM	0.289	BA
51168-2-E-F02-002	2nd Floor Across Room 210, Fountain	5/27/2016 5:00AM	0.454	BA
51168-2-E-F02-003	2nd Floor Across Room 210, Fountain	5/27/2016 5:00AM	0.43	BA
51168-2-E-F02-004	2nd Floor Across Room 210, Fountain	5/27/2016 5:00AM	0.396	BA
51168-2-E-F02-005	2nd Floor Across Room 210, Fountain	5/27/2016 5:00AM	0.362	BA
51168-2-S-F03-001	2nd Floor Across Room 221, Fountain	5/27/2016 5:00AM	<0.120	ND
51168-2-S-F03-002	2nd Floor Across Room 221, Fountain	5/27/2016 5:00AM	<0.120	ND
51168-2-S-F03-003	2nd Floor Across Room 221, Fountain	5/27/2016 5:00AM	0.139	BA
51168-2-S-F03-004	2nd Floor Across Room 221, Fountain	5/27/2016 5:00AM	0.191	BA
51168-2-S-F03-005	2nd Floor Across Room 221, Fountain	5/27/2016 5:00AM	0.182	BA

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit
BA-Below EPA Action Level of 15 ppb
AA-Above EPA Action Level