



School Lead Water Testing - Data Collection Form

School Short Name **Noble- UIC**
 Date of test **10/29/16**

School Short Name	Facility ID	Sample ID #	Sample Location	Sample Collection Date	Sample Collection Time	Test Result (ppb)	Test Results
Noble- UIC	51235	51235-1-KIT-KS01-001	North Wall Kitchen Sink	10/29/16	0600	0.44	BA
Noble- UIC	51235	51235-1-KIT-KS01-002	North Wall Kitchen Sink	10/29/16	0600	0.182	BA
Noble- UIC	51235	51235-1-KIT-KS01-003	North Wall Kitchen Sink	10/29/16	0600	0.172	BA
Noble- UIC	51235	51235-1-KIT-KS01-004	North Wall Kitchen Sink	10/29/16	0600	0.154	BA
Noble- UIC	51235	51235-1-KIT-KS01-005	North Wall Kitchen Sink	10/29/16	0600	0.221	BA
Noble- UIC	51235	51235-1-KIT-KS02-001	East Wall Kitchen Sink	10/29/16	0600	0.902	BA
Noble- UIC	51235	51235-1-KIT-KS02-002	East Wall Kitchen Sink	10/29/16	0600	0.25	BA
Noble- UIC	51235	51235-1-KIT-KS02-003	East Wall Kitchen Sink	10/29/16	0600	0.17	BA
Noble- UIC	51235	51235-1-KIT-KS02-004	East Wall Kitchen Sink	10/29/16	0600	0.538	BA
Noble- UIC	51235	51235-1-KIT-KS02-005	East Wall Kitchen Sink	10/29/16	0600	1.15	BA
Noble- UIC	51235	51235-1-HAL-F03-001	Across From 110 Left Fountain	10/29/16	0600	0.16	BA
Noble- UIC	51235	51235-1-HAL-F03-002	Across From 110 Left Fountain	10/29/16	0600	0.343	BA
Noble- UIC	51235	51235-1-HAL-F03-003	Across From 110 Left Fountain	10/29/16	0600	0.601	BA
Noble- UIC	51235	51235-1-HAL-F03-004	Across From 110 Left Fountain	10/29/16	0600	0.625	BA
Noble- UIC	51235	51235-1-HAL-F03-005	Across From 110 Left Fountain	10/29/16	0600	0.586	BA
Noble- UIC	51235	51235-1-HAL-F04-001	Across From 110 Center Fountain	10/29/16	0600	0.431	BA
Noble- UIC	51235	51235-1-HAL-F04-002	Across From 110 Center Fountain	10/29/16	0600	0.495	BA
Noble- UIC	51235	51235-1-HAL-F04-003	Across From 110 Center Fountain	10/29/16	0600	0.405	BA
Noble- UIC	51235	51235-1-HAL-F04-004	Across From 110 Center Fountain	10/29/16	0600	0.388	BA
Noble- UIC	51235	51235-1-HAL-F04-005	Across From 110 Center Fountain	10/29/16	0600	0.362	BA
Noble- UIC	51235	51235-1-HAL-F05-001	Across From 110 Right Fountain	10/29/16	0600	0.247	BA
Noble- UIC	51235	51235-1-HAL-F05-002	Across From 110 Right Fountain	10/29/16	0600	0.295	BA
Noble- UIC	51235	51235-1-HAL-F05-003	Across From 110 Right Fountain	10/29/16	0600	0.317	BA
Noble- UIC	51235	51235-1-HAL-F05-004	Across From 110 Right Fountain	10/29/16	0600	0.235	BA
Noble- UIC	51235	51235-1-HAL-F05-005	Across From 110 Right Fountain	10/29/16	0600	0.202	BA
Noble- UIC	51235	51235-1-HAL-F06-001	Across From Room 104 Fountain	10/29/16	0600	0.629	BA
Noble- UIC	51235	51235-1-HAL-F06-002	Across From Room 104 Fountain	10/29/16	0600	0.722	BA
Noble- UIC	51235	51235-1-HAL-F06-003	Across From Room 104 Fountain	10/29/16	0600	0.74	BA
Noble- UIC	51235	51235-1-HAL-F06-004	Across From Room 104 Fountain	10/29/16	0600	0.607	BA
Noble- UIC	51235	51235-1-HAL-F06-005	Across From Room 104 Fountain	10/29/16	0600	0.588	BA
Noble- UIC	51235	51235-2-HAL-F01-001	Near Room 207 Fountain	10/29/16	0600	0.912	BA
Noble- UIC	51235	51235-2-HAL-F01-002	Near Room 207 Fountain	10/29/16	0600	1.31	BA
Noble- UIC	51235	51235-2-HAL-F01-003	Near Room 207 Fountain	10/29/16	0600	1.11	BA
Noble- UIC	51235	51235-2-HAL-F01-004	Near Room 207 Fountain	10/29/16	0600	0.91	BA
Noble- UIC	51235	51235-2-HAL-F01-005	Near Room 207 Fountain	10/29/16	0600	0.822	BA
Noble- UIC	51235	51235-2-HAL-F02-001	Near Room 210 Left Fountain	10/29/16	0600	0.246	BA
Noble- UIC	51235	51235-2-HAL-F02-002	Near Room 210 Left Fountain	10/29/16	0600	<0.120	ND
Noble- UIC	51235	51235-2-HAL-F02-003	Near Room 210 Left Fountain	10/29/16	0600	<0.120	ND
Noble- UIC	51235	51235-2-HAL-F02-004	Near Room 210 Left Fountain	10/29/16	0600	<0.120	ND
Noble- UIC	51235	51235-2-HAL-F02-005	Near Room 210 Left Fountain	10/29/16	0600	<0.120	ND
Noble- UIC	51235	51235-2-HAL-F03-001	Near Room 210 Right Fountain	10/29/16	0600	<0.120	ND
Noble- UIC	51235	51235-2-HAL-F03-002	Near Room 210 Right Fountain	10/29/16	0600	<0.120	ND
Noble- UIC	51235	51235-2-HAL-F03-003	Near Room 210 Right Fountain	10/29/16	0600	<0.120	ND
Noble- UIC	51235	51235-2-HAL-F03-004	Near Room 210 Right Fountain	10/29/16	0600	<0.120	ND

Noble- UIC	51235	51235-2-HAL-F03-005	Near Room 210 Right Fountain	10/29/16	0600	<0.120	ND
Noble- UIC	51235	51235-2-HAL-F04-001	Near Room 216 Fountain	10/29/16	0600	3.53	BA
Noble- UIC	51235	51235-2-HAL-F04-002	Near Room 216 Fountain	10/29/16	0600	1.56	BA
Noble- UIC	51235	51235-2-HAL-F04-003	Near Room 216 Fountain	10/29/16	0600	1.42	BA
Noble- UIC	51235	51235-2-HAL-F04-004	Near Room 216 Fountain	10/29/16	0600	1.41	BA
Noble- UIC	51235	51235-2-HAL-F04-005	Near Room 216 Fountain	10/29/16	0600	1.31	BA
Noble- UIC	51235	51235-2-203-S05-001	Inside Room 203 South Wall Sink	10/29/16	0600	0.559	BA
Noble- UIC	51235	51235-2-203-S05-002	Inside Room 203 South Wall Sink	10/29/16	0600	0.345	BA
Noble- UIC	51235	51235-2-203-S05-003	Inside Room 203 South Wall Sink	10/29/16	0600	0.898	BA
Noble- UIC	51235	51235-2-203-S05-004	Inside Room 203 South Wall Sink	10/29/16	0600	0.862	BA
Noble- UIC	51235	51235-2-203-S05-005	Inside Room 203 South Wall Sink	10/29/16	0600	1.24	BA
Noble- UIC	51235	51235-2-203-WC06-001	Inside Room 203 West Wall Fountain	10/29/16	0600	<0.120	ND
Noble- UIC	51235	51235-2-203-WC06-002	Inside Room 203 West Wall Fountain	10/29/16	0600	<0.120	ND
Noble- UIC	51235	51235-2-203-WC06-003	Inside Room 203 West Wall Fountain	10/29/16	0600	<0.120	ND
Noble- UIC	51235	51235-2-203-WC06-004	Inside Room 203 West Wall Fountain	10/29/16	0600	<0.120	ND
Noble- UIC	51235	51235-2-203-WC06-005	Inside Room 203 West Wall Fountain	10/29/16	0600	<0.120	ND
Noble- UIC	51235	51235-3-HAL-F01-001	Near Room 307 Fountain	10/29/16	0600	0.787	BA
Noble- UIC	51235	51235-3-HAL-F01-002	Near Room 307 Fountain	10/29/16	0600	0.891	BA
Noble- UIC	51235	51235-3-HAL-F01-003	Near Room 307 Fountain	10/29/16	0600	0.793	BA
Noble- UIC	51235	51235-3-HAL-F01-004	Near Room 307 Fountain	10/29/16	0600	1.04	BA
Noble- UIC	51235	51235-3-HAL-F01-005	Near Room 307 Fountain	10/29/16	0600	1.18	BA
Noble- UIC	51235	51235-3-HAL-F02-001	Near Room 309 Left Fountain	10/29/16	0600	0.407	BA
Noble- UIC	51235	51235-3-HAL-F02-002	Near Room 309 Left Fountain	10/29/16	0600	0.777	BA
Noble- UIC	51235	51235-3-HAL-F02-003	Near Room 309 Left Fountain	10/29/16	0600	0.576	BA
Noble- UIC	51235	51235-3-HAL-F02-004	Near Room 309 Left Fountain	10/29/16	0600	0.468	BA
Noble- UIC	51235	51235-3-HAL-F02-005	Near Room 309 Left Fountain	10/29/16	0600	0.454	BA
Noble- UIC	51235	51235-3-HAL-F03-001	Near Room 309 Right Fountain	10/29/16	0600	0.461	BA
Noble- UIC	51235	51235-3-HAL-F03-002	Near Room 309 Right Fountain	10/29/16	0600	0.459	BA
Noble- UIC	51235	51235-3-HAL-F03-003	Near Room 309 Right Fountain	10/29/16	0600	0.295	BA
Noble- UIC	51235	51235-3-HAL-F03-004	Near Room 309 Right Fountain	10/29/16	0600	0.301	BA
Noble- UIC	51235	51235-3-HAL-F03-005	Near Room 309 Right Fountain	10/29/16	0600	0.152	BA
Noble- UIC	51235	51235-3-HAL-F04-001	Near Room 318 Fountain	10/29/16	0600	4.69	BA
Noble- UIC	51235	51235-3-HAL-F04-002	Near Room 318 Fountain	10/29/16	0600	2.15	BA
Noble- UIC	51235	51235-3-HAL-F04-003	Near Room 318 Fountain	10/29/16	0600	1.84	BA
Noble- UIC	51235	51235-3-HAL-F04-004	Near Room 318 Fountain	10/29/16	0600	1.69	BA
Noble- UIC	51235	51235-3-HAL-F04-005	Near Room 318 Fountain	10/29/16	0600	1.58	BA
Noble- UIC	51235	51235-4-HAL-F01-001	Near Room 407 Fountain	10/29/16	0600	0.935	BA
Noble- UIC	51235	51235-4-HAL-F01-002	Near Room 407 Fountain	10/29/16	0600	1.07	BA
Noble- UIC	51235	51235-4-HAL-F01-003	Near Room 407 Fountain	10/29/16	0600	1.13	BA
Noble- UIC	51235	51235-4-HAL-F01-004	Near Room 407 Fountain	10/29/16	0600	1.05	BA
Noble- UIC	51235	51235-4-HAL-F01-005	Near Room 407 Fountain	10/29/16	0600	0.936	BA

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit
BA-Below EPA Action Level of 15 ppb
AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations