



## School Lead Water Testing Summary

**School Short Name** **Stagg**  
**Address** 7424 S Morgan  
**Facility ID** 51395  
**CPS Team Member** Prins Sales  
**MEC Team Member** Ian Campoli

**Length of time water remained in pipes before sampled** [Approx 9 hours](#)  
**Water last used (Time and date)** [Approx 10 PM 5/3/16](#)  
**Date of test** [5/4/2016](#)  
**Report based on lab results dated** [5/13/2016, 5/18/2016](#)

Sample ID #	Sample Location	Sample Collection Time & Date	Test Results (ppb)	ppb Level
51395-1-CS-CS-01	Kitchen	6:10 AM 5/4/16	ND	-
51395-1-S-F-02	Hallway by Lunchroom	6:13 AM 5/4/16	ND	-
51395-1-S-F-03	Hallway by Room 112	6:15 AM 5/4/16	ND	-
51395-1-C-F-04	Room 106	6:18 AM 5/4/16	ND	-
51395-1-C-F-05	Hallway by Room 105	6:20 AM 5/4/16	ND	-
51395-1-N-F-06	Hallway by Room 101	6:25 AM 5/4/16	ND	-
51395-2-C-F-07	Hallway by Room 205	6:28 AM 5/4/16	ND	-
51395-3-C-F-08	Hallway by Room 309	6:31 AM 5/4/16	ND	-

**EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L**

### SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit  
BA-Below EPA Action Level of 15 ppb  
AA-Above EPA Action Level

**Chicago Public Schools - Department of Facility Operations**