



School Lead Water Testing - Data Collection Form

School Short Name **Beasley**
Address 5255 S. State Street

Length of time water remained in pipes before sampled (hours) 13.00
Report based on lab results dated 6/7/16
Date of test 05/25/16
Water last used (Time and date) Approx 4 PM 5/24/16

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
29321-1-N-S01-001	Kitchen Prep-Sink	5/26/16 5:00 AM	2.34	BA
29321-1-N-S01-002	Kitchen Prep-Sink	5/26/16 5:00 AM	2.36	BA
29321-1-N-S01-003	Kitchen Prep-Sink	5/26/16 5:00 AM	0.809	BA
29321-1-N-S01-004	Kitchen Prep-Sink	5/26/16 5:00 AM	0.975	BA
29321-1-N-S01-005	Kitchen Prep-Sink	5/26/16 5:00 AM	1.9	BA
29321-1-E-S03-001	Kitchen Wash Sink	5/26/16 5:00 AM	7.77	BA
29321-1-E-S03-002	Kitchen Wash Sink	5/26/16 5:00 AM	403	AA
29321-1-E-S03-003	Kitchen Wash Sink	5/26/16 5:00 AM	174	AA
29321-1-E-S03-004	Kitchen Wash Sink	5/26/16 5:00 AM	87.3	AA
29321-1-E-S03-005	Kitchen Wash Sink	5/26/16 5:00 AM	402	AA
29321-1-S-S04-001	Kitchen Soup Sink	5/26/16 5:00 AM	7.66	BA
29321-1-S-S04-002	Kitchen Soup Sink	5/26/16 5:00 AM	3.66	BA
29321-1-S-S04-003	Kitchen Soup Sink	5/26/16 5:00 AM	2.03	BA
29321-1-S-S04-004	Kitchen Soup Sink	5/26/16 5:00 AM	1.12	BA
29321-1-S-S04-005	Kitchen Soup Sink	5/26/16 5:00 AM	2.27	BA
29321-1-S-S05-001	Kitchen Dish Sink	5/26/16 5:00 AM	1.22	BA
29321-1-S-S05-002	Kitchen Dish Sink	5/26/16 5:00 AM	2.67	BA
29321-1-S-S05-003	Kitchen Dish Sink	5/26/16 5:00 AM	1.66	BA
29321-1-S-S05-004	Kitchen Dish Sink	5/26/16 5:00 AM	0.655	BA
29321-1-S-S05-005	Kitchen Dish Sink	5/26/16 5:00 AM	0.788	BA
29321-1-W-F06-001	South Fountain1 Outside Door 1	5/26/16 5:00 AM	<0.120	ND
29321-1-W-F06-002	South Fountain1 Outside Door 1	5/26/16 5:00 AM	<0.120	ND
29321-1-W-F06-003	South Fountain1 Outside Door 1	5/26/16 5:00 AM	0.132	BA
29321-1-W-F06-004	South Fountain1 Outside Door 1	5/26/16 5:00 AM	0.136	BA
29321-1-W-F06-005	South Fountain1 Outside Door 1	5/26/16 5:00 AM	<0.120	ND
29321-1-W-F07-001	Center Fountain 2 Outside Door 1	5/26/16 5:00 AM	0.142	BA
29321-1-W-F07-002	Center Fountain 2 Outside Door 1	5/26/16 5:00 AM	0.152	BA
29321-1-W-F07-003	Center Fountain 2 Outside Door 1	5/26/16 5:00 AM	0.157	BA
29321-1-W-F07-004	Center Fountain 2 Outside Door 1	5/26/16 5:00 AM	0.168	BA
29321-1-W-F07-005	Center Fountain 2 Outside Door 1	5/26/16 5:00 AM	0.144	BA
29321-1-W-F08-001	North Fountain 3 Outside Door 1	5/26/16 5:00 AM	<0.120	ND
29321-1-W-F08-002	North Fountain 3 Outside Door 1	5/26/16 5:00 AM	0.127	BA
29321-1-W-F08-003	North Fountain 3 Outside Door 1	5/26/16 5:00 AM	0.136	BA
29321-1-W-F08-004	North Fountain 3 Outside Door 1	5/26/16 5:00 AM	0.143	BA
29321-1-W-F08-005	North Fountain 3 Outside Door 1	5/26/16 5:00 AM	0.138	BA
29321-1-W-F09-001	Inside Main Office, Fountain	5/26/16 5:00 AM	3.23	BA
29321-1-W-F09-002	Inside Main Office, Fountain	5/26/16 5:00 AM	4.47	BA
29321-1-W-F09-003	Inside Main Office, Fountain	5/26/16 5:00 AM	6.53	BA
29321-1-W-F09-004	Inside Main Office, Fountain	5/26/16 5:00 AM	6.07	BA
29321-1-W-F09-005	Inside Main Office, Fountain	5/26/16 5:00 AM	3.78	BA
29321-1-W-S10-001	Inside Teachers Lounge, Sink	5/26/16 5:00 AM	4.87	BA
29321-1-W-S10-002	Inside Teachers Lounge, Sink	5/26/16 5:00 AM	5.11	BA
29321-1-W-S10-003	Inside Teachers Lounge, Sink	5/26/16 5:00 AM	2.24	BA
29321-1-W-S10-004	Inside Teachers Lounge, Sink	5/26/16 5:00 AM	1.7	BA
29321-1-W-S10-005	Inside Teachers Lounge, Sink	5/26/16 5:00 AM	2.35	BA
29321-1-N-F11-001	South Fountain 1 Outside Door 6	5/26/16 5:00 AM	2.98	BA
29321-1-N-F11-002	South Fountain 1 Outside Door 6	5/26/16 5:00 AM	0.922	BA
29321-1-N-F11-003	South Fountain 1 Outside Door 6	5/26/16 5:00 AM	0.393	BA
29321-1-N-F11-004	South Fountain 1 Outside Door 6	5/26/16 5:00 AM	0.539	BA
29321-1-N-F11-005	South Fountain 1 Outside Door 6	5/26/16 5:00 AM	0.346	BA
29321-1-N-F12-001	Center Fountain 2 Outside Door 6	5/26/16 5:00 AM	0.163	BA
29321-1-N-F12-002	Center Fountain 2 Outside Door 6	5/28/16 5:00 AM	0.2	BA

29321-1-N-F12-003	Center Fountain 2 Outside Door 6	5/26/16 5:00 AM	0.25	BA
29321-1-N-F12-004	Center Fountain 2 Outside Door 6	5/30/16 5:00 AM	0.238	BA
29321-1-N-F12-005	Center Fountain 2 Outside Door 6	5/26/16 5:00 AM	0.244	BA
29321-1-N-F13-001	North Fountain 3 Outside Door 6	5/26/16 5:00 AM	0.153	BA
29321-1-N-F13-002	North Fountain 3 Outside Door 6	5/26/16 5:00 AM	0.176	BA
29321-1-N-F13-003	North Fountain 3 Outside Door 6	5/26/16 5:00 AM	<0.120	ND
29321-1-N-F13-004	North Fountain 3 Outside Door 6	5/26/16 5:00 AM	<0.120	ND
29321-1-N-F13-05	North Fountain 3 Outside Door 6	5/26/16 5:00 AM	0.188	BA
29321-1-E-F14-001	Lunchroom Fountain 1	5/26/16 5:00 AM	0.422	BA
29321-1-E-F14-002	Lunchroom Fountain 1	5/26/16 5:00 AM	0.551	BA
29321-1-E-F14-003	Lunchroom Fountain 1	5/26/16 5:00 AM	0.74	BA
29321-1-E-F14-004	Lunchroom Fountain 1	5/26/16 5:00 AM	1.12	BA
29321-1-E-F14-005	Lunchroom Fountain 1	5/26/16 5:00 AM	1.24	BA
29321-1-E-F15-001	Lunchroom Fountain 2	5/26/16 5:00 AM	0.935	BA
29321-1-E-F15-002	Lunchroom Fountain 2	5/26/16 5:00 AM	0.994	BA
29321-1-E-F15-003	Lunchroom Fountain 2	5/26/16 5:00 AM	1.05	BA
29321-1-E-F15-004	Lunchroom Fountain 2	5/26/16 5:00 AM	1.04	BA
29321-1-E-F15-005	Lunchroom Fountain 2	5/26/16 5:00 AM	1.03	BA
29321-1-W-F16-001	Pool Area Fountain	5/26/16 5:00 AM	65.6	AA
29321-1-W-F16-002	Pool Area Fountain	5/26/16 5:00 AM	10	BA
29321-1-W-F16-003	Pool Area Fountain	5/26/16 5:00 AM	3.35	BA
29321-1-W-F16-004	Pool Area Fountain	5/26/16 5:00 AM	1.83	BA
29321-1-W-F16-005	Pool Area Fountain	5/26/16 5:00 AM	2.49	BA
29321-1-W-F17-001	Pool Area Boy's Bathroom Fountain	5/26/16 5:00 AM	0.858	BA
29321-1-W-F17-002	Pool Area Boy's Bathroom Fountain	5/26/16 5:00 AM	1.2	BA
29321-1-W-F17-003	Pool Area Boy's Bathroom Fountain	5/26/16 5:00 AM	1.64	BA
29321-1-W-F17-004	Pool Area Boy's Bathroom Fountain	5/26/16 5:00 AM	2.14	BA
29321-1-W-F17-005	Pool Area Boy's Bathroom Fountain	5/26/16 5:00 AM	2	BA
29321-2-N-F01-001	North Fountain 1 Outside Band Room	5/26/16 5:00 AM	0.151	BA
29321-2-N-F01-002	North Fountain 1 Outside Band Room	5/26/16 5:00 AM	0.176	BA
29321-2-N-F01-003	North Fountain 1 Outside Band Room	5/26/16 5:00 AM	0.532	BA
29321-2-N-F01-004	North Fountain 1 Outside Band Room	5/26/16 5:00 AM	0.735	BA
29321-2-N-F01-005	North Fountain 1 Outside Band Room	5/26/16 5:00 AM	0.971	BA
29321-2-N-F02-001	Center Fountain 2 Outside Band Room	5/26/16 5:00 AM	0.301	BA
29321-2-N-F02-002	Center Fountain 2 Outside Band Room	5/26/16 5:00 AM	0.183	BA
29321-2-N-F02-003	Center Fountain 2 Outside Band Room	5/26/16 5:00 AM	0.562	BA
29321-2-N-F02-004	Center Fountain 2 Outside Band Room	5/26/16 5:00 AM	0.706	BA
29321-2-N-F02-005	Center Fountain 2 Outside Band Room	5/26/16 5:00 AM	0.795	BA
29321-2-N-F03-001	South Fountain 3 Outside Band Room	5/26/16 5:00 AM	1.14	BA
29321-2-N-F03-002	South Fountain 3 Outside Band Room	5/26/16 5:00 AM	1.33	BA
29321-2-N-F03-003	South Fountain 3 Outside Band Room	5/26/16 5:00 AM	1.18	BA
29321-2-N-F03-004	South Fountain 3 Outside Band Room	5/26/16 5:00 AM	1.1	BA
29321-2-N-F03-005	South Fountain 3 Outside Band Room	5/26/16 5:00 AM	2.64	BA
29321-2-S-F04-001	North Fountain 1 Outside Room 236	5/26/16 5:00 AM	1.14	BA
29321-2-S-F04-002	North Fountain 1 Outside Room 236	5/26/16 5:00 AM	1.3	BA
29321-2-S-F04-003	North Fountain 1 Outside Room 236	5/26/16 5:00 AM	2.28	BA
29321-2-S-F04-004	North Fountain 1 Outside Room 236	5/26/16 5:00 AM	1.55	BA
29321-2-S-F04-005	North Fountain 1 Outside Room 236	5/26/16 5:00 AM	1.24	BA
29321-2-S-F05-001	Center Fountain 2 Outside Room 236	5/26/16 5:00 AM	0.53	BA
29321-2-S-F05-002	Center Fountain 2 Outside Room 236	5/26/16 5:00 AM	0.46	BA
29321-2-S-F05-003	Center Fountain 2 Outside Room 236	5/26/16 5:00 AM	0.233	BA
29321-2-S-F05-004	Center Fountain 2 Outside Room 236	5/26/16 5:00 AM	0.368	BA
29321-2-S-F05-005	Center Fountain 2 Outside Room 236	5/26/16 5:00 AM	0.147	BA
29321-2-S-F06-001	North Fountain 3 Outside Room 236	5/26/16 5:00 AM	0.305	BA
29321-2-S-F06-002	North Fountain 3 Outside Room 236	5/26/16 5:00 AM	0.183	BA
29321-2-S-F06-003	North Fountain 3 Outside Room 236	5/26/16 5:00 AM	0.132	BA
29321-2-S-F06-004	North Fountain 3 Outside Room 236	5/26/16 5:00 AM	0.41	BA
29321-2-S-F06-005	North Fountain 3 Outside Room 236	5/26/16 5:00 AM	0.455	BA
29321-2-S-S07-001	Inside Room 234 Sink 1	5/26/16 5:00 AM	950	AA
29321-2-S-S07-002	Inside Room 234 Sink 1	5/26/16 5:00 AM	965	AA
29321-2-S-S07-003	Inside Room 234 Sink 1	5/26/16 5:00 AM	214	AA
29321-2-S-S07-004	Inside Room 234 Sink 1	5/26/16 5:00 AM	140	AA
29321-2-S-S07-005	Inside Room 234 Sink 1	5/26/16 5:00 AM	64.4	AA
29321-2-S-S08-001	Inside Room 234 Sink 2	5/26/16 5:00 AM	9.04	BA
29321-2-S-S08-002	Inside Room 234 Sink 2	5/26/16 5:00 AM	24.8	AA
29321-2-S-S08-003	Inside Room 234 Sink 2	5/26/16 5:00 AM	7.24	BA
29321-2-S-S08-004	Inside Room 234 Sink 2	5/26/16 5:00 AM	2.15	BA

29321-2-S-S08-005	Inside Room 234 Sink 2	5/26/16 5:00 AM	2.33	BA
29321-1-N-S01-001	Annex Inside Parent Room, Sink	5/26/16 5:00 AM	1.29	BA
29321-1-N-S01-002	Annex Inside Parent Room, Sink	5/26/16 5:00 AM	1.38	BA
29321-1-N-S01-003	Annex Inside Parent Room, Sink	5/26/16 5:00 AM	0.618	BA
29321-1-N-S01-004	Annex Inside Parent Room, Sink	5/26/16 5:00 AM	0.906	BA
29321-1-N-S01-005	Annex Inside Parent Room, Sink	5/26/16 5:00 AM	0.942	BA
29321-1-N-S02-001	Annex Kitchen, Sink	5/26/16 5:00 AM	1.22	BA
29321-1-N-S02-002	Annex Kitchen, Sink	5/26/16 5:00 AM	0.792	BA
29321-1-N-S02-003	Annex Kitchen, Sink	5/26/16 5:00 AM	0.708	BA
29321-1-N-S02-004	Annex Kitchen, Sink	5/26/16 5:00 AM	1.71	BA
29321-1-N-S02-005	Annex Kitchen, Sink	5/26/16 5:00 AM	1.61	BA
29321-1-N-F03-001	Annex Outside Parent Room Fountain 1	5/26/16 5:00 AM	1.2	BA
29321-1-N-F03-002	Annex Outside Parent Room Fountain 1	5/26/16 5:00 AM	0.613	BA
29321-1-N-F03-003	Annex Outside Parent Room Fountain 1	5/26/16 5:00 AM	0.202	BA
29321-1-N-F03-004	Annex Outside Parent Room Fountain 1	5/26/16 5:00 AM	0.528	BA
29321-1-N-F03-005	Annex Outside Parent Room Fountain 1	5/26/16 5:00 AM	0.545	BA
29321-1-N-F04-001	Annex Outside Parent Room Fountain 2	5/27/16 5:00 AM	1.42	BA
29321-1-N-F04-002	Annex Outside Parent Room Fountain 2	5/28/16 5:00 AM	1.28	BA
29321-1-N-F04-003	Annex Outside Parent Room Fountain 2	5/29/16 5:00 AM	0.837	BA
29321-1-N-F04-004	Annex Outside Parent Room Fountain 2	5/30/16 5:00 AM	1.43	BA
29321-1-N-F04-005	Annex Outside Parent Room Fountain 2	5/31/16 5:00 AM	1.5	BA
29321-1-W-S05-001	Annex Inside Room 5, Sink	5/31/16 5:00 AM	1.71	BA
29321-1-W-S05-002	Annex Inside Room 5, Sink	5/31/16 5:00 AM	1.34	BA
29321-1-W-S05-003	Annex Inside Room 5, Sink	5/31/16 5:00 AM	1.3	BA
29321-1-W-S05-004	Annex Inside Room 5, Sink	5/31/16 5:00 AM	1.36	BA
29321-1-W-S05-005	Annex Inside Room 5, Sink	5/31/16 5:00 AM	1.2	BA
29321-1-W-S06-001	Annex Inside Room 6, Sink	5/31/16 5:00 AM	1.64	BA
29321-1-W-S06-002	Annex Inside Room 6, Sink	5/31/16 5:00 AM	1.19	BA
29321-1-W-S06-003	Annex Inside Room 6, Sink	5/31/16 5:00 AM	1.3	BA
29321-1-W-S06-004	Annex Inside Room 6, Sink	5/31/16 5:00 AM	1.21	BA
29321-1-W-S06-005	Annex Inside Room 6, Sink	5/31/16 5:00 AM	1.22	BA
29321-1-W-S07-001	Annex Inside Room 4, Sink	5/31/16 5:00 AM	0.785	BA
29321-1-W-S07-002	Annex Inside Room 4, Sink	5/31/16 5:00 AM	0.833	BA
29321-1-W-S07-003	Annex Inside Room 4, Sink	5/31/16 5:00 AM	0.787	BA
29321-1-W-S07-004	Annex Inside Room 4, Sink	5/31/16 5:00 AM	0.486	BA
29321-1-W-S07-005	Annex Inside Room 4, Sink	5/31/16 5:00 AM	0.57	BA
29321-1-S-S08-001	Annex Inside Teachers Lounge, Sink	5/31/16 5:00 AM	1.07	BA
29321-1-S-S08-002	Annex Inside Teachers Lounge, Sink	5/31/16 5:00 AM	1.2	BA
29321-1-S-S08-003	Annex Inside Teachers Lounge, Sink	5/31/16 5:00 AM	1.16	BA
29321-1-S-S08-004	Annex Inside Teachers Lounge, Sink	5/31/16 5:00 AM	1.2	BA
29321-1-S-S08-005	Annex Inside Teachers Lounge, Sink	5/31/16 5:00 AM	1.28	BA
29321-1-E-S09-001	Annex Inside Room 2, Sink	5/31/16 5:00 AM	1.3	BA
29321-1-E-S09-002	Annex Inside Room 2, Sink	5/31/16 5:00 AM	0.97	BA
29321-1-E-S09-003	Annex Inside Room 2, Sink	5/31/16 5:00 AM	0.905	BA
29321-1-E-S09-004	Annex Inside Room 2, Sink	5/31/16 5:00 AM	0.982	BA
29321-1-E-S09-005	Annex Inside Room 2, Sink	5/31/16 5:00 AM	0.982	BA
29321-1-E-S10-001	Annex Inside Room 3, Sink	5/31/16 5:00 AM	1.38	BA
29321-1-E-S10-002	Annex Inside Room 3, Sink	5/31/16 5:00 AM	1.55	BA
29321-1-E-S10-003	Annex Inside Room 3, Sink	5/31/16 5:00 AM	1.51	BA
29321-1-E-S10-004	Annex Inside Room 3, Sink	5/31/16 5:00 AM	2.72	BA
29321-1-E-S10-005	Annex Inside Room 3, Sink	5/31/16 5:00 AM	4.82	BA
29321-1-E-S11-001	Annex Inside Room 1, Sink	5/31/16 5:00 AM	0.972	BA
29321-1-E-S11-002	Annex Inside Room 1, Sink	5/26/16 5:00 AM	0.985	BA
29321-1-E-S11-003	Annex Inside Room 1, Sink	5/26/16 5:00 AM	1.02	BA
29321-1-E-S11-004	Annex Inside Room 1, Sink	5/26/16 5:00 AM	0.921	BA
29321-1-E-S11-005	Annex Inside Room 1, Sink	5/26/16 5:00 AM	0.856	BA

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit

BA-Below EPA Action Level of 15 ppb

AA-Above EPA Action Level