



## School Lead Water Testing Summary

**School Short Name** **Pritzker**  
**Address** 2009 W. Schiller  
**Facility ID** 51149  
**CPS Team Member** Craig Edgerley  
**MEC Team Member** Evan Christian

**Length of time water remained in pipes before sampled** [Approx. 10 hours](#)  
**Water last used (Time and date)** [Approx 10 PM 5/2/16](#)  
**Date of test** [5/3/2016](#)  
**Report based on lab results dated** [5/10/2016](#)

Sample ID #	Sample Location	Sample Collection Time & Date	Test Results (ppb)	ppb Level
51149-1-K-CS-01	Kitchen	6:38 AM 5/3/16	ND	-
51149-1-C-WC-02	Hallway by Gymnasium	6:42 AM 5/3/16	ND	-
51149-1-E-WC-03	Hallway by Room 112	6:45 AM 5/3/16	ND	-
51149-2-C-WC-04	Hallway by Room 203	6:49 AM 5/3/16	ND	-
51149-3-C-WC-05	Hallway by Room 303	6:54 AM 5/3/16	ND	-

**EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L**

### SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit  
BA-Below EPA Action Level of 15 ppb  
AA-Above EPA Action Level

**Chicago Public Schools - Department of Facility Operations**