



School Lead Water Testing Summary

School Short Name [Lenart](#)
Address [8101 S LaSalle](#)
Facility ID [51392](#)
CPS Team Member [Prins Sales](#)
MEC Team Member [Ian Campoli](#)

Length of time water remained in pipes before sampled [Approx 9 hours](#)
Water last used (Time and date) [Approx 10 PM 5/3/16](#)
Date of test [5/4/2016](#)
Report based on lab results dated [5/13/2016, 5/18/2016](#)

Sample ID #	Sample Location	Sample Collection Time & Date	Test Results (ppb)	ppb Level
51392-1-S-CS-01	Kitchen	7:01 AM 5/4/16	ND	-
51392-1-S-F-02	Hallway by Room 110	7:03 AM 5/4/16	ND	-
51392-1-C-WC-03	Hallway by Boiler Room	7:07 AM 5/4/16	ND	-
51392-2-N-F-04	Hallway by Room 201	7:10 AM 5/4/16	ND	-
51392-2-S-F-05	Hallway by Room 216	7:15 AM 5/4/16	11.8	BA
51392-3-N-F-06	Hallway by Room 301	7:19 AM 5/4/16	5.72	BA

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit
 BA-Below EPA Action Level of 15 ppb
 AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations