



School Lead Water Testing Summary

School Short Name **Canty**
Address 3740 N Panama
Facility ID 51005
CPS Team Member Craig Edgerley
MEC Team Member Mark Wyco

Length of time water remained in pipes before sampled [Approx 9 hours](#)
Water last used (Time and date) [Approx 10 PM 5/9/16](#)
Date of test [05/10/16](#)
Report based on lab results dated [05/18/16](#)

Sample ID #	Sample Location	Sample Collection Time & Date	Test Results (ppb)	ppb Level
51002-1-N-CS-01	Kitchen	6:10 AM 5/10/16	ND	-
51002-1-NW-F-02	Hallway by Room 113	6:15 AM 5/10/16	ND	-
51002-2-S-F-03	Hallway by Room 203	6:20 AM 5/10/16	ND	-
51002-2-NW-F-04	Hallway by Room 213	6:25 AM 5/10/16	ND	-
51002-1-C-F-05	Hallway by Room 109	6:30 AM 5/10/16	ND	-

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit
BA-Below EPA Action Level of 15 ppb
AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations