



School Lead Water Testing - Data Collection Form

School Short Name Hibbard

Length of time water remained in pipes before sampled (hours) 1.4
Report based on lab results dated 5/16/16
Date of test 5/28/16
Water last used (Time and date) 5/27/2016 - 10PM

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
1-W-C801-01	Room 115	5/28/2016 - 12:40 PM	ND	ND
1-W-C801-02	Room 115	5/28/2016 - 12:40 PM	ND	ND
1-W-C801-03	Room 115	5/28/2016 - 12:40 PM	ND	ND
1-W-C801-04	Room 115	5/28/2016 - 12:40 PM	ND	ND
1-W-C801-05	Room 115	5/28/2016 - 12:40 PM	ND	ND
1-W-C802-06	Room 115	5/28/2016 - 12:52 PM	ND	ND
1-W-C802-07	Room 115	5/28/2016 - 12:52 PM	ND	ND
1-W-C802-08	Room 115	5/28/2016 - 12:52 PM	ND	ND
1-W-C802-09	Room 115	5/28/2016 - 12:52 PM	ND	ND
1-W-C802-10	Room 115	5/28/2016 - 12:52 PM	ND	ND
1-W-F01-11	Room 115	5/28/2016 - 1:00 PM	ND	ND
1-W-F01-12	Room 115	5/28/2016 - 1:00 PM	ND	ND
1-W-F01-13	Room 115	5/28/2016 - 1:00 PM	ND	ND
1-W-F01-14	Room 115	5/28/2016 - 1:00 PM	ND	ND
1-W-F01-15	Room 115	5/28/2016 - 1:00 PM	ND	ND
1-W-C801-16	Room 116	5/28/2016 - 1:20 PM	ND	ND
1-W-C801-17	Room 116	5/28/2016 - 1:20 PM	ND	ND
1-W-C801-18	Room 116	5/28/2016 - 1:20 PM	ND	ND
1-W-C801-19	Room 116	5/28/2016 - 1:20 PM	ND	ND
1-W-C801-20	Room 116	5/28/2016 - 1:20 PM	ND	ND
1-W-C802-21	Room 116	5/28/2016 - 1:23PM	ND	ND
1-W-C802-22	Room 116	5/28/2016 - 1:23PM	ND	ND
1-W-C802-23	Room 116	5/28/2016 - 1:23PM	ND	ND
1-W-C802-24	Room 116	5/28/2016 - 1:23PM	ND	ND
1-W-C802-25	Room 116	5/28/2016 - 1:23PM	ND	ND
1-W-F01-26	Room 116	5/28/2016 - 1:25PM	ND	ND
1-W-F01-27	Room 116	5/28/2016 - 1:25PM	ND	ND
1-W-F01-28	Room 116	5/28/2016 - 1:25PM	ND	ND
1-W-F01-29	Room 116	5/28/2016 - 1:25PM	ND	ND
1-W-F01-30	Room 116	5/28/2016 - 1:25PM	ND	ND
1-W-C801-31	Room 117	5/28/2016 - 1:42PM	ND	ND
1-W-C801-32	Room 117	5/28/2016 - 1:42PM	ND	ND
1-W-C801-33	Room 117	5/28/2016 - 1:42PM	ND	ND
1-W-C801-34	Room 117	5/28/2016 - 1:42PM	ND	ND
1-W-C801-35	Room 117	5/28/2016 - 1:42PM	ND	ND
1-W-F01-36	Room 117	5/28/2016 - 1:44PM	ND	ND
1-W-F01-37	Room 117	5/28/2016 - 1:44PM	ND	ND
1-W-F01-38	Room 117	5/28/2016 - 1:44PM	ND	ND
1-W-F01-39	Room 117	5/28/2016 - 1:44PM	ND	ND
1-W-F01-40	Room 117	5/28/2016 - 1:44PM	ND	ND
1-W-C802-41	Room 117	5/28/2016 - 1:52PM	389	AA
1-W-C802-42	Room 117	5/28/2016 - 1:52PM	56.2	AA
1-W-C802-43	Room 117	5/28/2016 - 1:52PM	21.2	AA
1-W-C802-44	Room 117	5/28/2016 - 1:52PM	17.8	AA
1-W-C802-45	Room 117	5/28/2016 - 1:52PM	14.2	BA
1-W-C801-46	Room 118	5/28/2016 - 1:59 PM	ND	ND
1-W-C801-47	Room 118	5/28/2016 - 1:59 PM	ND	ND
1-W-C801-48	Room 118	5/28/2016 - 1:59 PM	ND	ND
1-W-C801-49	Room 118	5/28/2016 - 1:59 PM	ND	ND
1-W-C801-50	Room 118	5/28/2016 - 1:59 PM	ND	ND
1-W-C802-51	Room 118	5/28/2016 - 2:01PM	ND	ND
1-W-C802-52	Room 118	5/28/2016 - 2:01PM	ND	ND
1-W-C802-53	Room 118	5/28/2016 - 2:01PM	ND	ND
1-W-C802-54	Room 118	5/28/2016 - 2:01PM	ND	ND
1-W-C802-55	Room 118	5/28/2016 - 2:03PM	ND	ND
1-W-F01-56	Room 118	5/28/2016 - 2:03PM	ND	ND
1-W-F01-57	Room 118	5/28/2016 - 2:03PM	ND	ND
1-W-F01-58	Room 118	5/28/2016 - 2:03PM	ND	ND
1-W-F01-59	Room 118	5/28/2016 - 2:03PM	ND	ND
1-W-F01-60	Room 118	5/28/2016 - 2:03PM	ND	ND
1-W-C801-61	Room 119	5/28/2016 - 2:14PM	ND	ND
1-W-C801-62	Room 119	5/28/2016 - 2:14PM	ND	ND
1-W-C801-63	Room 119	5/28/2016 - 2:14PM	ND	ND
1-W-C801-64	Room 119	5/28/2016 - 2:14PM	ND	ND

1-W-C501-65	Room 119	5/28/2016 - 2:14PM	ND	ND
1-W-C502-66	Room 119	5/28/2016 - 2:15PM	12.6	BA
1-W-C502-67	Room 119	5/28/2016 - 2:15PM	ND	ND
1-W-C502-68	Room 119	5/28/2016 - 2:15PM	ND	ND
1-W-C502-69	Room 119	5/28/2016 - 2:15PM	ND	ND
1-W-C502-70	Room 119	5/28/2016 - 2:15PM	ND	ND
1-W-F01-71	Room 119	5/28/2016 - 2:21PM	ND	ND
1-W-F01-72	Room 119	5/28/2016 - 2:21PM	ND	ND
1-W-F01-73	Room 119	5/28/2016 - 2:21PM	ND	ND
1-W-F01-74	Room 119	5/28/2016 - 2:21PM	ND	ND
1-W-F01-75	Room 119	5/28/2016 - 2:21PM	ND	ND
1-W-C501-76	Room 120	5/28/2016 - 2:31PM	ND	ND
1-W-C501-77	Room 120	5/28/2016 - 2:31PM	ND	ND
1-W-C501-78	Room 120	5/28/2016 - 2:31PM	ND	ND
1-W-C501-79	Room 120	5/28/2016 - 2:31PM	ND	ND
1-W-C501-80	Room 120	5/28/2016 - 2:31PM	ND	ND
1-W-C502-81	Room 120	5/28/2016 - 2:32PM	ND	ND
1-W-C502-82	Room 120	5/28/2016 - 2:32PM	ND	ND
1-W-C502-83	Room 120	5/28/2016 - 2:32PM	ND	ND
1-W-C502-84	Room 120	5/28/2016 - 2:32PM	ND	ND
1-W-C502-85	Room 120	5/28/2016 - 2:32PM	ND	ND
1-W-F01-86	Room 120	5/28/2016 - 2:34PM	ND	ND
1-W-F01-87	Room 120	5/28/2016 - 2:34PM	ND	ND
1-W-F01-88	Room 120	5/28/2016 - 2:34PM	ND	ND
1-W-F01-89	Room 120	5/28/2016 - 2:34PM	ND	ND
1-W-F01-90	Room 120	5/28/2016 - 2:34PM	ND	ND
1-W-C501-91	Room 121	5/28/2016 - 2:49PM	ND	ND
1-W-C501-92	Room 121	5/28/2016 - 2:49PM	ND	ND
1-W-C501-93	Room 121	5/28/2016 - 2:49PM	ND	ND
1-W-C501-94	Room 121	5/28/2016 - 2:49PM	ND	ND
1-W-C502-96	Room 121	5/28/2016 - 2:49PM	ND	ND
1-W-C502-98	Room 121	5/28/2016 - 2:53PM	48.5	AA
1-W-C502-97	Room 121	5/28/2016 - 2:53PM	19.7	AA
1-W-C502-98	Room 121	5/28/2016 - 2:53PM	6.24	BA
1-W-C502-99	Room 121	5/28/2016 - 2:53PM	14.9	BA
1-W-C502-100	Room 121	5/28/2016 - 2:53PM	6.38	BA
1-W-F01-101	Room 121	5/28/2016 - 2:55PM	ND	ND
1-W-F01-102	Room 121	5/28/2016 - 2:55PM	ND	ND
1-W-F01-103	Room 121	5/28/2016 - 2:55PM	ND	ND
1-W-F01-104	Room 121	5/28/2016 - 2:55PM	ND	ND
1-W-F01-105	Room 121	5/28/2016 - 2:55PM	ND	ND
1-W-F01-106	Across Room 107	5/28/2016 - 3:15PM	ND	ND
1-W-F01-107	Across Room 107	5/28/2016 - 3:15PM	ND	ND
1-W-F01-108	Across Room 107	5/28/2016 - 3:15PM	ND	ND
1-W-F01-109	Across Room 107	5/28/2016 - 3:15PM	ND	ND
1-W-F01-110	Across Room 107	5/28/2016 - 3:15PM	ND	ND
1-W-F02-111	Across Room 107	5/28/2016 - 3:22PM	ND	ND
1-W-F02-112	Across Room 107	5/28/2016 - 3:22PM	ND	ND
1-W-F02-113	Across Room 107	5/28/2016 - 3:22PM	ND	ND
1-W-F02-114	Across Room 107	5/28/2016 - 3:22PM	ND	ND
1-W-F02-115	Across Room 107	5/28/2016 - 3:22PM	ND	ND
1-W-F04-116	Across Room 121	5/28/2016 - 3:35PM	ND	ND
1-W-F04-117	Across Room 121	5/28/2016 - 3:35PM	ND	ND
1-W-F04-118	Across Room 121	5/28/2016 - 3:35PM	ND	ND
1-W-F04-119	Across Room 121	5/28/2016 - 3:35PM	ND	ND
1-W-F04-120	Across Room 121	5/28/2016 - 3:35PM	ND	ND
1-C-C501-121	Kitchen (Central)	5/28/2016 - 3:46PM	ND	ND
1-C-C501-122	Kitchen (Central)	5/28/2016 - 3:46PM	ND	ND
1-C-C501-123	Kitchen (Central)	5/28/2016 - 3:46PM	ND	ND
1-C-C501-124	Kitchen (Central)	5/28/2016 - 3:46PM	ND	ND
1-C-C501-125	Kitchen (Central)	5/28/2016 - 3:46PM	ND	ND
1-B-C502-126	Kitchen (South)	5/28/2016 - 3:46PM	ND	ND
1-B-C502-127	Kitchen (South)	5/28/2016 - 3:46PM	ND	ND
1-B-C502-128	Kitchen (South)	5/28/2016 - 3:46PM	ND	ND
1-B-C502-129	Kitchen (South)	5/28/2016 - 3:46PM	ND	ND
1-B-C502-130	Kitchen (South)	5/28/2016 - 3:46PM	ND	ND
1-C-C503-131	Kitchen (South)	5/28/2016 - 3:56PM	ND	ND
1-C-C503-132	Kitchen (South)	5/28/2016 - 3:56PM	ND	ND
1-C-C503-133	Kitchen (South)	5/28/2016 - 3:56PM	ND	ND
1-C-C503-134	Kitchen (South)	5/28/2016 - 3:56PM	ND	ND
1-C-C503-135	Kitchen (South)	5/28/2016 - 3:56PM	ND	ND
3-W-F02-136	Across Room 323 - 3rd Floor	5/28/2016 - 4:10PM	ND	ND

3-W-F02-137	Across Room 323 - 3rd Floor	5/28/2016 - 4:10PM	ND	ND
3-W-F02-138	Across Room 323 - 3rd Floor	5/28/2016 - 4:10PM	ND	ND
3-W-F02-139	Across Room 323 - 3rd Floor	5/28/2016 - 4:10PM	ND	ND
3-W-F02-140	Across Room 323 - 3rd Floor	5/28/2016 - 4:10PM	ND	ND
3-W-F01-141	Across Room 323 - 3rd Floor	5/28/2016 - 4:12PM	ND	ND
3-W-F01-142	Across Room 323 - 3rd Floor	5/28/2016 - 4:12PM	ND	ND
3-W-F01-143	Across Room 323 - 3rd Floor	5/28/2016 - 4:12PM	ND	ND
3-W-F01-144	Across Room 323 - 3rd Floor	5/28/2016 - 4:12PM	ND	ND
3-W-F01-145	Across Room 323 - 3rd Floor	5/28/2016 - 4:13PM	ND	ND
3-W-F02-146	Across Room 219	5/28/2016 - 4:18PM	ND	ND
3-W-F02-147	Across Room 219	5/28/2016 - 4:18PM	ND	ND
3-W-F02-148	Across Room 219	5/28/2016 - 4:18PM	ND	ND
3-W-F02-149	Across Room 219	5/28/2016 - 4:18PM	ND	ND
3-W-F02-150	Across Room 219	5/28/2016 - 4:18PM	ND	ND
3-W-F01-151	Across Room 219	5/28/2016 - 4:20PM	ND	ND
3-W-F01-152	Across Room 221	5/28/2016 - 4:20PM	ND	ND
3-W-F01-153	Across Room 221	5/28/2016 - 4:20PM	ND	ND
3-W-F01-154	Across Room 222	5/28/2016 - 4:20PM	ND	ND
3-W-F01-155	Across Room 223	5/28/2016 - 4:20PM	ND	ND
3-W-F02-156	Between Rooms 307 and 303	5/28/2016 - 4:30PM	ND	ND
3-W-F02-157	Between Rooms 307 and 303	5/28/2016 - 4:30PM	ND	ND
3-W-F02-158	Between Rooms 307 and 303	5/28/2016 - 4:30PM	ND	ND
3-W-F02-159	Between Rooms 307 and 303	5/28/2016 - 4:30PM	ND	ND
3-W-F01-160	Between Rooms 307 and 303	5/28/2016 - 4:30PM	ND	ND
3-W-F01-161	Between Rooms 307 and 303	5/28/2016 - 4:30PM	ND	ND
3-W-F01-162	Between Rooms 307 and 303	5/28/2016 - 4:33PM	ND	ND
3-W-F01-163	Between Rooms 307 and 303	5/28/2016 - 4:33PM	ND	ND
3-W-F01-164	Between Rooms 307 and 303	5/28/2016 - 4:33PM	ND	ND
3-W-F01-165	Between Rooms 306 and 310	5/28/2016 - 4:39PM	ND	ND
3-E-F01-166	Between Rooms 307 and 303	5/28/2016 - 4:39PM	ND	ND
3-W-F01-166	Between Rooms 307 and 303	5/28/2016 - 4:39PM	ND	ND
3-E-F01-167	Between Rooms 306 and 310	5/28/2016 - 4:39PM	ND	ND
3-E-F01-168	Between Rooms 306 and 310	5/28/2016 - 4:39PM	ND	ND
3-E-F01-169	Between Rooms 306 and 310	5/28/2016 - 4:39PM	ND	ND
3-E-F01-170	Between Rooms 306 and 310	5/28/2016 - 4:39PM	ND	ND
3-E-F02-171	Between Rooms 306 and 310	5/28/2016 - 4:41PM	ND	ND
3-E-F02-172	Between Rooms 306 and 310	5/28/2016 - 4:41PM	ND	ND
3-E-F02-173	Between Rooms 306 and 310	5/28/2016 - 4:41PM	ND	ND
3-E-F02-174	Between Rooms 306 and 310	5/28/2016 - 4:41PM	ND	ND
3-E-F02-175	Between Rooms 306 and 310	5/28/2016 - 4:41PM	ND	ND
3-W-F01-176	Between Rooms 209 and 203	5/28/2016 - 4:57PM	ND	ND
3-W-F01-177	Between Rooms 209 and 203	5/28/2016 - 4:57PM	ND	ND
3-W-F01-178	Between Rooms 209 and 203	5/28/2016 - 4:57PM	ND	ND
3-W-F01-179	Between Rooms 209 and 203	5/28/2016 - 4:57PM	ND	ND
3-E-F02-180	Between Rooms 204 and 210	5/28/2016 - 4:59PM	ND	ND
3-E-F02-181	Between Rooms 204 and 210	5/28/2016 - 4:59PM	ND	ND
3-E-F02-182	Between Rooms 204 and 210	5/28/2016 - 4:59PM	ND	ND
3-E-F02-183	Between Rooms 204 and 210	5/28/2016 - 4:59PM	ND	ND
3-E-F01-184	Between Rooms 204 and 210	5/28/2016 - 5:00PM	ND	ND
3-E-F01-185	Between Rooms 204 and 210	5/28/2016 - 5:00PM	ND	ND
3-E-F01-186	Between Rooms 204 and 210	5/28/2016 - 5:00PM	ND	ND
3-E-F01-187	Between Rooms 204 and 210	5/28/2016 - 5:00PM	ND	ND
3-E-F01-188	Between Rooms 204 and 210	5/28/2016 - 5:00PM	ND	ND
3-E-F01-189	Between Rooms 204 and 210	5/28/2016 - 5:00PM	ND	ND
3-E-F01-190	Between Rooms 204 and 210	5/28/2016 - 5:00PM	ND	ND

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND- Not Detected at CCA's Reporting Limit

BA- Below EPA Action Level of 15 ppb

AA- Above EPA Action Level