



School Lead Water Testing Summary

School Short Name **Parker / Pre-k**
Address 6800 S Stewart Ave
Facility ID 51381
CPS Team Member Craig Edgerley
MEC Team Member Evan Christian

Length of time water remained in pipes before sampled [Approx 9-10 hours](#)
 Water last used (Time and date) [Approx 9 PM 5/11/16](#)
 Date of test [5/12/2016](#)
 Report based on lab results dated

Sample ID #	Sample Location	Sample Collection Time & Date	Test Results (ppb)	ppb Level
51381-1-K-CS-01	Kitchen	6:07 AM 5/12/16	ND	-
51381-1-S-F-02	Cafeteria	6:14 AM 5/12/16	ND	-
51381-1-S-F-03	Hallway by Room 105	6:18 AM 5/12/16	ND	-
51381-1-N-F-04	Hallway by Room 106	6:25 AM 5/12/16	ND	-
51381-2-E-F-05	Hallway by Room 216	6:28 AM 5/12/16	7.4	BA
51381-2-N-F-06	Hallway by Room 206	6:33 AM 5/12/16	ND	-
51381-3-S-WC-07	West Gymnasium	6:36 AM 5/12/16	ND	-
51381-3-S-F-08	Hallway by Room 305	6:38 AM 5/12/16	ND	-
51381-3-E-WC-09	East Gymnasium	6:40 AM 5/12/16	ND	-
51381-3-C-WC-10	Main Gymnasium	6:42 AM 5/12/16	ND	-
51381-4-N-F-11	Hallway by Room 406	6:46 AM 5/12/16	ND	-
51381-1-N-F-12	Hallway by Parents Room	6:55 AM 5/12/16	ND	-
51381-1-W-F-13	Room 004	6:58 AM 5/12/16	ND	-
51381-1-S-F-14	Room 001	7:02 AM 5/12/16	ND	-

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit
 BA-Below EPA Action Level of 15 ppb
 AA-Above EPA Action Level