



School Lead Water Testing Summary

School Short Name **Hefferan**
Address 4409 W. Wilcox St.
Facility ID 51186
CPS Team Member Craig Edgerley
MEC Team Member Evan Christian

Length of time water remained in pipes before sampled [Approx. 10 hours](#)
Water last used (Time and date) [Approx. 8 PM 4/28/16](#)
Date of test [4/29/2016](#)
Report based on lab results dated [5/11/2016](#)

Sample ID #	Sample Location	Sample Collection Time & Date	Test Results (ppb)	ppb Level
51186-1-K-CS-01	Kitchen	6:29 AM 4/29/16	ND	-
51186-1-W-WC-02	Hallway by Boiler Room	6:32 AM 4/29/16	ND	-
51186-1-E-WC-03	Hallway by Main Office	6:35 AM 4/29/16	ND	-
51186-2-E-WC-04	Hallway by Room 213	6:36 AM 4/29/16	ND	-
51186-2-W-WC-05	Hallway by Room 223	6:39 AM 4/29/16	ND	-

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit
BA-Below EPA Action Level of 15 ppb
AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations