



October 28, 2016

Dear CVCA families,

In light of national events that have brought increased attention to the issue of water quality, the City of Chicago announced several additional precautionary measures that will be added to the City's water testing protocol, continuing the City's track record of complying with current state and federal regulations as well as exceeding industry standards.

As part of this announcement, Chicago Public Schools (CPS) began testing the water for levels of lead from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe. Schools are being tested based on a priority criteria that includes the age of the school, age of the students (with priority given to schools with pre-K programs), presence of a kitchen (where meals are prepared) and presence of pipes that could need repairs or replacement.

The results of all the schools are coming in on a rolling basis, and the majority have had levels under the EPA's action level of 15 parts per billion (ppb). At CVCA samples were tested from 42 sites and the water sampled from eight drinking fountains and one sink were above the action level of 15 ppb: four fountains located on the first floor by the stairway exit, next to Rooms 011 and 117, and the northeast hallway; two fountains on the second floor across from the auditorium and outside of Room 245; and two on the third floor outside of Rooms 332 and 342. The sink is located on the second floor in the nurse's office. The water from the sink and fountains have been turned off and remediation plans are being created.

Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. Nine of the samples at CVCA returned with elevated results – the issue is not system-wide, but is specific to the fixtures or pipes for that sink and those fountains and will be addressed through the remediation plan. The full results of every school's water samples can be found online at cps.edu/leadtesting.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

Forrest Claypool
CEO, Chicago Public Schools

Dr. Julie Morita
Commissioner, Chicago Department of Public Health



28 de octubre de 2016

Estimadas familias de la escuela CVCA,

Ante recientes eventos nacionales que han aumentado la atención sobre el tema de la calidad del agua, la ciudad de Chicago anunció varias medidas de precaución adicionales que se sumarán al protocolo de la ciudad sobre control del agua, en cumplimiento de las regulaciones estatales y federales, así como de los estándares industriales

Como parte de este anuncio, las Escuelas Públicas de Chicago (CPS) comenzaron a examinar los niveles de plomo en el agua de las escuelas de todo el distrito. Nuestra prioridad máxima es la salud y seguridad de los estudiantes y del personal, y estas pruebas se iniciaron como precaución para estar seguros de la calidad del agua de las escuelas. Las pruebas se realizan según un criterio de prioridad que incluye la edad del edificio, edad de los estudiantes (con prioridad para las escuelas con programas de preescolares), la presencia de una cocina (donde se preparan alimentos) y de cañerías que puedan necesitar reparación o reemplazo.

Los resultados de todas las escuelas se han ido conociendo, y la mayoría registró niveles por debajo del nivel de acción de EPA que es de 15 partículas por billón (ppb). En CVCA se tomaron muestras en 42 lugares y el agua de ocho bebederos y de una pileta tenía rastros de plomo por encima del nivel de acción de 15 ppb: cuatro bebederos del primer piso, en la salida de la escalera y próximos a los salones 011 y 117, y en el corredor noroeste; dos bebederos del segundo piso, frente al auditorio y afuera del salón 245; y dos del tercer piso, afuera de los salones 332 y 342. La pileta está ubicada en el segundo piso, en la oficina de enfermería. El suministro de agua de esos dispositivos fue interrumpido y se están creando planes para remediar la situación.

El agua de Chicago no tiene plomo cuando sale de la planta de tratamiento. Sin embargo, se puede encontrar en algunas cañerías internas y materiales, y el plomo encontrado en el agua potable es provocado usualmente por la corrosión de las cañerías. Esto explica por qué solamente nueve de las muestras de CVCA registraron niveles elevados. Este no es problema general, sino específico de las cañerías de esos dispositivos, y será solucionado. Los resultados completos de cada escuela se pueden ver en línea en cps.edu/leadtesting.

Los lineamientos federales indican que los niños menores de seis años son los que corren mayores riesgos con la exposición al plomo, algo que puede ocurrir de varias fuentes, incluyendo pintura, tierra y algunos productos de consumo. Si están preocupados por la posible exposición de su hijo al plomo, el Departamento de Salud Pública de la ciudad de Chicago (CDPH) recomienda visitar a su pediatra o a alguno de los centros de salud listados en el material adjunto, para una prueba. Además, la línea directa del CDPH puede responder cualquier pregunta que tengan, o ayudarlos a decidir si su niño debe ser examinado; por preguntas o más información, llame por favor al 312-747-5323. Por información adicional sobre el plomo y los niños, visite www.cdc.gov/lead.

La seguridad de sus hijos es nuestra principal prioridad, y hacemos todo lo que está en nuestro poder para resolver esta situación de una manera rápida y rigurosa. Continuaremos informándoles sobre este proceso.

Atentamente,



Forrest Claypool
CEO, Escuelas Públicas de Chicago



Dra. Julie Morita, Comisionada
Departamento de Salud Pública de Chicago



School Lead Water Testing - Data Collection Form

School Short Name **Chicago Vocational Career**
Date of test 10/05/16

School Short Name	Facility ID	Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
Chicago Vocational Career	51625	51625-1-KIT-KS01-001	Kitchen Middle Prep Table	6:19AM	ND	ND
Chicago Vocational Career	51625	51625-1-KIT-KS01-002	Kitchen Middle Prep Table	6:19AM	ND	ND
Chicago Vocational Career	51625	51625-1-KIT-KS01-003	Kitchen Middle Prep Table	6:19AM	ND	ND
Chicago Vocational Career	51625	51625-1-KIT-KS01-004	Kitchen Middle Prep Table	6:19AM	ND	ND
Chicago Vocational Career	51625	51625-1-KIT-KS01-005	Kitchen Middle Prep Table	6:19AM	ND	ND
Chicago Vocational Career	51625	51625-1-KIT-S02-001	Far right prep table left sink	6:22AM	ND	ND
Chicago Vocational Career	51625	51625-1-KIT-S02-002	Far right prep table left sink	6:22AM	ND	ND
Chicago Vocational Career	51625	51625-1-KIT-S02-003	Far right prep table left sink	6:22AM	ND	ND
Chicago Vocational Career	51625	51625-1-KIT-S02-004	Far right prep table left sink	6:22AM	ND	ND
Chicago Vocational Career	51625	51625-1-KIT-S02-005	Far right prep table left sink	6:22AM	ND	ND
Chicago Vocational Career	51625	51625-1-KIT-KS03-001	Far right prep table right sink	6:24AM	ND	ND
Chicago Vocational Career	51625	51625-1-KIT-KS03-002	Far right prep table right sink	6:24AM	ND	ND
Chicago Vocational Career	51625	51625-1-KIT-KS03-003	Far right prep table right sink	6:24AM	12	BA
Chicago Vocational Career	51625	51625-1-KIT-KS03-004	Far right prep table right sink	6:24AM	ND	ND
Chicago Vocational Career	51625	51625-1-KIT-KS03-005	Far right prep table right sink	6:24AM	ND	ND
Chicago Vocational Career	51625	51625-1-CAF-F01-01	Middle Pillar, Left Cafeteria	6:25AM	ND	ND
Chicago Vocational Career	51625	51625-1-CAF-F01-02	Middle Pillar, Left Cafeteria	6:25AM	ND	ND
Chicago Vocational Career	51625	51625-1-CAF-F01-03	Middle Pillar, Left Cafeteria	6:25AM	ND	ND
Chicago Vocational Career	51625	51625-1-CAF-F01-04	Middle Pillar, Left Cafeteria	6:25AM	ND	ND
Chicago Vocational Career	51625	51625-1-CAF-F01-05	Middle Pillar, Left Cafeteria	6:25AM	ND	ND
Chicago Vocational Career	51625	51625-1-CAF-F02-01	Middle Pillar, Right Cafeteria	6:27AM	11.8	BA

Chicago Vocatinal Career	51625	51625-1-CAF-F02-02	Middle Pillar, Right Cafeteria	6:27AM	12.9	BA
Chicago Vocatinal Career	51625	51625-1-CAF-F02-03	Middle Pillar, Right Cafeteria	6:27AM	5.88	BA
Chicago Vocatinal Career	51625	51625-1-CAF-F02-04	Middle Pillar, Right Cafeteria	6:27AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-CAF-F02-05	Middle Pillar, Right Cafeteria	6:27AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-CAF-F03-01	By Stair exit	6:29AM	17.6	AA
Chicago Vocatinal Career	51625	51625-1-CAF-F03-02	By Stair exit	6:29AM	9.39	BA
Chicago Vocatinal Career	51625	51625-1-CAF-F03-03	By Stair exit	6:29AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-CAF-F03-04	By Stair exit	6:29AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-CAF-F03-05	By Stair exit	6:29AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-008-S01-01	Teacher's Lounge	6:41AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-008-S01-02	Teacher's Lounge	6:41AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-008-S01-03	Teacher's Lounge	6:41AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-008-S01-04	Teacher's Lounge	6:41AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-008-S01-05	Teacher's Lounge	6:41AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F01-01	Next to RM 011 Right Fount.	6:48AM	15.5	AA
Chicago Vocatinal Career	51625	51625-1-HAL-F01-02	Next to RM 011 Right Fount.	6:48AM	7.99	BA
Chicago Vocatinal Career	51625	51625-1-HAL-F01-03	Next to RM 011 Right Fount.	6:48AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F01-04	Next to RM 011 Right Fount.	6:48AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F01-05	Next to RM 011 Right Fount.	6:48AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F02-01	Next to RM 011 Left Fount.	6:50AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F02-02	Next to RM 011 Left Fount.	6:50AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F02-03	Next to RM 011 Left Fount.	6:50AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F02-04	Next to RM 011 Left Fount.	6:50AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F02-05	Next to RM 011 Left Fount.	6:50AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-113-S01-01	Culinary Arts RM Left Sink	6:56AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-113-S01-02	Culinary Arts RM Left Sink	6:56AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-113-S01-03	Culinary Arts RM Left Sink	6:56AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-113-S01-04	Culinary Arts RM Left Sink	6:56AM	ND	ND

Chicago Vocatinal Career	51625	51625-1-113-S01-05	Culinary Arts RM Left Sink	6:56AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-113-S02-01	RM 113 Middle Sink	6:58AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-113-S02-02	RM 113 Middle Sink	6:58AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-113-S02-03	RM 113 Middle Sink	6:58AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-113-S02-04	RM 113 Middle Sink	6:58AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-113-S02-05	RM 113 Middle Sink	6:58AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-113-S03-01	RM 113 Right Sink	7:00AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-113-S03-02	RM 113 Right Sink	7:00AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-113-S03-03	RM 113 Right Sink	7:00AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-113-S03-04	RM 113 Right Sink	7:00AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-113-S03-05	RM 113 Right Sink	7:00AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F03-01	Across Auditorium Left Fount	7:10AM	8.37	BA
Chicago Vocatinal Career	51625	51625-1-HAL-F03-02	Across Auditorium Left Fount	7:10AM	5.68	BA
Chicago Vocatinal Career	51625	51625-1-HAL-F03-03	Across Auditorium Left Fount	7:10AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F03-04	Across Auditorium Left Fount	7:10AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F03-05	Across Auditorium Left Fount	7:10AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F04-01	Across Auditorium Right Fount	7:12AM	5.93	BA
Chicago Vocatinal Career	51625	51625-1-HAL-F04-02	Across Auditorium Right Fount	7:12AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F04-03	Across Auditorium Right Fount	7:12AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F04-04	Across Auditorium Right Fount	7:12AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F04-05	Across Auditorium Right Fount	7:12AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F05-01	Across RM 126	7:16AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F05-02	Across RM 126	7:16AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F05-03	Across RM 126	7:16AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F05-04	Across RM 126	7:16AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F05-05	Across RM 126	7:16AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-117-F01-01	Back of Auditorium left sink	7:17AM	49.6	AA
Chicago Vocatinal Career	51625	51625-1-117-F01-02	Back of Auditorium left sink	7:17AM	48.1	AA

Chicago Vocatinal Career	51625	51625-1-117-F01-03	Back of Auditorium left sink	7:17AM	23	AA
Chicago Vocatinal Career	51625	51625-1-117-F01-04	Back of Auditorium left sink	7:17AM	13.1	BA
Chicago Vocatinal Career	51625	51625-1-117-F01-05	Back of Auditorium left sink	7:17AM	8.55	BA
Chicago Vocatinal Career	51625	51625-1-HAL-F06-01	Across From RM 126	7:29AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F06-02	Across From RM 126	7:29AM	5.66	BA
Chicago Vocatinal Career	51625	51625-1-HAL-F06-03	Across From RM 126	7:29AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F06-04	Across From RM 126	7:29AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F06-05	Across From RM 126	7:29AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F07-01	Main Entrance Left Fountain	7:34AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F07-02	Main Entrance Left Fountain	7:34AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F07-03	Main Entrance Left Fountain	7:34AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F07-04	Main Entrance Left Fountain	7:34AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F07-05	Main Entrance Left Fountain	7:34AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F08-01	Main Entrance Right Fountain	7:36AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F08-02	Main Entrance Right Fountain	7:36AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F08-03	Main Entrance Right Fountain	7:36AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F08-04	Main Entrance Right Fountain	7:36AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F08-05	Main Entrance Right Fountain	7:36AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-135-F01-01	Main Office	7:38AM	5.07	BA
Chicago Vocatinal Career	51625	51625-1-135-F01-02	Main Office	7:38AM	5.28	BA
Chicago Vocatinal Career	51625	51625-1-135-F01-03	Main Office	7:38AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-135-F01-04	Main Office	7:38AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-135-F01-05	Main Office	7:38AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F09-01	Across RM 138 Left Fount	7:47AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F09-02	Across RM 138 Left Fount	7:47AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F09-03	Across RM 138 Left Fount	7:47AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F09-04	Across RM 138 Left Fount	7:47AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F09-05	Across RM 138 Left Fount	7:47AM	ND	ND

Chicago Vocatinal Career	51625	51625-1-HAL-F10-01	Across RM 138 Right Fount	7:49AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F10-02	Across RM 138 Right Fount	7:49AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F10-03	Across RM 138 Right Fount	7:49AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F10-04	Across RM 138 Right Fount	7:49AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F10-05	Across RM 138 Right Fount	7:49AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F11-01	Across RM 144 Left Fount	7:57AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F11-02	Across RM 144 Left Fount	7:57AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F11-03	Across RM 144 Left Fount	7:57AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F11-04	Across RM 144 Left Fount	7:57AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F11-05	Across RM 144 Left Fount	7:57AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F12-01	Across RM 144 Right Fount	7:59AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F12-02	Across RM 144 Right Fount	7:59AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F12-03	Across RM 144 Right Fount	7:59AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F12-04	Across RM 144 Right Fount	7:59AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F12-05	Across RM 144 Right Fount	7:59AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F13-01	NE Corner Hall	8:01AM	10	BA
Chicago Vocatinal Career	51625	51625-1-HAL-F13-02	NE Corner Hall	8:01AM	17.6	AA
Chicago Vocatinal Career	51625	51625-1-HAL-F13-03	NE Corner Hall	8:01AM	17.1	AA
Chicago Vocatinal Career	51625	51625-1-HAL-F13-04	NE Corner Hall	8:01AM	16.7	AA
Chicago Vocatinal Career	51625	51625-1-HAL-F13-05	NE Corner Hall	8:01AM	14.7	BA
Chicago Vocatinal Career	51625	51625-1-HAL-F14-01	Across RM 022	8:07AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F14-02	Across RM 022	8:07AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F14-03	Across RM 022	8:07AM	5.98	BA
Chicago Vocatinal Career	51625	51625-1-HAL-F14-04	Across RM 022	8:07AM	6.03	BA
Chicago Vocatinal Career	51625	51625-1-HAL-F14-05	Across RM 022	8:07AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F15-01	Across RM 022	7:10AM	5.28	BA
Chicago Vocatinal Career	51625	51625-1-HAL-F15-02	Across RM 022	7:10AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F15-03	Across RM 022	7:10AM	ND	ND

Chicago Vocatinal Career	51625	51625-1-HAL-F15-04	Across RM 022	7:10AM	ND	ND
Chicago Vocatinal Career	51625	51625-1-HAL-F15-05	Across RM 022	7:10AM	ND	ND
Chicago Vocatinal Career	51625	51625-2-HAL-F01-01	Across Auditorium Left Fount	6:15AM	9.05	BA
Chicago Vocatinal Career	51625	51625-2-HAL-F01-02	Across Auditorium Left Fount	6:15AM	19.2	AA
Chicago Vocatinal Career	51625	51625-2-HAL-F01-03	Across Auditorium Left Fount	6:15AM	12.8	BA
Chicago Vocatinal Career	51625	51625-2-HAL-F01-04	Across Auditorium Left Fount	6:15AM	8.38	BA
Chicago Vocatinal Career	51625	51625-2-HAL-F01-05	Across Auditorium Left Fount	6:15AM	8.19	BA
Chicago Vocatinal Career	51625	51625-2-HAL-F02-01	Across Auditorium Right Fount	6:20AM	8.61	BA
Chicago Vocatinal Career	51625	51625-2-HAL-F02-02	Across Auditorium Right Fount	6:20AM	8.85	BA
Chicago Vocatinal Career	51625	51625-2-HAL-F02-03	Across Auditorium Right Fount	6:20AM	6.18	BA
Chicago Vocatinal Career	51625	51625-2-HAL-F02-04	Across Auditorium Right Fount	6:20AM	ND	ND
Chicago Vocatinal Career	51625	51625-2-HAL-F02-05	Across Auditorium Right Fount	6:20AM	13.2	BA
Chicago Vocatinal Career	51625	51625-2-HAL-F04-01	Outside RM 228 Right Fount	6:25AM	ND	ND
Chicago Vocatinal Career	51625	51625-2-HAL-F04-02	Outside RM 228 Right Fount	6:25AM	ND	ND
Chicago Vocatinal Career	51625	51625-2-HAL-F04-03	Outside RM 228 Right Fount	6:25AM	ND	ND
Chicago Vocatinal Career	51625	51625-2-HAL-F04-04	Outside RM 228 Right Fount	6:25AM	ND	ND
Chicago Vocatinal Career	51625	51625-2-HAL-F04-05	Outside RM 228 Right Fount	6:25AM	ND	ND
Chicago Vocatinal Career	51625	51625-2-HAL-F05-01	Outside Library	6:30AM	5.73	BA
Chicago Vocatinal Career	51625	51625-2-HAL-F05-02	Outside Library	6:30AM	ND	ND
Chicago Vocatinal Career	51625	51625-2-HAL-F05-03	Outside Library	6:30AM	ND	ND
Chicago Vocatinal Career	51625	51625-2-HAL-F05-04	Outside Library	6:30AM	ND	ND
Chicago Vocatinal Career	51625	51625-2-HAL-F05-05	Outside Library	6:30AM	ND	ND
Chicago Vocatinal Career	51625	51625-2-HAL-F06-01	Outside RM 238Left Fountain	6:35AM	ND	ND
Chicago Vocatinal Career	51625	51625-2-HAL-F06-02	Outside RM 238Left Fountain	6:35AM	ND	ND
Chicago Vocatinal Career	51625	51625-2-HAL-F06-03	Outside RM 238Left Fountain	6:35AM	ND	ND
Chicago Vocatinal Career	51625	51625-2-HAL-F06-04	Outside RM 238Left Fountain	6:35AM	ND	ND
Chicago Vocatinal Career	51625	51625-2-HAL-F06-05	Outside RM 238Left Fountain	6:35AM	ND	ND
Chicago Vocatinal Career	51625	51625-2-HAL-F07-01	Outside RM 238 Right Fountain	6:40AM	ND	ND

Chicago Vocatinal Career	51625	51625-2-HAL-F07-02	Outside RM 238 Right Fountain	6:40AM	ND	ND
Chicago Vocatinal Career	51625	51625-2-HAL-F07-03	Outside RM 238 Right Fountain	6:40AM	ND	ND
Chicago Vocatinal Career	51625	51625-2-HAL-F07-04	Outside RM 238 Right Fountain	6:40AM	ND	ND
Chicago Vocatinal Career	51625	51625-2-HAL-F07-05	Outside RM 238 Right Fountain	6:40AM	ND	ND
Chicago Vocatinal Career	51625	51625-2-HAL-F09-01	Outside RM 245 Right Fountain	6:45AM	17.1	AA
Chicago Vocatinal Career	51625	51625-2-HAL-F09-02	Outside RM 245 Right Fountain	6:45AM	17.7	AA
Chicago Vocatinal Career	51625	51625-2-HAL-F09-03	Outside RM 245 Right Fountain	6:45AM	14.1	BA
Chicago Vocatinal Career	51625	51625-2-HAL-F09-04	Outside RM 245 Right Fountain	6:45AM	9.33	BA
Chicago Vocatinal Career	51625	51625-2-HAL-F09-05	Outside RM 245 Right Fountain	6:45AM	10.2	BA
Chicago Vocatinal Career	51625	51625-2-241A-S01-01	Nurses Office sink on West Wall	6:50AM	16.1	AA
Chicago Vocatinal Career	51625	51625-2-241A-S01-02	Nurses Office sink on West Wall	6:50AM	18.2	AA
Chicago Vocatinal Career	51625	51625-2-241A-S01-03	Nurses Office sink on West Wall	6:50AM	14.5	BA
Chicago Vocatinal Career	51625	51625-2-241A-S01-04	Nurses Office sink on West Wall	6:50AM	11.4	BA
Chicago Vocatinal Career	51625	51625-2-241A-S01-05	Nurses Office sink on West Wall	6:50AM	8.77	BA
Chicago Vocatinal Career	51625	51625-2-241A-S02-01	Nurses Office	6:55AM	ND	ND
Chicago Vocatinal Career	51625	51625-2-241A-S02-02	Nurses Office	6:55AM	ND	ND
Chicago Vocatinal Career	51625	51625-2-241A-S02-03	Nurses Office	6:55AM	ND	ND
Chicago Vocatinal Career	51625	51625-2-241A-S02-04	Nurses Office	6:55AM	ND	ND
Chicago Vocatinal Career	51625	51625-2-241A-S02-05	Nurses Office	6:55AM	ND	ND
Chicago Vocatinal Career	51625	51625-2-HAL-F10-01	Outside RM 252	7:00AM	ND	ND
Chicago Vocatinal Career	51625	51625-2-HAL-F10-02	Outside RM 252	7:00AM	5.08	BA
Chicago Vocatinal Career	51625	51625-2-HAL-F10-03	Outside RM 252	7:00AM	ND	ND
Chicago Vocatinal Career	51625	51625-2-HAL-F10-04	Outside RM 252	7:00AM	ND	ND
Chicago Vocatinal Career	51625	51625-2-HAL-F10-05	Outside RM 252	7:00AM	ND	ND
Chicago Vocatinal Career	51625	51625-3-HAL-F03-01	Outside RM 325	7:10AM	ND	ND
Chicago Vocatinal Career	51625	51625-3-HAL-F03-02	Outside RM 325	7:10AM	ND	ND
Chicago Vocatinal Career	51625	51625-3-HAL-F03-03	Outside RM 325	7:10AM	ND	ND
Chicago Vocatinal Career	51625	51625-3-HAL-F03-04	Outside RM 325	7:10AM	ND	ND

Chicago Vocational Career	51625	51625-3-HAL-F03-05	Outside RM 325	7:10AM	ND	ND
Chicago Vocational Career	51625	51625-3-HAL-F05-01	Outside RM 332	7:15AM	15	AA
Chicago Vocational Career	51625	51625-3-HAL-F05-02	Outside RM 332	7:15AM	7.75	BA
Chicago Vocational Career	51625	51625-3-HAL-F05-03	Outside RM 332	7:15AM	5.21	BA
Chicago Vocational Career	51625	51625-3-HAL-F05-04	Outside RM 332	7:15AM	ND	ND
Chicago Vocational Career	51625	51625-3-HAL-F05-05	Outside RM 332	7:15AM	ND	ND
Chicago Vocational Career	51625	51625-3-HAL-F06-01	Outside RM 338	7:20AM	10.7	BA
Chicago Vocational Career	51625	51625-3-HAL-F06-02	Outside RM 338	7:20AM	ND	ND
Chicago Vocational Career	51625	51625-3-HAL-F06-03	Outside RM 338	7:20AM	6.19	BA
Chicago Vocational Career	51625	51625-3-HAL-F06-04	Outside RM 338	7:20AM	7.21	BA
Chicago Vocational Career	51625	51625-3-HAL-F06-05	Outside RM 338	7:20AM	8.59	BA
Chicago Vocational Career	51625	51625-3-HAL-F08-01	Outside RM 342	7:25AM	29.4	AA
Chicago Vocational Career	51625	51625-3-HAL-F08-02	Outside RM 342	7:25AM	45.3	AA
Chicago Vocational Career	51625	51625-3-HAL-F08-03	Outside RM 342	7:25AM	33.3	AA
Chicago Vocational Career	51625	51625-3-HAL-F08-04	Outside RM 342	7:25AM	21.3	AA
Chicago Vocational Career	51625	51625-3-HAL-F08-05	Outside RM 342	7:25AM	16.2	AA
Chicago Vocational Hanger	52343	52343-1-HANG-S01-01	Hangar	8:15AM	ND	ND
Chicago Vocational Hanger	52343	52343-1-HANG-S01-02	Hangar	8:15AM	ND	ND
Chicago Vocational Hanger	52343	52343-1-HANG-S01-03	Hangar	8:15AM	ND	ND
Chicago Vocational Hanger	52343	52343-1-HANG-S01-04	Hangar	8:15AM	ND	ND

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit

BA-Below EPA Action Level of 15 ppb

AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations