



School Lead Water Testing - Data Collection Form

School Short Name **Monroe**

Length of time water remained in pipes before sampled (hours) 13:00
Report based on lab results dated 6/3/16
Date of test 5/25/16
Water last used (Time and date) Approx 4pm 5/24/2016

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
24531-B-E01-S-001	Sink, Basement Room 401 - Annex Bldg.	5/24/16 5:00 AM	1.09	BA
24531-B-E01-S-002	Sink, Basement Room 401 - Annex Bldg.	5/24/16 5:00 AM	0.749	BA
24531-B-E01-S-003	Sink, Basement Room 401 - Annex Bldg.	5/24/16 5:00 AM	4.11	BA
24531-B-E01-S-004	Sink, Basement Room 401 - Annex Bldg.	5/24/16 5:00 AM	0.662	BA
24531-B-E01-S-005	Sink, Basement Room 401 - Annex Bldg.	5/24/16 5:00 AM	0.706	BA
24531-B-E02-S-001	Sink, Basement Vault - Annex Bldg.	5/24/16 5:00 AM	1.345	BA
24531-B-E02-S-002	Sink, Basement Vault - Annex Bldg.	5/24/16 5:00 AM	1.70	BA
24531-B-E02-S-003	Sink, Basement Vault - Annex Bldg.	5/24/16 5:00 AM	0.120	BA
24531-B-E02-S-004	Sink, Basement Vault - Annex Bldg.	5/24/16 5:00 AM	0.746	BA
24531-B-E02-S-005	Sink, Basement Vault - Annex Bldg.	5/24/16 5:00 AM	0.172	BA
24531-B-E03-S-001	Sink, Basement Room 402 - Annex Bldg.	5/24/16 5:00 AM	0.163	BA
24531-B-E03-S-002	Sink, Basement Room 402 - Annex Bldg.	5/24/16 5:00 AM	1.25	BA
24531-B-E03-S-003	Sink, Basement Room 402 - Annex Bldg.	5/24/16 5:00 AM	0.153	BA
24531-B-E03-S-004	Sink, Basement Room 402 - Annex Bldg.	5/24/16 5:00 AM	0.676	BA
24531-B-E03-S-005	Sink, Basement Room 402 - Annex Bldg.	5/24/16 5:00 AM	0.150	BA
24531-B-E04-F-001	Fountain, Basement Hallway - Annex Bldg.	5/24/16 5:00 AM	<0.120	BA
24531-B-E04-F-002	Fountain, Basement Hallway - Annex Bldg.	5/24/16 5:00 AM	<0.120	BA
24531-B-E04-F-003	Fountain, Basement Hallway - Annex Bldg.	5/24/16 5:00 AM	<0.120	BA
24531-B-E04-F-004	Fountain, Basement Hallway - Annex Bldg.	5/24/16 5:00 AM	<0.120	BA
24531-B-E04-F-005	Fountain, Basement Hallway - Annex Bldg.	5/24/16 5:00 AM	<0.120	BA
24531-B-E05-S-001	Sink, Basement Room 403 - Annex Bldg.	5/24/16 5:00 AM	0.223	BA
24531-B-E05-S-002	Sink, Basement Room 403 - Annex Bldg.	5/24/16 5:00 AM	<0.120	BA
24531-B-E05-S-003	Sink, Basement Room 403 - Annex Bldg.	5/24/16 5:00 AM	0.677	BA
24531-B-E05-S-004	Sink, Basement Room 403 - Annex Bldg.	5/24/16 5:00 AM	0.135	BA
24531-B-E05-S-005	Sink, Basement Room 403 - Annex Bldg.	5/24/16 5:00 AM	0.170	BA
24531-B-E06-S-001	Sink, Basement Room 404 - Annex Bldg.	5/24/16 5:00 AM	0.272	BA
24531-B-E06-S-002	Sink, Basement Room 404 - Annex Bldg.	5/24/16 5:00 AM	0.266	BA
24531-B-E06-S-003	Sink, Basement Room 404 - Annex Bldg.	5/24/16 5:00 AM	0.281	BA
24531-B-E06-S-004	Sink, Basement Room 404 - Annex Bldg.	5/24/16 5:00 AM	0.261	BA
24531-B-E06-S-005	Sink, Basement Room 404 - Annex Bldg.	5/24/16 5:00 AM	0.355	BA
24531-B-E07-S-001	Sink, Basement Kitchen - Annex Bldg.	5/24/16 5:00 AM	0.621	BA
24531-B-E07-S-002	Sink, Basement Kitchen - Annex Bldg.	5/24/16 5:00 AM	0.702	BA
24531-B-E07-S-003	Sink, Basement Kitchen - Annex Bldg.	5/24/16 5:00 AM	2.060	BA
24531-B-E07-S-004	Sink, Basement Kitchen - Annex Bldg.	5/24/16 5:00 AM	2.15	BA
24531-B-E07-S-005	Sink, Basement Kitchen - Annex Bldg.	5/24/16 5:00 AM	0.859	BA
24531-1-E01-F-001	Fountain, First Floor Hallway - Annex Bldg.	5/24/16 5:00 AM	<0.120	BA
24531-1-E01-F-002	Fountain, First Floor Hallway - Annex Bldg.	5/24/16 5:00 AM	<0.120	BA
24531-1-E01-F-003	Fountain, First Floor Hallway - Annex Bldg.	5/24/16 5:00 AM	<0.120	BA
24531-1-E01-F-004	Fountain, First Floor Hallway - Annex Bldg.	5/24/16 5:00 AM	<0.120	BA
24531-1-E01-F-005	Fountain, First Floor Hallway - Annex Bldg.	5/24/16 5:00 AM	<0.120	BA
24531-2-E01-F-001	Fountain, Second Floor Hallway - Annex Bldg.	5/24/16 5:00 AM	<0.120	BA
24531-2-E01-F-002	Fountain, Second Floor Hallway - Annex Bldg.	5/24/16 5:00 AM	<0.120	BA
24531-2-E01-F-003	Fountain, Second Floor Hallway - Annex Bldg.	5/24/16 5:00 AM	<0.120	BA
24531-2-E01-F-004	Fountain, Second Floor Hallway - Annex Bldg.	5/24/16 5:00 AM	<0.120	BA
24531-2-E01-F-005	Fountain, Second Floor Hallway - Annex Bldg.	5/24/16 5:00 AM	<0.120	BA
24531-3-E01-F-001	Fountain, 3rd Floor Hallway - Main Bldg.	5/25/16 5:00 AM	0.364	BA
24531-3-E01-F-002	Fountain, 3rd Floor Hallway - Main Bldg.	5/25/16 5:00 AM	0.289	BA
24531-3-E01-F-003	Fountain, 3rd Floor Hallway - Main Bldg.	5/25/16 5:00 AM	0.498	BA
24531-3-E01-F-004	Fountain, 3rd Floor Hallway - Main Bldg.	5/25/16 5:00 AM	0.261	BA
24531-3-E01-F-005	Fountain, 3rd Floor Hallway - Main Bldg.	5/25/16 5:00 AM	0.441	BA
24531-2-E01-F-001	Fountain, 2nd Floor Hallway - Main Bldg.	5/25/16 5:00 AM	0.274	BA
24531-2-E01-F-002	Fountain, 2nd Floor Hallway - Main Bldg.	5/25/16 5:00 AM	0.302	BA
24531-2-E01-F-003	Fountain, 2nd Floor Hallway - Main Bldg.	5/25/16 5:00 AM	0.468	BA
24531-2-E01-F-004	Fountain, 2nd Floor Hallway - Main Bldg.	5/25/16 5:00 AM	0.295	BA
24531-2-E01-F-005	Fountain, 2nd Floor Hallway - Main Bldg.	5/25/16 5:00 AM	0.352	BA
24531-1-E01-F-001	Fountain 1, 1st Floor Hallway by Rm 101 - Main Bldg.	5/25/16 5:00 AM	0.494	BA
24531-1-E01-F-002	Fountain 1, 1st Floor Hallway by Rm 101 - Main Bldg.	5/25/16 5:00 AM	0.456	BA
24531-1-E01-F-003	Fountain 1, 1st Floor Hallway by Rm 101 - Main Bldg.	5/25/16 5:00 AM	0.460	BA
24531-1-E01-F-004	Fountain 1, 1st Floor Hallway by Rm 101 - Main Bldg.	5/25/16 5:00 AM	0.532	BA
24531-1-E01-F-005	Fountain 1, 1st Floor Hallway by Rm 101 - Main Bldg.	5/25/16 5:00 AM	0.477	BA
24531-1-E02-F-001	Fountain 2, 1st Floor Hallway by Rm 101 - Main Bldg.	5/25/16 5:00 AM	0.505	BA
24531-1-E02-F-002	Fountain 2, 1st Floor Hallway by Rm 101 - Main Bldg.	5/25/16 5:00 AM	0.741	BA
24531-1-E02-F-003	Fountain 2, 1st Floor Hallway by Rm 101 - Main Bldg.	5/25/16 5:00 AM	0.931	BA
24531-1-E02-F-004	Fountain 2, 1st Floor Hallway by Rm 101 - Main Bldg.	5/25/16 5:00 AM	0.683	BA
24531-1-E02-F-005	Fountain 2, 1st Floor Hallway by Rm 101 - Main Bldg.	5/25/16 5:00 AM	0.492	BA
24531-B-E01-F-001	Fountain, Basement Hallway - Main Bldg.	5/25/16 5:00 AM	0.703	BA
24531-B-E01-F-002	Fountain, Basement Hallway - Main Bldg.	5/25/16 5:00 AM	0.530	BA
24531-B-E01-F-003	Fountain, Basement Hallway - Main Bldg.	5/25/16 5:00 AM	0.522	BA
24531-B-E01-F-004	Fountain, Basement Hallway - Main Bldg.	5/25/16 5:00 AM	0.721	BA
24531-B-E01-F-005	Fountain, Basement Hallway - Main Bldg.	5/25/16 5:00 AM	0.441	BA

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit
BA-Below EPA Action Level of 15 ppb
AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations