



School Lead Water Testing - Data Collection Form

School Short Name **Fulton**

Length of time water remained in pipes before sampled (hours) 13.00
Report based on lab results dated 6/3/16
Date of test 05/24/16
Water last used (Time and date) Approx 4 PM 5/23/16

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
23281-B-N01-S-001	Basement, Kitchen Sink	5/24/16 5:00 AM	0.791	BA
23281-B-N01-S-002	Basement, Kitchen Sink	5/24/16 5:00 AM	<0.120	ND
23281-B-N01-S-003	Basement, Kitchen Sink	5/24/16 5:00 AM	<0.120	ND
23281-B-N01-S-004	Basement, Kitchen Sink	5/24/16 5:00 AM	<0.120	ND
23281-B-N01-S-005	Basement, Kitchen Sink	5/24/16 5:00 AM	<0.120	ND
23281-B-E01-F-001	Basement, Fountain across Exit 5	5/24/16 5:00 AM	2.57	BA
23281-B-E01-F-002	Basement, Fountain across Exit 5	5/24/16 5:00 AM	1.42	BA
23281-B-E01-F-003	Basement, Fountain across Exit 5	5/24/16 5:00 AM	1.01	BA
23281-B-E01-F-004	Basement, Fountain across Exit 5	5/24/16 5:00 AM	0.78	BA
23281-B-E01-F-005	Basement, Fountain across Exit 5	5/24/16 5:00 AM	0.605	BA
23281-B-E02-F-001	Basement, Fountain next to Exit 5	5/24/16 5:00 AM	<0.120	ND
23281-B-E02-F-002	Basement, Fountain next to Exit 5	5/24/16 5:00 AM	0.131	BA
23281-B-E02-F-003	Basement, Fountain next to Exit 5	5/24/16 5:00 AM	0.242	BA
23281-B-E02-F-004	Basement, Fountain next to Exit 5	5/24/16 5:00 AM	0.273	BA
23281-B-E02-F-005	Basement, Fountain next to Exit 5	5/24/16 5:00 AM	0.282	BA
23281-B-N02-F-001	1st, Fountain Across from Main	5/24/16 5:00 AM	1.84	BA
23281-B-N02-F-002	1st, Fountain Across from Main	5/24/16 5:00 AM	1.18	BA
23281-B-N02-F-003	1st, Fountain Across from Main	5/24/16 5:00 AM	1.13	BA
23281-B-N02-F-004	1st, Fountain Across from Main	5/24/16 5:00 AM	1.48	BA
23281-B-N02-F-005	1st, Fountain Across from Main	5/24/16 5:00 AM	1.75	BA
23281-2-N01-F-001	Fountain Next to Room 208	5/24/16 5:00 AM	0.147	BA
23281-2-N01-F-002	Fountain Next to Room 208	5/24/16 5:00 AM	<0.120	ND
23281-2-N01-F-003	Fountain Next to Room 208	5/24/16 5:00 AM	0.173	BA
23281-2-N01-F-004	Fountain Next to Room 208	5/24/16 5:00 AM	0.252	BA
23281-2-N01-F-005	Fountain Next to Room 208	5/24/16 5:00 AM	0.35	BA
23281-2-N02-F-001	Fountain Next to Room 201	5/24/16 5:00 AM	0.34	BA
23281-2-N02-F-002	Fountain Next to Room 201	5/24/16 5:00 AM	0.329	BA
23281-2-N02-F-003	Fountain Next to Room 201	5/24/16 5:00 AM	0.333	BA
23281-2-N02-F-004	Fountain Next to Room 201	5/24/16 5:00 AM	0.333	BA
23281-2-N02-F-005	Fountain Next to Room 201	5/24/16 5:00 AM	0.35	BA
23281-3-N01-F-001	Fountain Next to Room 308	5/24/16 5:00 AM	<0.120	ND
23281-3-N01-F-002	Fountain Next to Room 308	5/24/16 5:00 AM	<0.120	ND
23281-3-N01-F-003	Fountain Next to Room 308	5/24/16 5:00 AM	<0.120	ND
23281-3-N01-F-004	Fountain Next to Room 308	5/24/16 5:00 AM	<0.120	ND
23281-3-N01-F-005	Fountain Next to Room 308	5/24/16 5:00 AM	<0.120	ND
23281-4-N01-S-001	Sink in Annex Room 414	5/24/16 5:00 AM	1.03	BA
23281-4-N01-S-002	Sink in Annex Room 414	5/24/16 5:00 AM	0.72	BA
23281-4-N01-S-003	Sink in Annex Room 414	5/24/16 5:00 AM	0.686	BA
23281-4-N01-S-004	Sink in Annex Room 414	5/24/16 5:00 AM	0.41	BA
23281-4-N01-S-005	Sink in Annex Room 414	5/24/16 5:00 AM	0.326	BA
23281-1-N02-S-001	Sink in Annex Room 413	5/24/16 5:00 AM	1.9	BA
23281-1-N02-S-002	Sink in Annex Room 413	5/24/16 5:00 AM	1.22	BA
23281-1-N02-S-003	Sink in Annex Room 413	5/24/16 5:00 AM	1	BA
23281-1-N02-S-004	Sink in Annex Room 413	5/24/16 5:00 AM	1.07	BA
23281-1-N02-S-005	Sink in Annex Room 413	5/24/16 5:00 AM	0.627	BA
232381-1-N02-F-001	nex - 1st Fl. Corridor, Fountain	5/24/16 5:00 AM	1.12	BA
232381-1-N02-F-002	nex - 1st Fl. Corridor, Fountain	5/24/16 5:00 AM	0.605	BA
232381-1-N02-F-003	nex - 1st Fl. Corridor, Fountain	5/24/16 5:00 AM	0.514	BA
232381-1-N02-F-004	nex - 1st Fl. Corridor, Fountain	5/24/16 5:00 AM	0.522	BA
232381-1-N02-F-005	nex - 1st Fl. Corridor, Fountain	5/24/16 5:00 AM	0.547	BA
23281-1-N03-F-001	nex - 1st Fl. Corridor, Fountain	5/24/16 5:00 AM	1.02	BA
23281-1-N03-F-002	nex - 1st Fl. Corridor, Fountain	5/24/16 5:00 AM	0.386	BA

23281-1-N03-F-003	nex - 1st Fl. Corridor, Fountain	5/24/16 5:00 AM	0.332	BA
23281-1-N03-F-004	nex - 1st Fl. Corridor, Fountain	5/24/16 5:00 AM	0.394	BA
23281-1-N03-F-005	nex - 1st Fl. Corridor, Fountain	5/24/16 5:00 AM	0.309	BA
23281-2-N01-F-001	nex 2nd Fl. Corridor, Fountain	5/24/16 5:00 AM	0.81	BA
23281-2-N01-F-002	nex 2nd Fl. Corridor, Fountain	5/24/16 5:00 AM	0.495	BA
23281-2-N01-F-003	nex 2nd Fl. Corridor, Fountain	5/24/16 5:00 AM	0.257	BA
23281-2-N01-F-004	nex 2nd Fl. Corridor, Fountain	5/24/16 5:00 AM	0.259	BA
23281-2-N01-F-005	nex 2nd Fl. Corridor, Fountain	5/24/16 5:00 AM	0.243	BA
23281-2-N02-F-001	nex 2nd Fl. Corridor, Fountain	5/24/16 5:00 AM	2.5	BA
23281-2-N02-F-002	nex 2nd Fl. Corridor, Fountain	5/24/16 5:00 AM	1.7	BA
23281-2-N02-F-003	nex 2nd Fl. Corridor, Fountain	5/24/16 5:00 AM	0.614	BA
23281-2-N02-F-004	nex 2nd Fl. Corridor, Fountain	5/24/16 5:00 AM	0.552	BA
23281-2-N02-F-005	nex 2nd Fl. Corridor, Fountain	5/24/16 5:00 AM	0.435	BA

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit

BA-Below EPA Action Level of 15 ppb

AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations