



School Lead Water Testing - Data Collection Form

School Short Name **Bateman**

Length of time water remained in pipes before sampled (hours)

Report based on lab results dated

Water last used (Time and date)

13.00
4/7/16
05/27/16
Approx 4 PM 5/26/16

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
91046-1-W-501-001	Kitchen Dish Wash Sink 1	5/27/2016 5:00AM	0.527	BA
91046-1-W-501-002	Kitchen Dish Wash Sink 1	5/27/2016 5:00AM	0.153	BA
91046-1-W-501-003	Kitchen Dish Wash Sink 1	5/27/2016 5:00AM	<0.120	ND
91046-1-W-501-004	Kitchen Dish Wash Sink 1	5/27/2016 5:00AM	<0.120	ND
91046-1-W-501-005	Kitchen Dish Wash Sink 1	5/27/2016 5:00AM	<0.120	ND
91046-1-W-502-001	Kitchen Center Sink 2	5/27/2016 5:00AM	0.297	BA
91046-1-W-502-002	Kitchen Center Sink 2	5/27/2016 5:00AM	<0.120	ND
91046-1-W-502-003	Kitchen Center Sink 2	5/27/2016 5:00AM	<0.120	ND
91046-1-W-502-004	Kitchen Center Sink 2	5/27/2016 5:00AM	<0.120	ND
91046-1-W-503-005	Kitchen Center Sink 2	5/27/2016 5:00AM	<0.120	ND
91046-1-W-503-001	Kitchen Food Prep Sink 3	5/27/2016 5:00AM	0.354	BA
91046-1-W-503-002	Kitchen Food Prep Sink 3	5/27/2016 5:00AM	<0.120	ND
91046-1-W-503-003	Kitchen Food Prep Sink 3	5/27/2016 5:00AM	<0.120	ND
91046-1-W-503-004	Kitchen Food Prep Sink 3	5/27/2016 5:00AM	<0.120	ND
91046-1-S-504-001	Room 118 North Sink 2	5/27/2016 5:00AM	<0.120	ND
91046-1-S-504-002	Room 118 North Sink 2	5/27/2016 5:00AM	<0.120	ND
91046-1-S-504-003	Room 118 North Sink 2	5/27/2016 5:00AM	<0.120	ND
91046-1-S-504-004	Room 118 North Sink 2	5/27/2016 5:00AM	<0.120	ND
91046-1-S-504-005	Room 118 North Sink 2	5/27/2016 5:00AM	<0.120	ND
91046-1-S-505-001	Room 119 North Sink 1	5/27/2016 5:00AM	<0.120	ND
91046-1-S-505-002	Room 119 North Sink 1	5/27/2016 5:00AM	<0.120	ND
91046-1-S-505-003	Room 119 North Sink 1	5/27/2016 5:00AM	<0.120	ND
91046-1-S-505-004	Room 119 North Sink 1	5/27/2016 5:00AM	<0.120	ND
91046-1-S-505-005	Room 119 North Sink 1	5/27/2016 5:00AM	<0.120	ND
91046-1-S-P06-001	Room 119 Fountain	5/27/2016 5:00AM	<0.120	ND
91046-1-S-P06-002	Room 119 Fountain	5/27/2016 5:00AM	<0.120	ND
91046-1-S-P06-003	Room 119 Fountain	5/27/2016 5:00AM	<0.120	ND
91046-1-S-P06-004	Room 119 Fountain	5/27/2016 5:00AM	<0.120	ND
91046-1-S-P06-005	Room 119 Fountain	5/27/2016 5:00AM	0.128	BA
91046-1-S-P07-001	***** Addition Outside main Office Fountain 1 *****	5/27/2016 5:00AM	<0.120	ND
91046-1-S-P07-002	Addition Outside main Office Fountain 1	5/27/2016 5:00AM	<0.120	ND
91046-1-S-P07-003	Addition Outside main Office Fountain 1	5/27/2016 5:00AM	<0.120	ND
91046-1-S-P07-004	Addition Outside main Office Fountain 1	5/27/2016 5:00AM	<0.120	ND
91046-1-S-P07-005	Addition Outside main Office Fountain 1	5/27/2016 5:00AM	<0.120	ND
91046-1-S-P08-001	Addition Outside main Office Fountain 2	5/27/2016 5:00AM	<0.120	ND
91046-1-S-P08-002	Addition Outside main Office Fountain 2	5/27/2016 5:00AM	<0.120	ND
91046-1-S-P08-003	Addition Outside main Office Fountain 2	5/27/2016 5:00AM	<0.120	ND
91046-1-S-P08-004	Addition Outside main Office Fountain 2	5/27/2016 5:00AM	<0.120	ND
91046-1-S-P08-005	Addition Outside main Office Fountain 2	5/27/2016 5:00AM	<0.120	ND
91046-1-S-S06-001	Room 128 Pre-K Sink	5/27/2016 5:00AM	<0.120	ND
91046-1-S-S06-002	Room 128 Pre-K Sink	5/27/2016 5:00AM	<0.120	ND
91046-1-S-S06-003	Room 128 Pre-K Sink	5/27/2016 5:00AM	<0.120	ND
91046-1-S-S06-004	Room 128 Pre-K Sink	5/27/2016 5:00AM	<0.120	ND
91046-1-S-S06-005	Room 128 Pre-K Sink	5/27/2016 5:00AM	<0.120	ND
91046-1-S-F10-001	Main Hall Outside Room 108 Fountain	5/27/2016 5:00AM	2.19	BA
91046-1-S-F10-002	Main Hall Outside Room 108 Fountain	5/27/2016 5:00AM	2.05	BA
91046-1-S-F10-003	Main Hall Outside Room 108 Fountain	5/27/2016 5:00AM	1.88	BA
91046-1-S-F10-004	Main Hall Outside Room 108 Fountain	5/27/2016 5:00AM	1.96	BA
91046-1-S-F10-005	Main Hall Outside Room 108 Fountain	5/27/2016 5:00AM	2.04	BA
91046-1-S-F11-001	Main Corridor Outside 107 Fountain	5/27/2016 5:00AM	2.04	BA
91046-1-S-F11-002	Main Corridor Outside 107 Fountain	5/27/2016 5:00AM	1.9	BA
91046-1-S-F11-003	Main Corridor Outside 107 Fountain	5/27/2016 5:00AM	1.98	BA
91046-1-S-F11-004	Main Corridor Outside 107 Fountain	5/27/2016 5:00AM	1.98	BA
91046-1-S-F11-005	Main Corridor Outside 107 Fountain	5/27/2016 5:00AM	1.85	BA
91046-1-N-F12-001	Main Corridor Outside Room 102 Fountain 1	5/27/2016 5:00AM	0.605	BA
91046-1-N-F12-002	Main Corridor Outside Room 102 Fountain	5/27/2016 5:00AM	0.719	BA
91046-1-N-F12-003	Main Corridor Outside Room 102 Fountain 1	5/27/2016 5:00AM	0.735	BA
91046-1-N-F12-004	Main Corridor Outside Room 102 Fountain 1	5/27/2016 5:00AM	0.84	BA
91046-1-N-F12-005	Main Corridor Outside Room 102 Fountain 1	5/27/2016 5:00AM	1.14	BA
91046-1-N-F13-001	Main Corridor Outside Room 102 Fountain 2	5/27/2016 5:00AM	5.901	BA
91046-1-N-F13-002	Main Corridor Outside Room 102 Fountain 2	5/27/2016 5:00AM	1.21	BA
91046-1-N-F13-003	Main Corridor Outside Room 102 Fountain 2	5/27/2016 5:00AM	1.06	BA
91046-1-N-F13-004	Main Corridor Outside Room 102 Fountain 2	5/27/2016 5:00AM	1.04	BA
91046-1-N-F13-005	Main Corridor Outside Room 102 Fountain 2	5/27/2016 5:00AM	0.919	BA
91046-1-S-S14-001	North Sink 1 Inside Room 102	5/27/2016 5:00AM	0.922	BA
91046-1-S-S14-002	North Sink 1 Inside Room 102	5/27/2016 5:00AM	1.41	BA
91046-1-S-S14-003	North Sink 1 Inside Room 102	5/27/2016 5:00AM	0.936	BA
91046-1-S-S14-004	North Sink 1 Inside Room 102	5/27/2016 5:00AM	1.01	BA
91046-1-S-S14-005	North Sink 1 Inside Room 102	5/27/2016 5:00AM	1.1	BA
91046-1-S-S15-001	South Sink 2 Inside Room 102	5/27/2016 5:00AM	0.743	BA
91046-1-S-S15-002	South Sink 2 Inside Room 102	5/27/2016 5:00AM	1.95	BA
91046-1-S-S15-003	South Sink 2 Inside Room 102	5/27/2016 5:00AM	0.877	BA
91046-1-S-S15-004	South Sink 2 Inside Room 102	5/27/2016 5:00AM	1.4	BA
91046-1-S-S15-005	South Sink 2 Inside Room 102	5/27/2016 5:00AM	1.25	BA
91046-1-S-S16-001	Teacher lounge North Sink 1	5/27/2016 5:00AM	0.715	BA
91046-1-S-S16-002	Teacher lounge North Sink 1	5/27/2016 5:00AM	0.619	BA
91046-1-S-S16-003	Teacher lounge North Sink 1	5/27/2016 5:00AM	0.689	BA
91046-1-S-S16-004	Teacher lounge North Sink 1	5/27/2016 5:00AM	0.579	BA
91046-1-S-S16-005	Teacher lounge North Sink 1	5/27/2016 5:00AM	0.64	BA
91046-1-S-S17-001	Teacher lounge South Sink 2	5/27/2016 5:00AM	0.571	BA
91046-1-S-S17-002	Teacher lounge South Sink 2	5/27/2016 5:00AM	0.561	BA
91046-1-S-S17-003	Teacher lounge South Sink 2	5/27/2016 5:00AM	0.548	BA
91046-1-S-S17-004	Teacher lounge South Sink 2	5/27/2016 5:00AM	0.57	BA
91046-1-S-S17-005	Teacher lounge South Sink 2	5/27/2016 5:00AM	0.575	BA
91046-2-N-F01-001	Main Corridor Outside Room 201 Fountain 1	5/27/2016 5:00AM	0.451	BA
91046-2-N-F01-002	Main Corridor Outside Room 201 Fountain	5/27/2016 5:00AM	0.581	BA
91046-2-N-F01-003	Main Corridor Outside Room 201 Fountain	5/27/2016 5:00AM	0.583	BA
91046-2-N-F01-004	Main Corridor Outside Room 201 Fountain 1	5/27/2016 5:00AM	0.532	BA
91046-2-N-F01-005	Main Corridor Outside Room 201 Fountain 1	5/27/2016 5:00AM	0.506	BA
91046-2-N-F02-001	Main Corridor Outside Room 201 Fountain 2	5/27/2016 5:00AM	0.513	BA
91046-2-N-F02-002	Main Corridor Outside Room 201 Fountain 2	5/27/2016 5:00AM	0.579	BA
91046-2-N-F02-003	Main Corridor Outside Room 201 Fountain 2	5/27/2016 5:00AM	0.576	BA
91046-2-N-F02-004	Main Corridor Outside Room 201 Fountain 2	5/27/2016 5:00AM	0.529	BA
91046-2-N-F02-005	Main Corridor Outside Room 201 Fountain 2	5/27/2016 5:00AM	0.454	BA
91046-2-S-F03-001	Main Corridor Outside Room 207 Fountain 1	5/27/2016 5:00AM	0.768	BA
91046-2-S-F03-002	Main Corridor Outside Room 207 Fountain	5/27/2016 5:00AM	0.952	BA
91046-2-S-F03-003	Main Corridor Outside Room 207 Fountain	5/27/2016 5:00AM	1.01	BA
91046-2-S-F03-004	Main Corridor Outside Room 207 Fountain 1	5/27/2016 5:00AM	0.824	BA
91046-2-S-F03-005	Main Corridor Outside Room 207 Fountain 1	5/27/2016 5:00AM	0.74	BA
91046-2-S-F04-001	Main Corridor Outside Room 207 Fountain 2	5/27/2016 5:00AM	0.755	BA
91046-2-S-F04-002	Main Corridor Outside Room 207 Fountain 2	5/27/2016 5:00AM	0.964	BA
91046-2-S-F04-003	Main Corridor Outside Room 207 Fountain 2	5/27/2016 5:00AM	0.559	BA
91046-2-S-F04-004	Main Corridor Outside Room 207 Fountain 2	5/27/2016 5:00AM	0.765	BA
91046-2-S-F04-005	Main Corridor Outside Room 207 Fountain 2	5/27/2016 5:00AM	0.817	BA
91046-2-E-F01-001	Main Corridor Outside Room 220 Fountain 1	5/27/2016 5:00AM	<0.120	ND
91046-2-E-F01-002	Main Corridor Outside Room 220 Fountain 1	5/27/2016 5:00AM	<0.120	ND
91046-2-E-F01-003	Main Corridor Outside Room 220 Fountain 1	5/27/2016 5:00AM	<0.120	ND
91046-2-E-F01-004	Main Corridor Outside Room 220 Fountain 1	5/27/2016 5:00AM	<0.120	ND
91046-2-E-F01-005	Main Corridor Outside Room 220 Fountain 1	5/27/2016 5:00AM	<0.120	ND
91046-2-E-F02-001	Main Corridor Outside Room 220 Fountain 2	5/27/2016 5:00AM	<0.120	ND
91046-2-E-F02-002	Main Corridor Outside Room 220 Fountain 2	5/27/2016 5:00AM	<0.120	ND
91046-2-E-F02-003	Main Corridor Outside Room 220 Fountain 2	5/27/2016 5:00AM	<0.120	ND
91046-2-E-F02-004	Main Corridor Outside Room 220 Fountain 2	5/27/2016 5:00AM	<0.120	ND
91046-2-E-F02-005	Main Corridor Outside Room 220 Fountain 2	5/27/2016 5:00AM	<0.120	ND
91046-3-N-F01-001	Main Corridor Outside Room 301 Fountain	5/27/2016 5:00AM	0.473	BA
91046-3-N-F01-002	Main Corridor Outside Room 301 Fountain	5/27/2016 5:00AM	0.639	BA
91046-3-N-F01-003	Main Corridor Outside Room 301 Fountain	5/27/2016 5:00AM	0.608	BA
91046-3-N-F01-004	Main Corridor Outside Room 301 Fountain	5/27/2016 5:00AM	0.623	BA
91046-3-N-F01-005	Main Corridor Outside Room 301 Fountain	5/27/2016 5:00AM	0.579	BA
91046-3-S-F02-001	Main Corridor Outside Room 307 Fountain	5/27/2016 5:00AM	2.74	BA
91046-3-S-F02-002	Main Corridor Outside Room 307 Fountain	5/27/2016 5:00AM	1.09	BA
91046-3-S-F02-003	Main Corridor Outside Room 307 Fountain	5/27/2016 5:00AM	1.08	BA
91046-3-S-F02-004	Main Corridor Outside Room 307 Fountain	5/27/2016 5:00AM	1.13	BA
91046-3-S-F02-005	Main Corridor Outside Room 307 Fountain	5/27/2016 5:00AM	1.08	BA
91046-3-E-F01-001	Main Corridor Outside Room 318 Fountain 1	5/27/2016 5:00AM	<0.120	ND
91046-3-E-F01-002	Main Corridor Outside Room 318 Fountain 1	5/27/2016 5:00AM	<0.120	ND
91046-3-E-F01-003	Main Corridor Outside Room 318 Fountain 1	5/27/2016 5:00AM	<0.120	ND
91046-3-E-F01-004	Main Corridor Outside Room 318 Fountain 1	5/27/2016 5:00AM	<0.120	ND
91046-3-E-F01-005	Main Corridor Outside Room 318 Fountain 1	5/27/2016 5:00AM	<0.120	ND
91046-3-E-F02-001	Main Corridor Outside Room 318 Fountain 2	5/27/2016 5:00AM	<0.120	ND
91046-3-E-F02-002	Main Corridor Outside Room 318 Fountain 2	5/27/2016 5:00AM	<0.120	ND
91046-3-E-F02-003	Main Corridor Outside Room 318 Fountain 2	5/27/2016 5:00AM	<0.120	ND
91046-3-E-F02-004	Main Corridor Outside Room 318 Fountain 2	5/27/2016 5:00AM	<0.120	ND
91046-3-E-F02-005	Main Corridor Outside Room 318 Fountain 2	5/27/2016 5:00AM	<0.120	ND

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND Not Detected at the Reporting Limit
BA Below EPA Action Level of 15 ppb
AA Above EPA Action Level