



School Lead Water Testing - Data Collection Form

School Short Name **Armstrong G**

Length of time water remained in pipes before sampled (hours)
Report based on lab results dated
Date of test
Water last used (Time and date)

13.00
6/13/16
05/27/16
Approx 4 PM 5/26/16

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
51044-1-F01-E-001	Annex, 1st Floor Hallway, Fountain (1)	5/27/2016 5:00AM	<0.120	ND
51044-1-F01-E-002	Annex, 1st Floor Hallway, Fountain (1)	5/27/2016 5:00AM	<0.120	ND
51044-1-F01-E-003	Annex, 1st Floor Hallway, Fountain (1)	5/27/2016 5:00AM	<0.120	ND
51044-1-F01-E-004	Annex, 1st Floor Hallway, Fountain (1)	5/27/2016 5:00AM	<0.120	ND
51044-1-F01-E-005	Annex, 1st Floor Hallway, Fountain (1)	5/27/2016 5:00AM	<0.120	ND
51044-1-F02-E-001	Annex, 1st Floor Hallway, Fountain (2)	5/27/2016 5:00AM	<0.120	ND
51044-1-F02-E-002	Annex, 1st Floor Hallway, Fountain (2)	5/27/2016 5:00AM	<0.120	ND
51044-1-F02-E-003	Annex, 1st Floor Hallway, Fountain (2)	5/27/2016 5:00AM	1.11	BA
51044-1-F02-E-004	Annex, 1st Floor Hallway, Fountain (2)	5/27/2016 5:00AM	<0.120	ND
51044-1-F02-E-005	Annex, 1st Floor Hallway, Fountain (2)	5/27/2016 5:00AM	<0.120	ND
51044-1-F03-E-001	Annex, Inside Room 116, Fountain	5/27/2016 5:00AM	<0.120	ND
51044-1-F03-E-002	Annex, Inside Room 116, Fountain	5/27/2016 5:00AM	<0.120	ND
51044-1-F03-E-003	Annex, Inside Room 116, Fountain	5/27/2016 5:00AM	<0.120	ND
51044-1-F03-E-004	Annex, Inside Room 116, Fountain	5/27/2016 5:00AM	<0.120	ND
51044-1-F03-E-005	Annex, Inside Room 116, Fountain	5/27/2016 5:00AM	0.121	BA
51044-1-F04-E-001	Annex, Inside Room 115, Fountain	5/27/2016 5:00AM	<0.120	ND
51044-1-F04-E-002	Annex, Inside Room 115, Fountain	5/27/2016 5:00AM	<0.120	ND
51044-1-F04-E-003	Annex, Inside Room 115, Fountain	5/27/2016 5:00AM	<0.120	ND
51044-1-F04-E-004	Annex, Inside Room 115, Fountain	5/27/2016 5:00AM	<0.120	ND
51044-1-F04-E-005	Annex, Inside Room 115, Fountain	5/27/2016 5:00AM	<0.120	ND
51044-1-F05-E-001	Annex, Inside Room 114, Fountain	5/27/2016 5:00AM	<0.120	ND
51044-1-F05-E-002	Annex, Inside Room 114, Fountain	5/27/2016 5:00AM	<0.120	ND
51044-1-F05-E-003	Annex, Inside Room 114, Fountain	5/27/2016 5:00AM	<0.120	ND
51044-1-F05-E-004	Annex, Inside Room 114, Fountain	5/27/2016 5:00AM	<0.120	ND
51044-1-F05-E-005	Annex, Inside Room 114, Fountain	5/27/2016 5:00AM	<0.120	ND
51044-1-F06-E-001	Annex, Inside Room 113, Fountain	5/27/2016 5:00AM	<0.120	ND
51044-1-F06-E-002	Annex, Inside Room 113, Fountain	5/27/2016 5:00AM	<0.120	ND
51044-1-F06-E-003	Annex, Inside Room 113, Fountain	5/27/2016 5:00AM	<0.120	ND
51044-1-F06-E-004	Annex, Inside Room 113, Fountain	5/27/2016 5:00AM	<0.120	ND
51044-1-F06-E-005	Annex, Inside Room 113, Fountain	5/27/2016 5:00AM	<0.120	ND
51044-1-F07-W-001	Annex, Inside Room 112, Fountain	5/27/2016 5:00AM	0.279	BA
51044-1-F07-W-002	Annex, Inside Room 112, Fountain	5/27/2016 5:00AM	<0.120	ND
51044-1-F07-W-003	Annex, Inside Room 112, Fountain	5/27/2016 5:00AM	<0.120	ND
51044-1-F07-W-004	Annex, Inside Room 112, Fountain	5/27/2016 5:00AM	<0.120	ND
51044-1-F08-W-005	Annex, Inside Room 111, Fountain	5/27/2016 5:00AM	<0.120	ND
51044-1-F08-W-001	Annex, Inside Room 111, Fountain	5/27/2016 5:00AM	0.125	BA
51044-1-F08-W-002	Annex, Inside Room 111, Fountain	5/27/2016 5:00AM	<0.120	ND
51044-1-F08-W-003	Annex, Inside Room 111, Fountain	5/27/2016 5:00AM	<0.120	ND
51044-1-F08-W-004	Annex, Inside Room 111, Fountain	5/27/2016 5:00AM	<0.120	ND
51044-1-F08-W-005	Annex, Inside Room 111, Fountain	5/27/2016 5:00AM	<0.120	ND
51044-1-F09-W-001	Annex, Inside Room 110, Fountain	5/27/2016 5:00AM	<0.120	ND
51044-1-F09-W-002	Annex, Inside Room 110, Fountain	5/27/2016 5:00AM	<0.120	ND
51044-1-F09-W-003	Annex, Inside Room 110, Fountain	5/27/2016 5:00AM	<0.120	ND
51044-1-F09-W-004	Annex, Inside Room 110, Fountain	5/27/2016 5:00AM	<0.120	ND
51044-1-F09-W-005	Annex, Inside Room 110, Fountain	5/27/2016 5:00AM	<0.120	ND
51044-2-F01-E-001	Annex, 2nd Floor Hallway, Fountain (1)	5/27/2016 5:00AM	0.125	BA
51044-2-F01-E-002	Annex, 2nd Floor Hallway, Fountain (1)	5/27/2016 5:00AM	<0.120	ND
51044-2-F01-E-003	Annex, 2nd Floor Hallway, Fountain (1)	5/27/2016 5:00AM	<0.120	ND
51044-2-F01-E-004	Annex, 2nd Floor Hallway, Fountain (1)	5/27/2016 5:00AM	<0.120	ND
51044-2-F01-E-005	Annex, 2nd Floor Hallway, Fountain (1)	5/27/2016 5:00AM	<0.120	ND
51044-2-F02-E-001	Annex, 2nd Floor Hallway, Fountain (2)	5/27/2016 5:00AM	<0.120	ND
51044-2-F02-E-002	Annex, 2nd Floor Hallway, Fountain (2)	5/27/2016 5:00AM	<0.120	ND
51044-2-F02-E-003	Annex, 2nd Floor Hallway, Fountain (2)	5/27/2016 5:00AM	<0.120	ND
51044-2-F02-E-004	Annex, 2nd Floor Hallway, Fountain (2)	5/27/2016 5:00AM	<0.120	ND
51044-2-F02-E-005	Annex, 2nd Floor Hallway, Fountain (2)	5/27/2016 5:00AM	<0.120	ND
51044-3-F01-E-001	Annex, 3rd Floor Hallway, Fountain (1)	5/27/2016 5:00AM	<0.120	ND
51044-3-F01-E-002	Annex, 3rd Floor Hallway, Fountain (1)	5/27/2016 5:00AM	<0.120	ND
51044-3-F01-E-003	Annex, 3rd Floor Hallway, Fountain (1)	5/27/2016 5:00AM	<0.120	ND
51044-3-F01-E-004	Annex, 3rd Floor Hallway, Fountain (1)	5/27/2016 5:00AM	<0.120	ND
51044-3-F01-E-005	Annex, 3rd Floor Hallway, Fountain (1)	5/27/2016 5:00AM	<0.120	ND
51044-3-F02-E-001	Annex, 3rd Floor Hallway, Fountain (2)	5/27/2016 5:00AM	<0.120	ND
51044-3-F02-E-002	Annex, 3rd Floor Hallway, Fountain (2)	5/27/2016 5:00AM	<0.120	ND
51044-3-F02-E-003	Annex, 3rd Floor Hallway, Fountain (2)	5/27/2016 5:00AM	<0.120	ND
51044-3-F02-E-004	Annex, 3rd Floor Hallway, Fountain (2)	5/27/2016 5:00AM	<0.120	ND
51044-3-F02-E-005	Annex, 3rd Floor Hallway, Fountain (2)	5/27/2016 5:00AM	<0.120	ND
51044-1-F01-N-001	Main Building, 1st Floor Hallway North, Fountain	5/27/2016 5:00AM	2.43	BA
51044-1-F01-N-002	Main Building, 1st Floor Hallway North, Fountain	5/27/2016 5:00AM	2.37	BA
51044-1-F01-N-003	Main Building, 1st Floor Hallway North, Fountain	5/27/2016 5:00AM	1.28	BA
51044-1-F01-N-004	Main Building, 1st Floor Hallway North, Fountain	5/27/2016 5:00AM	0.756	BA
51044-1-F01-N-005	Main Building, 1st Floor Hallway North, Fountain	5/27/2016 5:00AM	2.78	BA
51044-1-F02-S-001	Main Building, 1st Floor Hallway South, Fountain	5/27/2016 5:00AM	3.09	BA
51044-1-F02-S-002	Main Building, 1st Floor Hallway South, Fountain	5/27/2016 5:00AM	2.1	BA
51044-1-F02-S-003	Main Building, 1st Floor Hallway South, Fountain	5/27/2016 5:00AM	1.27	BA
51044-1-F02-S-004	Main Building, 1st Floor Hallway South, Fountain	5/27/2016 5:00AM	1.3	BA
51044-1-F02-S-005	Main Building, 1st Floor Hallway South, Fountain	5/27/2016 5:00AM	1.52	BA
51044-2-F01-N-001	Main Building, 2nd Floor Hallway North, Fountain	5/27/2016 5:00AM	0.389	BA
51044-2-F01-N-002	Main Building, 2nd Floor Hallway North, Fountain	5/27/2016 5:00AM	<0.120	ND
51044-2-F01-N-003	Main Building, 2nd Floor Hallway North, Fountain	5/27/2016 5:00AM	0.414	BA
51044-2-F01-N-004	Main Building, 2nd Floor Hallway North, Fountain	5/27/2016 5:00AM	0.184	BA
51044-2-F01-N-005	Main Building, 2nd Floor Hallway North, Fountain	5/27/2016 5:00AM	0.25	BA
51044-2-F02-S-001	Main Building, 2nd Floor Hallway South, Fountain	5/27/2016 5:00AM	0.141	BA
51044-2-F02-S-002	Main Building, 2nd Floor Hallway South, Fountain	5/27/2016 5:00AM	<0.120	ND
51044-2-F02-S-003	Main Building, 2nd Floor Hallway South, Fountain	5/27/2016 5:00AM	0.224	BA
51044-2-F02-S-004	Main Building, 2nd Floor Hallway South, Fountain	5/27/2016 5:00AM	0.607	BA
51044-2-F02-S-005	Main Building, 2nd Floor Hallway South, Fountain	5/27/2016 5:00AM	0.132	BA
51044-3-F01-N-001	Main Building, 3rd Floor Hallway North, Fountain	5/27/2016 5:00AM	0.144	BA
51044-3-F01-N-002	Main Building, 3rd Floor Hallway North, Fountain	5/27/2016 5:00AM	0.229	BA
51044-3-F01-N-003	Main Building, 3rd Floor Hallway North, Fountain	5/27/2016 5:00AM	0.442	BA
51044-3-F01-N-004	Main Building, 3rd Floor Hallway North, Fountain	5/27/2016 5:00AM	0.225	BA
51044-3-F01-N-005	Main Building, 3rd Floor Hallway North, Fountain	5/27/2016 5:00AM	0.177	BA
51044-3-F02-S-001	Main Building, 3rd Floor Hallway South, Fountain	5/27/2016 5:00AM	<0.120	ND
51044-3-F02-S-002	Main Building, 3rd Floor Hallway South, Fountain	5/27/2016 5:00AM	<0.120	ND
51044-3-F02-S-003	Main Building, 3rd Floor Hallway South, Fountain	5/27/2016 5:00AM	<0.120	ND
51044-3-F02-S-004	Main Building, 3rd Floor Hallway South, Fountain	5/27/2016 5:00AM	<0.120	ND
51044-3-F02-S-005	Main Building, 3rd Floor Hallway South, Fountain	5/27/2016 5:00AM	<0.120	ND
51044-1-S01-S-001	Annex, Kitchen 3 Comp, Sink	5/27/2016 5:00AM	<0.120	ND
51044-1-S01-S-002	Annex, Kitchen 3 Comp, Sink	5/27/2016 5:00AM	<0.120	ND
51044-1-S01-S-003	Annex, Kitchen 3 Comp, Sink	5/27/2016 5:00AM	<0.120	ND
51044-1-S01-S-004	Annex, Kitchen 3 Comp, Sink	5/27/2016 5:00AM	<0.120	ND
51044-1-S02-S-001	Annex, Kitchen 2 Comp, Sink	5/27/2016 5:00AM	0.85	BA
51044-1-S02-S-002	Annex, Kitchen 2 Comp, Sink	5/27/2016 5:00AM	1.32	BA
51044-1-S02-S-003	Annex, Kitchen 2 Comp, Sink	5/27/2016 5:00AM	<0.120	ND
51044-1-S02-S-004	Annex, Kitchen 2 Comp, Sink	5/27/2016 5:00AM	<0.120	ND
51044-1-S02-S-005	Annex, Kitchen 2 Comp, Sink	5/27/2016 5:00AM	<0.120	ND
51044-1-SK03-S-001	Annex, Kitchen Steam Kettle, Sink	5/27/2016 5:00AM	<0.120	ND
51044-1-SK03-S-002	Annex, Kitchen Steam Kettle, Sink	5/27/2016 5:00AM	0.4	BA
51044-1-SK03-S-003	Annex, Kitchen Steam Kettle, Sink	5/27/2016 5:00AM	<0.120	ND
51044-1-SK03-S-004	Annex, Kitchen Steam Kettle, Sink	5/27/2016 5:00AM	0.197	BA
51044-1-SK03-S-005	Annex, Kitchen Steam Kettle, Sink	5/27/2016 5:00AM	0.211	BA
51044-1-S04-S-001	Annex, Kitchen Pasta Cover, Sink	5/27/2016 5:00AM	0.254	BA
51044-1-S04-S-002	Annex, Kitchen Pasta Cover, Sink	5/27/2016 5:00AM	<0.120	ND
51044-1-S04-S-003	Annex, Kitchen Pasta Cover, Sink	5/27/2016 5:00AM	<0.120	ND
51044-1-S04-S-004	Annex, Kitchen Pasta Cover, Sink	5/27/2016 5:00AM	<0.120	ND
51044-1-S04-S-005	Annex, Kitchen Pasta Cover, Sink	5/27/2016 5:00AM	<0.120	ND

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND
ND-Not Detected at the Reporting Limit
BA-Below EPA Action Level of 15 ppb
AA-Above EPA Action Level