



School Lead Water Testing Summary

School Short Name [Jackson](#)
Address [917 W. 88th](#)
Facility ID [51454](#)
CPS Team Member [Prins Sales](#)
MEC Team Member [Todd Huffer](#)

Length of time water remained in pipes before sampled [Approx 13-14 hours](#)
Water last used (Time and date) [Approx 5 PM 5/4/16](#)
Date of test [5/5/2016](#)
Report based on lab results dated [5/13/2016](#)

Sample ID #	Sample Location	Sample Collection Time & Date	Test Results (ppb)	ppb Level
51454-1-W-CS-01	Kitchen	6:41 AM 5/5/16	ND	-
51454-1-S-F-02	Hallway by Gym	6:43 AM 5/5/16	ND	-
51454-1-S-F-03	Hallway by Room 142	6:45 AM 5/5/16	ND	-
51454-2-S-F-04	Hallway by Library	6:50 AM 5/5/16	ND	-
51454-3-S-F-05	Hallway by Room 306	6:55 AM 5/5/16	ND	-

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit
BA-Below EPA Action Level of 15 ppb
AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations