



School Lead Water Testing - Data Collection Form

School Short Name **Gary**

Sample ID #	Sample Location	Water Last Used (Time & Date)	Sample Collection Time & Date	Test Result (ppb)	Test Results
1-S-F01-01	1st FL - S. Hall across from Room 108	6/3/16 10:00 PM	6/4/16 6:40 AM	None Detected	ND
1-S-F01-02	1st FL - S. Hall across from Room 108	6/3/16 10:00 PM	6/4/16 6:40 AM	None Detected	ND
1-S-F01-03	1st FL - S. Hall across from Room 108	6/3/16 10:00 PM	6/4/16 6:40 AM	None Detected	ND
1-S-F01-04	1st FL - S. Hall across from Room 108	6/3/16 10:00 PM	6/4/16 6:40 AM	None Detected	ND
1-S-F01-05	1st FL - S. Hall across from Room 108	6/3/16 10:00 PM	6/4/16 6:40 AM	None Detected	ND
1-N-F01-01	1st FL - N. Hall	8/11/16 10:00 PM	8/12/16 9:30 AM	0.142	BA
1-N-F01-02	1st FL - N. Hall	8/11/16 10:00 PM	8/12/16 9:30 AM	0.136	BA
1-N-F01-03	1st FL - N. Hall	8/11/16 10:00 PM	8/12/16 9:30 AM	0.224	BA
1-N-F01-04	1st FL - N. Hall	8/11/16 10:00 PM	8/12/16 9:30 AM	<0.120	BA
1-N-F01-05	1st FL - N. Hall	8/11/16 10:00 PM	8/12/16 9:30 AM	0.231	BA
1-N-F02-11	1st FL - N. Hall	6/3/16 10:00 PM	6/4/16 6:44 AM	None Detected	ND
1-N-F02-12	1st FL - N. Hall	6/3/16 10:00 PM	6/4/16 6:44 AM	None Detected	ND
1-N-F02-13	1st FL - N. Hall	6/3/16 10:00 PM	6/4/16 6:44 AM	None Detected	ND
1-N-F02-14	1st FL - N. Hall	6/3/16 10:00 PM	6/4/16 6:44 AM	None Detected	ND
1-N-F02-15	1st FL - N. Hall	6/3/16 10:00 PM	6/4/16 6:44 AM	None Detected	ND
B-S-CS01-16	Kitchen	6/3/16 10:00 PM	6/4/16 7:01 AM	None Detected	ND
B-S-CS01-17	Kitchen	6/3/16 10:00 PM	6/4/16 7:01 AM	None Detected	ND
B-S-CS01-18	Kitchen	6/3/16 10:00 PM	6/4/16 7:01 AM	None Detected	ND
B-S-CS01-19	Kitchen	6/3/16 10:00 PM	6/4/16 7:01 AM	None Detected	ND
B-S-CS01-20	Kitchen	6/3/16 10:00 PM	6/4/16 7:01 AM	None Detected	ND
B-S-CS02-21	Kitchen	6/3/16 10:00 PM	6/4/16 7:02 AM	None Detected	ND
B-S-CS02-22	Kitchen	6/3/16 10:00 PM	6/4/16 7:02 AM	None Detected	ND
B-S-CS02-23	Kitchen	6/3/16 10:00 PM	6/4/16 7:02 AM	None Detected	ND
B-S-CS02-24	Kitchen	6/3/16 10:00 PM	6/4/16 7:02 AM	None Detected	ND
B-S-CS02-25	Kitchen	6/3/16 10:00 PM	6/4/16 7:02 AM	None Detected	ND
2-S-F01-26	2nd FL Across Room 210	6/3/16 10:00 PM	6/4/16 7:09 AM	None Detected	ND
2-S-F01-27	2nd FL Across Room 210	6/3/16 10:00 PM	6/4/16 7:09 AM	None Detected	ND
2-S-F01-28	2nd FL Across Room 210	6/3/16 10:00 PM	6/4/16 7:09 AM	None Detected	ND
2-S-F01-29	2nd FL Across Room 210	6/3/16 10:00 PM	6/4/16 7:09 AM	None Detected	ND
2-S-F01-30	2nd FL Across Room 210	6/3/16 10:00 PM	6/4/16 7:09 AM	None Detected	ND
2-S-F02-31	2nd FL - Across from Room 210	6/3/16 10:00 PM	6/4/16 7:10 AM	None Detected	ND
2-S-F02-32	2nd FL - Across from Room 210	6/3/16 10:00 PM	6/4/16 7:10 AM	None Detected	ND
2-S-F02-33	2nd FL - Across from Room 210	6/3/16 10:00 PM	6/4/16 7:10 AM	None Detected	ND
2-S-F02-34	2nd FL - Across from Room 210	6/3/16 10:00 PM	6/4/16 7:10 AM	None Detected	ND
2-S-F02-35	2nd FL - Across from Room 210	6/3/16 10:00 PM	6/4/16 7:10 AM	None Detected	ND
2-N-F01-36	2nd FL - Across from Room 200	6/3/16 10:00 PM	6/4/16 7:15 AM	None Detected	ND
2-N-F01-37	2nd FL - Across from Room 200	6/3/16 10:00 PM	6/4/16 7:15 AM	None Detected	ND
2-N-F01-38	2nd FL - Across from Room 200	6/3/16 10:00 PM	6/4/16 7:15 AM	None Detected	ND
2-N-F01-39	2nd FL - Across from Room 200	6/3/16 10:00 PM	6/4/16 7:15 AM	None Detected	ND
2-N-F01-40	2nd FL - Across from Room 200	6/3/16 10:00 PM	6/4/16 7:15 AM	None Detected	ND
2-N-F02-06	Hallway by Room 200	8/11/16 10:00 PM	8/12/16 9:35 AM	0.36	BA
2-N-F02-07	Hallway by Room 200	8/11/16 10:00 PM	8/12/16 9:35 AM	0.512	BA
2-N-F02-08	Hallway by Room 200	8/11/16 10:00 PM	8/12/16 9:35 AM	0.442	BA

2-N-F02-09	Hallway by Room 200	8/11/16 10:00 PM	8/12/16 9:35 AM	0.502	BA
2-N-F02-10	Hallway by Room 200	8/11/16 10:00 PM	8/12/16 9:35 AM	0.373	BA
3-S-F01-46	3rd FL Across from Room 308	6/3/16 10:00 PM	6/4/16 7:28 AM	None Detected	ND
3-S-F01-47	3rd FL Across from Room 308	6/3/16 10:00 PM	6/4/16 7:28 AM	None Detected	ND
3-S-F01-48	3rd FL Across from Room 308	6/3/16 10:00 PM	6/4/16 7:28 AM	None Detected	ND
3-S-F01-49	3rd FL Across from Room 308	6/3/16 10:00 PM	6/4/16 7:28 AM	None Detected	ND
3-S-F01-50	3rd FL Across from Room 308	6/3/16 10:00 PM	6/4/16 7:28 AM	None Detected	ND
3-S-F02-51	3rd FL Across from Room 308	6/3/16 10:00 PM	6/4/16 7:29 AM	None Detected	ND
3-S-F02-52	3rd FL Across from Room 308	6/3/16 10:00 PM	6/4/16 7:29 AM	None Detected	ND
3-S-F02-53	3rd FL Across from Room 308	6/3/16 10:00 PM	6/4/16 7:29 AM	None Detected	ND
3-S-F02-54	3rd FL Across from Room 308	6/3/16 10:00 PM	6/4/16 7:29 AM	None Detected	ND
3-S-F02-55	3rd FL Across from Room 308	6/3/16 10:00 PM	6/4/16 7:29 AM	None Detected	ND
1-N-F01-01	N Hall - Center by Restrooms	6/3/16 10:00 PM	6/4/16 7:45 AM	None Detected	ND
1-N-F01-02	N Hall - Center by Restrooms	6/3/16 10:00 PM	6/4/16 7:45 AM	None Detected	ND
1-N-F01-03	N Hall - Center by Restrooms	6/3/16 10:00 PM	6/4/16 7:45 AM	None Detected	ND
1-N-F01-04	N Hall - Center by Restrooms	6/3/16 10:00 PM	6/4/16 7:45 AM	None Detected	ND
1-N-F01-05	N Hall - Center by Restrooms	6/3/16 10:00 PM	6/4/16 7:45 AM	None Detected	ND
1-S-F01-01	1st FL Hall by Bathroom - S. End.	6/3/16 10:00 PM	6/4/16 7:45 AM	None Detected	ND
1-S-F01-02	1st FL Hall by Bathroom - S. End.	6/3/16 10:00 PM	6/4/16 7:45 AM	None Detected	ND
1-S-F01-03	1st FL Hall by Bathroom - S. End.	6/3/16 10:00 PM	6/4/16 7:45 AM	None Detected	ND
1-S-F01-04	1st FL Hall by Bathroom - S. End.	6/3/16 10:00 PM	6/4/16 7:45 AM	None Detected	ND
1-S-F01-05	1st FL Hall by Bathroom - S. End.	6/3/16 10:00 PM	6/4/16 7:45 AM	None Detected	ND
1-N-F01-06	1st FL Hall by Bathroom - N. End	6/3/16 10:00 PM	6/4/16 7:46 AM	None Detected	ND
1-N-F01-07	1st FL Hall by Bathroom - N. End	6/3/16 10:00 PM	6/4/16 7:46 AM	None Detected	ND
1-N-F01-08	1st FL Hall by Bathroom - N. End	6/3/16 10:00 PM	6/4/16 7:46 AM	None Detected	ND
1-N-F01-09	1st FL Hall by Bathroom - N. End	6/3/16 10:00 PM	6/4/16 7:46 AM	None Detected	ND
1-N-F01-10	1st FL Hall by Bathroom - N. End	6/3/16 10:00 PM	6/4/16 7:46 AM	None Detected	ND
2-N-F01-11	2nd Floor Hallway - North End	6/3/16 10:00 PM	6/4/16 8:24 AM	None Detected	ND
2-N-F01-12	2nd Floor Hallway - North End	6/3/16 10:00 PM	6/4/16 8:24 AM	None Detected	ND
2-N-F01-13	2nd Floor Hallway - North End	6/3/16 10:00 PM	6/4/16 8:24 AM	None Detected	ND
2-N-F01-14	2nd Floor Hallway - North End	6/3/16 10:00 PM	6/4/16 8:24 AM	None Detected	ND
2-N-F01-15	2nd Floor Hallway - North End	6/3/16 10:00 PM	6/4/16 8:24 AM	None Detected	ND
2-S-F01-16	2nd Floor Hallway - South End	6/3/16 10:00 PM	6/4/16 8:23 AM	None Detected	ND
2-S-F01-17	2nd Floor Hallway - South End	6/3/16 10:00 PM	6/4/16 8:23 AM	None Detected	ND
2-S-F01-18	2nd Floor Hallway - South End	6/3/16 10:00 PM	6/4/16 8:23 AM	None Detected	ND
2-S-F01-19	2nd Floor Hallway - South End	6/3/16 10:00 PM	6/4/16 8:23 AM	None Detected	ND
2-S-F01-20	2nd Floor Hallway - South End	6/3/16 10:00 PM	6/4/16 8:23 AM	None Detected	ND

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit

BA-Below EPA Action Level of 15 ppb

AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations