



School Lead Water Testing Summary

School Short Name **Ericson**
Address 3600 W. 5th Ave.
Facility ID 51201
CPS Team Member Prins Sales
MEC Team Member Roxana Ordonez

Length of time water remained in pipes before sampled [Approx. 9 hours](#)
Water last used (Time and date) [Approx. 9pm 4/26/16](#)
Date of test [4/27/2016](#)
Report based on lab results dated [5/2/2016](#)

Sample ID #	Sample Location	Sample Collection Time & Date	Test Results (ppb)	ppb Level
51201-N-CS-01	Kitchen	6:30 AM 4/27/16	ND	-
51201-1-NE-WC-02	Outside Gym	6:32 AM 4/27/16	ND	-
51201-1-SW-WC-03	Hallway by Room 105	6:37 AM 4/27/16	ND	-
51201-2-SW-WC-04	Hallway by Room 205	6:41 AM 4/27/16	ND	-
51201-2-NE-WC-05	Hallway by Room 206	6:45 AM 4/27/16	ND	-

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit
BA-Below EPA Action Level of 15 ppb
AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations