



July 12, 2016

Dear CPS family,

In light of national events that have brought increased attention to the issue of water quality, the City of Chicago announced several additional precautionary measures that will be added to the City's water testing protocol, continuing the City's track record of complying with current state and federal regulations as well as exceeding industry standards.

As part of this announcement, Chicago Public Schools (CPS) began testing the water for levels of lead from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe. Schools are being tested based on a priority criteria that includes the age of the school, age of the students (with priority given to schools with pre-K programs), presence of a kitchen (where meals are prepared) and presence of pipes that could need repairs or replacement.

The results of all the schools are coming in on a rolling basis, and the majority have had levels under the EPA's action level of 15 parts per billion (ppb). We wanted to let you know that no lead was found above the action level in your child's school. The full results of your school's water samples can be found online at cps.edu/leadtesting.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician for testing. Additionally, CDPH's lead hotline can address any health related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

Forrest Claypool
CEO, Chicago Public Schools

Dr. Julie Morita
Commissioner, Chicago Department of Public Health





12 de julio de 2016

Estimadas familias de CPS,

Ante los eventos nacionales que han incrementado la atención en el tema de la calidad del agua, la Alcaldía de Chicago anunció varias medidas adicionales de precaución que serán agregadas al protocolo de prueba del agua de la ciudad, continuando con el cumplimiento de las regulaciones estatales y federales, que exceden los estándares industriales.

Como parte de este anuncio, las Escuelas Públicas de Chicago (CPS) comenzaron a medir los niveles de plomo en el agua de todas las escuelas del distrito. Nuestra principal prioridad es la salud y seguridad de todos nuestros estudiantes y personal, y estas pruebas fueron iniciadas solamente para extremar las precauciones y estar seguros de que el agua es segura. Las escuelas son examinadas con base a un criterio de prioridad que incluye la antigüedad del edificio, edad de los estudiantes (con prioridad para las escuelas con programas preescolares), presencia de una cocina (donde se preparan alimentos) y la presencia de cañerías que necesiten reparación o reemplazo.

Los resultados de todas las escuelas se están conociendo, y la mayoría ha registrado niveles por debajo del nivel de acción de la EPA, que es de 15 partículas por billón (ppb). Queremos hacerles saber que no se encontraron rastros de plomo por encima del nivel de acción en la escuela de su niño. Los resultados completos de las pruebas en su escuela se pueden ver en línea en cps.edu/leadtesting.

Los lineamientos federales indican que los niños menores de seis años son los que corren mayores riesgos con la exposición al plomo, algo que puede ocurrir de varias fuentes, incluyendo pintura, tierra y algunos productos de consumo. Si están preocupados por la posible exposición de su hijo al plomo, el Departamento de Salud Pública de la ciudad de Chicago (CDPH) recomienda visitar a su pediatra o a alguno de los centros de salud listados en el material adjunto, para una prueba. Además, la línea directa del CDPH puede responder cualquier pregunta que tengan, o ayudarlos a decidir si su niño debe ser examinado; por preguntas o más información, llame por favor al 312-747-5323. Por información adicional sobre el plomo y los niños, visite www.cdc.gov/lead.

La seguridad de sus hijos es nuestra principal prioridad, y hacemos todo lo que está en nuestro poder para resolver esta situación de una manera rápida y rigurosa. Continuaremos informándoles sobre este proceso.

Atentamente,

Forrest Claypool
CEO, Escuelas Públicas de Chicago

Dra. Julie Morita, Comisionada
Departamento de Salud Pública de Chicago





School Lead Water Testing - Data Collection Form

School Name **Bass**

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
51373-B-N-F01-001	Main- Outside Room 008, North Fountain 1	6/10/16 5:00 AM	2.88	BA
51373-B-N-F01-002	Main- Outside Room 008, North Fountain 1	6/10/16 5:00 AM	3.03	BA
51373-B-N-F01-003	Main- Outside Room 008, North Fountain 1	6/10/16 5:00 AM	3.2	BA
51373-B-N-F01-004	Main- Outside Room 008, North Fountain 1	6/10/16 5:00 AM	2.94	BA
51373-B-N-F01-005	Main- Outside Room 008, North Fountain 1	6/10/16 5:00 AM	2.85	BA
51373-B-N-F02-001	Main- Outside Room 008, North Center Fountain 2	6/10/16 5:00 AM	3.05	BA
51373-B-N-F02-002	Main- Outside Room 008, North Center Fountain 2	6/10/16 5:00 AM	3.13	BA
51373-B-N-F02-003	Main- Outside Room 008, North Center Fountain 2	6/10/16 5:00 AM	3	BA
51373-B-N-F02-004	Main- Outside Room 008, North Center Fountain 2	6/10/16 5:00 AM	2.89	BA
51373-B-N-F02-005	Main- Outside Room 008, North Center Fountain 2	6/10/16 5:00 AM	2.82	BA
51373-B-S-F03-001	Main- Outside Room 008, South Center Fountain 3	6/10/16 5:00 AM	2.65	BA
51373-B-S-F03-002	Main- Outside Room 008, South Center Fountain 3	6/10/16 5:00 AM	2.41	BA
51373-B-S-F03-003	Main- Outside Room 008, South Center Fountain 3	6/10/16 5:00 AM	2.15	BA
51373-B-S-F03-004	Main- Outside Room 008, South Center Fountain 3	6/10/16 5:00 AM	2.05	BA
51373-B-S-F03-005	Main- Outside Room 008, South Center Fountain 3	6/10/16 5:00 AM	2.04	BA
51373-B-S-F04-001	Main- Outside Room 008, South Fountain 4	6/10/16 5:00 AM	2.19	BA
51373-B-S-F04-002	Main- Outside Room 008, South Fountain 4	6/10/16 5:00 AM	2	BA
51373-B-S-F04-003	Main- Outside Room 008, South Fountain 4	6/10/16 5:00 AM	1.88	BA
51373-B-S-F04-004	Main- Outside Room 008, South Fountain 4	6/10/16 5:00 AM	1.77	BA
51373-B-S-F04-005	Main- Outside Room 008, South Fountain 4	6/10/16 5:00 AM	1.76	BA
51373-1-N-F01-001	Main- Outside Principal's Office, North Fountain 1	6/10/16 5:00 AM	0.906	BA
51373-1-N-F01-002	Main- Outside Principal's Office, North Fountain 1	6/10/16 5:00 AM	0.719	BA
51373-1-N-F01-003	Main- Outside Principal's Office, North Fountain 1	6/10/16 5:00 AM	0.646	BA
51373-1-N-F01-004	Main- Outside Principal's Office, North Fountain 1	6/10/16 5:00 AM	0.677	BA
51373-1-N-F01-005	Main- Outside Principal's Office, North Fountain 1	6/10/16 5:00 AM	0.656	BA
51373-1-S-F02-001	Main- Outside Principal's Office, South Fountain 2	6/10/16 5:00 AM	0.889	BA
51373-1-S-F02-002	Main- Outside Principal's Office, South Fountain 2	6/10/16 5:00 AM	0.989	BA
51373-1-S-F02-003	Main- Outside Principal's Office, South Fountain 2	6/10/16 5:00 AM	0.988	BA
51373-1-S-F02-004	Main- Outside Principal's Office, South Fountain 2	6/10/16 5:00 AM	0.852	BA
51373-1-S-F02-005	Main- Outside Principal's Office, South Fountain 2	6/10/16 5:00 AM	0.841	BA
51373-2-N-F01-001	Main- Outside Room 203, North Fountain 1	6/10/16 5:00 AM	0.94	BA
51373-2-N-F01-002	Main- Outside Room 203, North Fountain 1	6/10/16 5:00 AM	0.691	BA
51373-2-N-F01-003	Main- Outside Room 203, North Fountain 1	6/10/16 5:00 AM	0.46	BA
51373-2-N-F01-004	Main- Outside Room 203, North Fountain 1	6/10/16 5:00 AM	0.505	BA
51373-2-N-F01-005	Main- Outside Room 203, North Fountain 1	6/10/16 5:00 AM	0.586	BA
51373-2-S-F02-001	Main- Outside Room 203, South Fountain 2	6/10/16 5:00 AM	0.589	BA
51373-2-S-F02-002	Main- Outside Room 203, South Fountain 2	6/10/16 5:00 AM	0.666	BA
51373-2-S-F02-003	Main- Outside Room 203, South Fountain 2	6/10/16 5:00 AM	0.623	BA
51373-2-S-F02-004	Main- Outside Room 203, South Fountain 2	6/10/16 5:00 AM	0.663	BA
51373-2-S-F02-005	Main- Outside Room 203, South Fountain 2	6/10/16 5:00 AM	0.623	BA
51373-3-N-F01-001	Main- Outside Room 303, North Fountain 1	6/10/16 5:00 AM	2.24	BA
51373-3-N-F01-002	Main- Outside Room 303, North Fountain 1	6/10/16 5:00 AM	1.1	BA
51373-3-N-F01-003	Main- Outside Room 303, North Fountain 1	6/10/16 5:00 AM	1.02	BA
51373-3-N-F01-004	Main- Outside Room 303, North Fountain 1	6/10/16 5:00 AM	1.02	BA
51373-3-N-F01-005	Main- Outside Room 303, North Fountain 1	6/10/16 5:00 AM	1	BA
51373-3-S-F02-001	Main- Outside Room 303, South Fountain 2	6/10/16 5:00 AM	2.02	BA
51373-3-S-F02-002	Main- Outside Room 303, South Fountain 2	6/10/16 5:00 AM	1.54	BA
51373-3-S-F02-003	Main- Outside Room 303, South Fountain 2	6/10/16 5:00 AM	1.01	BA
51373-3-S-F02-004	Main- Outside Room 303, South Fountain 2	6/10/16 5:00 AM	0.885	BA
51373-3-S-F02-005	Main- Outside Room 303, South Fountain 2	6/10/16 5:00 AM	0.849	BA
51373-1-W-S01-001	Annex- Kitchen North Wall, East Sink 1	6/10/16 5:00 AM	0.294	BA
51373-1-W-S01-002	Annex- Kitchen North Wall, East Sink 1	6/10/16 5:00 AM	<0.120	ND
51373-1-W-S01-003	Annex- Kitchen North Wall, East Sink 1	6/10/16 5:00 AM	0.168	BA
51373-1-W-S01-004	Annex- Kitchen North Wall, East Sink 1	6/10/16 5:00 AM	0.174	BA
51373-1-W-S01-005	Annex- Kitchen North Wall, East Sink 1	6/10/16 5:00 AM	0.126	BA
51373-1-W-S02-001	Annex- Kitchen North Wall, West Sink 2	6/10/16 5:00 AM	0.435	BA
51373-1-W-S02-002	Annex- Kitchen North Wall, West Sink 2	6/10/16 5:00 AM	0.344	BA
51373-1-W-S02-003	Annex- Kitchen North Wall, West Sink 2	6/10/16 5:00 AM	0.161	BA
51373-1-W-S02-004	Annex- Kitchen North Wall, West Sink 2	6/10/16 5:00 AM	0.152	BA
51373-1-W-S02-005	Annex- Kitchen North Wall, West Sink 2	6/10/16 5:00 AM	<0.120	ND
51373-1-N-F03-001	Annex- Outside Toilets, Fountain	6/10/16 5:00 AM	0.748	BA
51373-1-N-F03-002	Annex- Outside Toilets, Fountain	6/10/16 5:00 AM	0.496	BA
51373-1-N-F03-003	Annex- Outside Toilets, Fountain	6/10/16 5:00 AM	0.418	BA
51373-1-N-F03-004	Annex- Outside Toilets, Fountain	6/10/16 5:00 AM	0.277	BA
51373-1-N-F03-005	Annex- Outside Toilets, Fountain	6/10/16 5:00 AM	0.205	BA
51373-1-S-S04-001	Annex- Inside Pre-Kindergarten Room 112, Sink	6/10/16 5:00 AM	0.826	BA
51373-1-S-S04-002	Annex- Inside Pre-Kindergarten Room 112, Sink	6/10/16 5:00 AM	0.828	BA
51373-1-S-S04-003	Annex- Inside Pre-Kindergarten Room 112, Sink	6/10/16 5:00 AM	0.912	BA
51373-1-S-S04-004	Annex- Inside Pre-Kindergarten Room 112, Sink	6/10/16 5:00 AM	1.43	BA
51373-1-S-S04-005	Annex- Inside Pre-Kindergarten Room 112, Sink	6/10/16 5:00 AM	1.17	BA
51373-1-W-S05-001	Annex- Inside Pre-Kindergarten Room 110, Sink	6/10/16 5:00 AM	0.451	BA
51373-1-W-S05-002	Annex- Inside Pre-Kindergarten Room 110, Sink	6/10/16 5:00 AM	0.567	BA
51373-1-W-S05-003	Annex- Inside Pre-Kindergarten Room 110, Sink	6/10/16 5:00 AM	0.663	BA
51373-1-W-S05-004	Annex- Inside Pre-Kindergarten Room 110, Sink	6/10/16 5:00 AM	0.701	BA
51373-1-W-S05-005	Annex- Inside Pre-Kindergarten Room 110, Sink	6/10/16 5:00 AM	0.682	BA
51373-2-N-F01-001	Annex- 2nd Floor Outside Toilets, Fountain	6/10/16 5:00 AM	0.51	BA
51373-2-N-F01-002	Annex- 2nd Floor Outside Toilets, Fountain	6/10/16 5:00 AM	0.399	BA
51373-2-N-F01-003	Annex- 2nd Floor Outside Toilets, Fountain	6/10/16 5:00 AM	0.231	BA
51373-2-N-F01-004	Annex- 2nd Floor Outside Toilets, Fountain	6/10/16 5:00 AM	0.176	BA
51373-2-N-F01-005	Annex- 2nd Floor Outside Toilets, Fountain	6/10/16 5:00 AM	0.161	BA

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit
BA-Below EPA Action Level of 15 ppb
AA-Above EPA Action Level