



# School Lead Water Testing - Data Collection Form

School Short Name    **Gunsaulus**

Length of time water remained in pipes before sampled (hours)    13 Hours  
Report based on lab results dated    6/10/16  
Date of test    05/28/16  
Water last used (Time and date)    Approx 4 PM 5/27/16

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
51272-1-S-S01-001	Sink In kitchen above stove (faucet)	5/28/16 5:00 AM	34.7	AA
51272-1-S-S01-002	Sink In kitchen above stove (faucet)	5/28/16 5:00 AM	12.6	BA
51272-1-S-S01-003	Sink In kitchen above stove (faucet)	5/28/16 5:00 AM	1.91	BA
51272-1-S-S01-004	Sink In kitchen above stove (faucet)	5/28/16 5:00 AM	4.36	BA
51272-1-S-S01-005	Sink In kitchen above stove (faucet)	5/28/16 5:00 AM	1.25	BA
51272-1-S-S02-001	Kitchen, Sink 2	5/28/16 5:00 AM	0.356	BA
51272-1-S-S02-002	Kitchen, Sink 2	5/28/16 5:00 AM	0.358	BA
51272-1-S-S02-003	Kitchen, Sink 2	5/28/16 5:00 AM	0.768	BA
51272-1-S-S02-004	Kitchen, Sink 2	5/28/16 5:00 AM	0.562	BA
51272-1-S-S02-005	Kitchen, Sink 2	5/28/16 5:00 AM	0.579	BA
51272-1-S-S03-001	Kitchen, Sink 3	5/28/16 5:00 AM	0.673	BA
51272-1-S-S03-002	Kitchen, Sink 3	5/28/16 5:00 AM	0.818	BA
51272-1-S-S03-003	Kitchen, Sink 3	5/28/16 5:00 AM	0.781	BA
51272-1-S-S03-004	Kitchen, Sink 3	5/28/16 5:00 AM	0.688	BA
51272-1-S-S03-005	Kitchen, Sink 3	5/28/16 5:00 AM	0.805	BA
51272-1-E-F04-001	Fountain 1 Across from room 105	5/28/16 5:00 AM	0.951	BA
51272-1-E-F04-002	Fountain 1 Across from room 105	5/28/16 5:00 AM	0.928	BA
51272-1-E-F04-003	Fountain 1 Across from room 105	5/28/16 5:00 AM	0.529	BA
51272-1-E-F04-004	Fountain 1 Across from room 105	5/28/16 5:00 AM	0.813	BA
51272-1-E-F04-005	Fountain 1 Across from room 105	5/28/16 5:00 AM	0.711	BA
51272-1-E-F05-001	Fountain 2 Across from room 105	5/28/16 5:00 AM	0.645	BA
51272-1-E-F05-002	Fountain 2 Across from room 105	5/28/16 5:00 AM	0.572	BA
51272-1-E-F05-003	Fountain 2 Across from room 105	5/28/16 5:00 AM	0.919	BA
51272-1-E-F05-004	Fountain 2 Across from room 105	5/28/16 5:00 AM	0.472	BA
51272-1-E-F05-005	Fountain 2 Across from room 105	5/28/16 5:00 AM	0.46	BA
51272-1-W-S06-001	Sink inside room 114	5/28/16 5:00 AM	2.46	BA
51272-1-W-S06-002	Sink inside room 114	5/28/16 5:00 AM	1.8	BA
51272-1-W-S06-003	Sink inside room 114	5/28/16 5:00 AM	1.68	BA
51272-1-W-S06-004	Sink inside room 114	5/28/16 5:00 AM	1.38	BA
51272-1-W-S06-005	Sink inside room 114	5/28/16 5:00 AM	2.31	BA
51272-1-W-F07-001	Fountain 1 outside room 114	5/28/16 5:00 AM	1.04	BA
51272-1-W-F07-002	Fountain 1 outside room 114	5/28/16 5:00 AM	1.04	BA
51272-1-W-F07-003	Fountain 1 outside room 114	5/28/16 5:00 AM	1.02	BA
51272-1-W-F07-004	Fountain 1 outside room 114	5/28/16 5:00 AM	0.895	BA
51272-1-W-F07-005	Fountain 1 outside room 114	5/28/16 5:00 AM	0.727	BA
51272-1-W-F08-001	Fountain 2 outside room 114	5/28/16 5:00 AM	1.24	BA
51272-1-W-F08-002	Fountain 2 outside room 114	5/28/16 5:00 AM	1.73	BA
51272-1-W-F08-003	Fountain 2 outside room 114	5/28/16 5:00 AM	2.11	BA
51272-1-W-F08-004	Fountain 2 outside room 114	5/28/16 5:00 AM	1.35	BA
51272-1-W-F08-005	Fountain 2 outside room 114	5/28/16 5:00 AM	1.3	BA
51272-2-W-F01-001	Fountain 1 outside room 202	5/28/16 5:00 AM	0.815	BA
51272-2-W-F01-002	Fountain 1 outside room 202	5/28/16 5:00 AM	0.472	BA
51272-2-W-F01-003	Fountain 1 outside room 202	5/28/16 5:00 AM	0.692	BA
51272-2-W-F01-004	Fountain 1 outside room 202	5/28/16 5:00 AM	0.475	BA
51272-2-W-F01-005	Fountain 1 outside room 202	5/28/16 5:00 AM	0.568	BA
51272-2-W-F02-001	Fountain 2 outside room 202	5/28/16 5:00 AM	0.87	BA
51272-2-W-F02-002	Fountain 2 outside room 202	5/28/16 5:00 AM	0.489	BA
51272-2-W-F02-003	Fountain 2 outside room 202	5/28/16 5:00 AM	0.517	BA
51272-2-W-F02-004	Fountain 2 outside room 202	5/28/16 5:00 AM	0.515	BA
51272-2-W-F02-005	Fountain 2 outside room 202	5/28/16 5:00 AM	0.525	BA
51272-2-W-F03-001	Fountain 1 outside room 207	5/28/16 5:00 AM	0.729	BA
51272-2-W-F03-002	Fountain 1 outside room 207	5/28/16 5:00 AM	0.535	BA
51272-2-W-F03-003	Fountain 1 outside room 207	5/28/16 5:00 AM	0.498	BA
51272-2-W-F03-004	Fountain 1 outside room 207	5/28/16 5:00 AM	0.497	BA
51272-2-W-F03-005	Fountain 1 outside room 207	5/28/16 5:00 AM	0.52	BA
51272-2-W-F04-001	Fountain 2 outside room 207	5/28/16 5:00 AM	0.81	BA
51272-2-W-F04-002	Fountain 2 outside room 207	5/28/16 5:00 AM	0.521	BA
51272-2-W-F04-003	Fountain 2 outside room 207	5/28/16 5:00 AM	0.55	BA
51272-2-W-F04-004	Fountain 2 outside room 207	5/28/16 5:00 AM	0.571	BA
51272-2-W-F04-005	Fountain 2 outside room 207	5/28/16 5:00 AM	0.56	BA
51272-3-W-F01-001	Fountain outside room 302	5/28/16 5:00 AM	0.744	BA
51272-3-W-F01-002	Fountain outside room 302	5/28/16 5:00 AM	0.553	BA
51272-3-W-F01-003	Fountain outside room 302	5/28/16 5:00 AM	0.473	BA
51272-3-W-F01-004	Fountain outside room 302	5/28/16 5:00 AM	0.447	BA
51272-3-W-F01-005	Fountain outside room 302	5/28/16 5:00 AM	0.47	BA
51272-3-W-F02-001	Fountain outside room 307	5/28/16 5:00 AM	0.744	BA
51272-3-W-F02-002	Fountain outside room 307	5/28/16 5:00 AM	0.7	BA
51272-3-W-F02-003	Fountain outside room 307	5/28/16 5:00 AM	0.644	BA
51272-3-W-F02-004	Fountain outside room 307	5/28/16 5:00 AM	0.568	BA
51272-3-W-F02-005	Fountain outside room 307	5/28/16 5:00 AM	0.563	BA

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

## SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit  
BA-Below EPA Action Level of 15 ppb  
AA-Above EPA Action Level