



School Lead Water Testing Summary

School Short Name **De Diego**

Address 1313 N. Claremont Ave.

Facility ID 51151

CPS Team Member Craig Edgerley

MEC Team Member Evan Christian

Length of time water remained in pipes before sampled [Approx. 9 hours](#)

Water last used (Time and date) [Approx. 9 PM 4/26/16](#)

Date of test [04/27/16](#)

Report based on lab results dated [5/2/2016, 5/18/2016](#)

Sample ID #	Sample Location	Sample Collection Time & Date	Test Results (ppb)	ppb Level
51151-B-C-F-01	Hallway by Room 021	6:03 AM 4/27/16	ND	-
51151-1-N-WC-02	Hallway by Room 133	6:06 AM 4/27/16	ND	-
51151-1-C-F-03	Hallway by Room 123	6:08 AM 4/27/16	ND	-
51151-1-S-F-04	Hallway by Room 109	6:10 AM 4/27/16	ND	-
51151-2-S-F-05	Hallway by Room 210	6:12 AM 4/27/16	ND	-
51151-2-C-F-06	Hallway by Room 219	6:14 AM 4/27/16	ND	-
51151-2-N-F-07	Hallway by Room 231	6:16 AM 4/27/16	ND	-
51151-3-K-CS-08	Kitchen	6:18 AM 4/27/16	ND	-
51151-3-N-F-09	Hallway by Room 333	6:20 AM 4/27/16	ND	-
51151-3-C-F-10	Hallway by Room 321	6:22 AM 4/27/16	ND	-
51151-3-S-F-11	Hallway by Room 310	6:24 AM 4/27/16	ND	-

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit

BA-Below EPA Action Level of 15 ppb

AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations