



School Lead Water Testing - Data Collection Form

School Short Name **Logandale**

Length of time water remained in pipes before sampled (hours)

13.00

Report based on lab results dated

6/15/16

Date of test

06/01/16

Water last used (Time and date)

Approx 4 PM 5/31/16

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
51158-1-N-S01-001	Annex- Kitchen, Sink 1	6/1/16 5:00 AM	0.463	BA
51158-1-N-S01-002	Annex- Kitchen, Sink 1	6/1/16 5:00 AM	0.148	BA
51158-1-N-S01-003	Annex- Kitchen, Sink 1	6/1/16 5:00 AM	<0.120	ND
51158-1-N-S01-004	Annex- Kitchen, Sink 1	6/1/16 5:00 AM	<0.120	ND
51158-1-N-S01-005	Annex- Kitchen, Sink 1	6/1/16 5:00 AM	<0.120	ND
51158-1-W-S02-001	Annex- Kitchen, Sink 2	6/1/16 5:00 AM	<0.120	ND
51158-1-W-S02-002	Annex- Kitchen, Sink 2	6/1/16 5:00 AM	0.523	BA
51158-1-W-S02-003	Annex- Kitchen, Sink 2	6/1/16 5:00 AM	0.164	BA
51158-1-W-S02-004	Annex- Kitchen, Sink 2	6/1/16 5:00 AM	0.175	BA
51158-1-W-S02-005	Annex- Kitchen, Sink 2	6/1/16 5:00 AM	<0.120	ND
51158-1-S-F03-001	Annex- North Gym Entrance, Fountain 1	6/1/16 5:00 AM	<0.120	ND
51158-1-S-F03-002	Annex- North Gym Entrance, Fountain 1	6/1/16 5:00 AM	<0.120	ND
51158-1-S-F03-003	Annex- North Gym Entrance, Fountain 1	6/1/16 5:00 AM	<0.120	ND
51158-1-S-F03-004	Annex- North Gym Entrance, Fountain 1	6/1/16 5:00 AM	<0.120	ND
51158-1-S-F03-005	Annex- North Gym Entrance, Fountain 1	6/1/16 5:00 AM	<0.120	ND
51158-1-S-F04-001	Annex- North Gym Entrance, Fountain 2	6/1/16 5:00 AM	<0.120	ND
51158-1-S-F04-002	Annex- North Gym Entrance, Fountain 2	6/1/16 5:00 AM	<0.120	ND
51158-1-S-F04-003	Annex- North Gym Entrance, Fountain 2	6/1/16 5:00 AM	<0.120	ND
51158-1-S-F04-004	Annex- North Gym Entrance, Fountain 2	6/1/16 5:00 AM	<0.120	ND
51158-1-S-F04-005	Annex- North Gym Entrance, Fountain 2	6/1/16 5:00 AM	<0.120	ND
51158-1-E-F05-001	Annex- 1st Fl West Corridor, Fountain 1	6/1/16 5:00 AM	0.203	BA
51158-1-E-F05-002	Annex- 1st Fl West Corridor, Fountain 1	6/1/16 5:00 AM	0.408	BA
51158-1-E-F05-003	Annex- 1st Fl West Corridor, Fountain 1	6/1/16 5:00 AM	0.273	BA
51158-1-E-F05-004	Annex- 1st Fl West Corridor, Fountain 1	6/1/16 5:00 AM	0.208	BA
51158-1-E-F05-005	Annex- 1st Fl West Corridor, Fountain 1	6/1/16 5:00 AM	0.127	BA
51158-1-E-F06-001	Annex- 1st Fl West Corridor, Fountain 2	6/1/16 5:00 AM	0.199	BA
51158-1-E-F06-002	Annex- 1st Fl West Corridor, Fountain 2	6/1/16 5:00 AM	<0.120	ND
51158-1-E-F06-003	Annex- 1st Fl West Corridor, Fountain 2	6/1/16 5:00 AM	<0.120	ND
51158-1-E-F06-004	Annex- 1st Fl West Corridor, Fountain 2	6/1/16 5:00 AM	<0.120	ND
51158-1-E-F06-005	Annex- 1st Fl West Corridor, Fountain 2	6/1/16 5:00 AM	<0.120	ND
51158-1-N-F07-001	Annex- 1st Fl South Corridor, Fountain 3	6/1/16 5:00 AM	<0.120	ND
51158-1-N-F07-002	Annex- 1st Fl South Corridor, Fountain 3	6/1/16 5:00 AM	<0.120	ND
51158-1-N-F07-003	Annex- 1st Fl South Corridor, Fountain 3	6/1/16 5:00 AM	<0.120	ND
51158-1-N-F07-004	Annex- 1st Fl South Corridor, Fountain 3	6/1/16 5:00 AM	<0.120	ND
51158-1-N-F07-005	Annex- 1st Fl South Corridor, Fountain 3	6/1/16 5:00 AM	<0.120	ND
51158-2-E-F01-001	Annex- 2nd Fl West Corridor, Fountain 1	6/1/16 5:00 AM	<0.120	ND
51158-2-E-F01-002	Annex- 2nd Fl West Corridor, Fountain 1	6/1/16 5:00 AM	<0.120	ND
51158-2-E-F01-003	Annex- 2nd Fl West Corridor, Fountain 1	6/1/16 5:00 AM	<0.120	ND
51158-2-E-F01-004	Annex- 2nd Fl West Corridor, Fountain 1	6/1/16 5:00 AM	<0.120	ND
51158-2-E-F01-005	Annex- 2nd Fl West Corridor, Fountain 1	6/1/16 5:00 AM	<0.120	ND
51158-2-E-F02-001	Annex- 2nd Fl West Corridor, Fountain 2	6/1/16 5:00 AM	<0.120	ND
51158-2-E-F02-002	Annex- 2nd Fl West Corridor, Fountain 2	6/1/16 5:00 AM	<0.120	ND
51158-2-E-F02-003	Annex- 2nd Fl West Corridor, Fountain 2	6/1/16 5:00 AM	<0.120	ND
51158-2-E-F02-004	Annex- 2nd Fl West Corridor, Fountain 2	6/1/16 5:00 AM	<0.120	ND
51158-2-E-F02-005	Annex- 2nd Fl West Corridor, Fountain 2	6/1/16 5:00 AM	<0.120	ND
51158-3-E-F01-001	Annex- 3rd Fl West Corridor, Fountain 1	6/1/16 5:00 AM	<0.120	ND
51158-3-E-F01-002	Annex- 3rd Fl West Corridor, Fountain 1	6/1/16 5:00 AM	<0.120	ND
51158-3-E-F01-003	Annex- 3rd Fl West Corridor, Fountain 1	6/1/16 5:00 AM	<0.120	ND
51158-3-E-F01-004	Annex- 3rd Fl West Corridor, Fountain 1	6/1/16 5:00 AM	<0.120	ND
51158-3-E-F01-005	Annex- 3rd Fl West Corridor, Fountain 1	6/1/16 5:00 AM	<0.120	ND
51158-3-E-F02-001	Annex- 3rd Fl West Corridor, Fountain 2	6/1/16 5:00 AM	<0.120	ND
51158-3-E-F02-002	Annex- 3rd Fl West Corridor, Fountain 2	6/1/16 5:00 AM	<0.120	ND
51158-3-E-F02-003	Annex- 3rd Fl West Corridor, Fountain 2	6/1/16 5:00 AM	<0.120	ND
51158-3-E-F02-004	Annex- 3rd Fl West Corridor, Fountain 2	6/1/16 5:00 AM	<0.120	ND
51158-3-E-F02-005	Annex- 3rd Fl West Corridor, Fountain 2	6/1/16 5:00 AM	<0.120	ND
51158-B-W-S01-001	Main- Kitchen, Sink	6/1/16 5:00 AM	1.66	BA
51158-B-W-S01-002	Main- Kitchen, Sink	6/1/16 5:00 AM	0.371	BA
51158-B-W-S01-003	Main- Kitchen, Sink	6/1/16 5:00 AM	0.216	BA
51158-B-W-S01-004	Main- Kitchen, Sink	6/1/16 5:00 AM	0.286	BA
51158-B-W-S01-005	Main- Kitchen, Sink	6/1/16 5:00 AM	0.681	BA
51158-B-E-F02-001	Main- Girls Play Room, Fountain 1	6/1/16 5:00 AM	0.173	BA
51158-B-E-F02-002	Main- Girls Play Room, Fountain 1	6/1/16 5:00 AM	0.575	BA
51158-B-E-F02-003	Main- Girls Play Room, Fountain 1	6/1/16 5:00 AM	0.457	BA
51158-B-E-F02-004	Main- Girls Play Room, Fountain 1	6/1/16 5:00 AM	0.338	BA
51158-B-E-F02-005	Main- Girls Play Room, Fountain 1	6/1/16 5:00 AM	0.289	BA
51158-B-E-F03-001	Main- Girls Play Room, Fountain 2	6/1/16 5:00 AM	0.191	BA
51158-B-E-F03-002	Main- Girls Play Room, Fountain 2	6/1/16 5:00 AM	0.246	BA
51158-B-E-F03-003	Main- Girls Play Room, Fountain 2	6/1/16 5:00 AM	0.239	BA
51158-B-E-F03-004	Main- Girls Play Room, Fountain 2	6/1/16 5:00 AM	0.235	BA
51158-B-E-F03-005	Main- Girls Play Room, Fountain 2	6/1/16 5:00 AM	0.215	BA
51158-B-E-F04-001	Main- Girls Play Room, Fountain 3	6/1/16 5:00 AM	<0.120	ND
51158-B-E-F04-002	Main- Girls Play Room, Fountain 3	6/1/16 5:00 AM	0.226	BA
51158-B-E-F04-003	Main- Girls Play Room, Fountain 3	6/1/16 5:00 AM	0.195	BA
51158-B-E-F04-004	Main- Girls Play Room, Fountain 3	6/1/16 5:00 AM	0.255	BA
51158-B-E-F04-005	Main- Girls Play Room, Fountain 3	6/1/16 5:00 AM	0.696	BA
51158-2-E-F01-001	Main- Next to Room 204, Fountain	6/1/16 5:00 AM	1.26	BA
51158-2-E-F01-002	Main- Next to Room 204, Fountain	6/1/16 5:00 AM	0.89	BA
51158-2-E-F01-003	Main- Next to Room 204, Fountain	6/1/16 5:00 AM	0.82	BA
51158-2-E-F01-004	Main- Next to Room 204, Fountain	6/1/16 5:00 AM	0.755	BA
51158-2-E-F01-005	Main- Next to Room 204, Fountain	6/1/16 5:00 AM	0.709	BA
51158-2-E-F02-001	Main- Next to Room 208, Fountain 1	6/1/16 5:00 AM	0.175	BA
51158-2-E-F02-002	Main- Next to Room 208, Fountain 1	6/1/16 5:00 AM	0.346	BA
51158-2-E-F02-003	Main- Next to Room 208, Fountain 1	6/1/16 5:00 AM	0.295	BA
51158-2-E-F02-004	Main- Next to Room 208, Fountain 1	6/1/16 5:00 AM	0.271	BA
51158-2-E-F02-005	Main- Next to Room 208, Fountain 1	6/1/16 5:00 AM	0.28	BA
51158-2-E-F03-001	Main- Next to Room 208, Fountain 2	6/1/16 5:00 AM	0.212	BA
51158-2-E-F03-002	Main- Next to Room 208, Fountain 2	6/1/16 5:00 AM	0.305	BA
51158-2-E-F03-003	Main- Next to Room 208, Fountain 2	6/1/16 5:00 AM	0.291	BA
51158-2-E-F03-004	Main- Next to Room 208, Fountain 2	6/1/16 5:00 AM	0.258	BA
51158-2-E-F03-005	Main- Next to Room 208, Fountain 2	6/1/16 5:00 AM	0.284	BA
51158-2-E-F04-001	Main- Next to Room 208, Fountain 3	6/1/16 5:00 AM	0.146	BA
51158-2-E-F04-002	Main- Next to Room 208, Fountain 3	6/1/16 5:00 AM	0.327	BA
51158-2-E-F04-003	Main- Next to Room 208, Fountain 3	6/1/16 5:00 AM	0.384	BA
51158-2-E-F04-004	Main- Next to Room 208, Fountain 3	6/1/16 5:00 AM	0.33	BA
51158-2-E-F04-005	Main- Next to Room 208, Fountain 3	6/1/16 5:00 AM	0.305	BA
51158-1-E-F01-001	Main- Next to Room 104 Fountain	6/1/16 5:00 AM	0.823	BA
51158-1-E-F01-002	Main- Next to Room 104 Fountain	6/1/16 5:00 AM	0.426	BA
51158-1-E-F01-003	Main- Next to Room 104 Fountain	6/1/16 5:00 AM	0.328	BA
51158-1-E-F01-004	Main- Next to Room 104 Fountain	6/1/16 5:00 AM	0.378	BA
51158-1-E-F01-005	Main- Next to Room 104 Fountain	6/1/16 5:00 AM	0.288	BA
51158-1-N-S02-001	Main- Inside Kindergarten Room 106/108, Sink	6/1/16 5:00 AM	0.547	BA
51158-1-N-S02-002	Main- Inside Kindergarten Room 106/108, Sink	6/1/16 5:00 AM	0.319	BA
51158-1-N-S02-003	Main- Inside Kindergarten Room 106/108, Sink	6/1/16 5:00 AM	0.43	BA
51158-1-N-S02-004	Main- Inside Kindergarten Room 106/108, Sink	6/1/16 5:00 AM	0.327	BA
51158-1-N-S02-005	Main- Inside Kindergarten Room 106/108, Sink	6/1/16 5:00 AM	0.305	BA
51158-1-E-F03-001	Main- Next to Room 106, Fountain	6/1/16 5:00 AM	0.944	BA
51158-1-E-F03-002	Main- Next to Room 106, Fountain	6/1/16 5:00 AM	0.375	BA
51158-1-E-F03-003	Main- Next to Room 106, Fountain	6/1/16 5:00 AM	0.278	BA
51158-1-E-F03-004	Main- Next to Room 106, Fountain	6/1/16 5:00 AM	0.241	BA
51158-1-E-F03-005	Main- Next to Room 106, Fountain	6/1/16 5:00 AM	0.268	BA
51158-3-E-F01-001	Main- Next to Gym, Fountain	6/1/16 5:00 AM	0.991	BA
51158-3-E-F01-002	Main- Next to Gym, Fountain	6/1/16 5:00 AM	0.599	BA
51158-3-E-F01-003	Main- Next to Gym, Fountain	6/1/16 5:00 AM	0.467	BA
51158-3-E-F01-004	Main- Next to Gym, Fountain	6/1/16 5:00 AM	0.536	BA
51158-3-E-F01-005	Main- Next to Gym, Fountain	6/1/16 5:00 AM	0.905	BA

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit

BA-Below EPA Action Level of 15 ppb

AA-Above EPA Action Level