



School Lead Water Testing - Data Collection Form

School Short Name **Walt Disney Magnet**

Length of time water remained in pipes before sampled (hours)

13.00

Report based on lab results dated

6/13/16

Date of test

06/01/16

Water last used (Time and date)

Approx 4 PM 5/31/16

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
51082-2-N-F12-001	Gym, Fountain	6/1/2016 5:00AM	1.02	BA
51082-2-N-F12-002	Gym, Fountain	6/1/2016 5:00AM	1.08	BA
51082-2-N-F12-003	Gym, Fountain	6/1/2016 5:00AM	0.948	BA
51082-2-N-F12-004	Gym, Fountain	6/1/2016 5:00AM	0.85	BA
51082-2-N-F12-005	Gym, Fountain	6/1/2016 5:00AM	0.649	BA
51082-3-N-WC01-001	Room 329, Northeast Watercooler	6/1/2016 5:00AM	0.551	BA
51082-3-N-WC01-002	Room 329, Northeast Watercooler	6/1/2016 5:00AM	0.481	BA
51082-3-N-WC01-003	Room 329, Northeast Watercooler	6/1/2016 5:00AM	0.464	BA
51082-3-N-WC01-004	Room 329, Northeast Watercooler	6/1/2016 5:00AM	0.480	BA
51082-3-N-WC01-005	Room 329, Northeast Watercooler	6/1/2016 5:00AM	0.478	BA
51082-3-N-WC02-001	Room 329, Northeast Watercooler (2)	6/1/2016 5:00AM	0.436	BA
51082-3-N-WC02-002	Room 329, Northeast Watercooler (2)	6/1/2016 5:00AM	0.464	BA
51082-3-N-WC02-003	Room 329, Northeast Watercooler (2)	6/1/2016 5:00AM	0.466	BA
51082-3-N-WC02-004	Room 329, Northeast Watercooler (2)	6/1/2016 5:00AM	0.473	BA
51082-3-N-WC02-005	Room 329, Northeast Watercooler (2)	6/1/2016 5:00AM	0.475	BA
51082-3-S-WC04-001	Room 329, Southeast Watercooler (3)	6/1/2016 5:00AM	0.424	BA
51082-3-S-WC04-002	Room 329, Southeast Watercooler (3)	6/1/2016 5:00AM	0.399	BA
51082-3-S-WC04-003	Room 329, Southeast Watercooler (3)	6/1/2016 5:00AM	0.427	BA
51082-3-S-WC04-004	Room 329, Southeast Watercooler (3)	6/1/2016 5:00AM	0.432	BA
51082-3-S-WC04-005	Room 329, Southeast Watercooler (3)	6/1/2016 5:00AM	0.434	BA
51082-3-S-S05-001	Kitchen Sink	6/1/2016 5:00AM	1.18	BA
51082-3-S-S05-002	Kitchen Sink	6/1/2016 5:00AM	1.01	BA
51082-3-S-S05-003	Kitchen Sink	6/1/2016 5:00AM	1.9	BA
51082-3-S-S05-004	Kitchen Sink	6/1/2016 5:00AM	1.17	BA
51082-3-S-S05-005	Kitchen Sink	6/1/2016 5:00AM	0.975	BA
51082-3-S-F06-001	Kitchen Fountain	6/1/2016 5:00AM	0.849	BA
51082-3-S-F06-002	Kitchen Fountain	6/1/2016 5:00AM	0.902	BA
51082-3-S-F06-003	Kitchen Fountain	6/1/2016 5:00AM	0.815	BA
51082-3-S-F06-004	Kitchen Fountain	6/1/2016 5:00AM	0.846	BA
51082-3-S-F06-005	Kitchen Fountain	6/1/2016 5:00AM	0.864	BA
51082-3-S-F07-001	Room 326, Southwest Fountain	6/1/2016 5:00AM	0.888	BA
51082-3-S-F07-002	Room 326, Southwest Fountain	6/1/2016 5:00AM	0.501	BA
51082-3-S-F07-003	Room 326, Southwest Fountain	6/1/2016 5:00AM	0.453	BA
51082-3-S-F07-004	Room 326, Southwest Fountain	6/1/2016 5:00AM	0.54	BA
51082-3-S-F07-005	Room 326, Southwest Fountain	6/1/2016 5:00AM	0.399	BA
51082-3-S-F08-001	Room 326, Southeast Fountain	6/1/2016 5:00AM	0.486	BA
51082-3-S-F08-002	Room 326, Southeast Fountain	6/1/2016 5:00AM	0.513	BA
51082-3-S-F08-003	Room 326, Southeast Fountain	6/1/2016 5:00AM	0.427	BA
51082-3-S-F08-004	Room 326, Southeast Fountain	6/1/2016 5:00AM	0.41	BA
51082-3-S-F08-005	Room 326, Southeast Fountain	6/1/2016 5:00AM	0.428	BA
51082-3-N-WC09-001	Room 326, Northwest Watercooler	6/1/2016 5:00AM	0.358	BA
51082-3-N-WC09-002	Room 326, Northwest Watercooler	6/1/2016 5:00AM	1.09	BA
51082-3-N-WC09-003	Room 326, Northwest Watercooler	6/1/2016 5:00AM	0.509	BA
51082-3-N-WC09-004	Room 326, Northwest Watercooler	6/1/2016 5:00AM	0.52	BA
51082-3-N-WC09-005	Room 326, Northwest Watercooler	6/1/2016 5:00AM	0.522	BA
51082-3-N-WC10-001	Room 326, Northeast Watercooler	6/1/2016 5:00AM	0.487	BA
51082-3-N-WC10-002	Room 326, Northeast Watercooler	6/1/2016 5:00AM	0.46	BA
51082-3-N-WC10-003	Room 326, Northeast Watercooler	6/1/2016 5:00AM	0.398	BA
51082-3-N-WC10-004	Room 326, Northeast Watercooler	6/1/2016 5:00AM	0.398	BA
51082-3-N-WC10-005	Room 326, Northeast Watercooler	6/1/2016 5:00AM	0.405	BA
51082-2-S-S01-001	Kitchen Sink	6/1/2016 5:00AM	0.548	BA
51082-2-S-S01-002	Kitchen Sink	6/1/2016 5:00AM	0.428	BA
51082-2-S-S01-003	Kitchen Sink	6/1/2016 5:00AM	0.336	BA
51082-2-S-S01-004	Kitchen Sink	6/1/2016 5:00AM	0.19	BA
51082-2-S-S01-005	Kitchen Sink	6/1/2016 5:00AM	2.18	BA
51082-2-S-F02-001	Kitchen Fountain	6/1/2016 5:00AM	1.57	BA
51082-2-S-F02-002	Kitchen Fountain	6/1/2016 5:00AM	1.59	BA
51082-2-S-F02-003	Kitchen Fountain	6/1/2016 5:00AM	1.01	BA
51082-2-S-F02-004	Kitchen Fountain	6/1/2016 5:00AM	0.946	BA
51082-2-S-F02-005	Kitchen Fountain	6/1/2016 5:00AM	0.86	BA
51082-2-S-F03-001	Gym, Fountain	6/1/2016 5:00AM	1.39	BA
51082-2-S-F03-002	Gym, Fountain	6/1/2016 5:00AM	1.32	BA
51082-2-S-F03-003	Gym, Fountain	6/1/2016 5:00AM	0.863	BA
51082-2-S-F03-004	Gym, Fountain	6/1/2016 5:00AM	0.788	BA
51082-2-S-F03-005	Gym, Fountain	6/1/2016 5:00AM	0.903	BA
51082-2-S-WC04-001	Room 229 SW, Watercooler	6/1/2016 5:00AM	0.471	BA
51082-2-S-WC04-002	Room 229 SW, Watercooler	6/1/2016 5:00AM	0.454	BA
51082-2-S-WC04-003	Room 229 SW, Watercooler	6/1/2016 5:00AM	0.453	BA
51082-2-S-WC04-004	Room 229 SW, Watercooler	6/1/2016 5:00AM	0.444	BA
51082-2-S-WC04-005	Room 229 SW, Watercooler	6/1/2016 5:00AM	0.439	BA
51082-2-S-WC05-001	Room 229 SE, Watercooler	6/1/2016 5:00AM	0.378	BA
51082-2-S-WC05-002	Room 229 SE, Watercooler	6/1/2016 5:00AM	0.487	BA
51082-2-S-WC06-003	Room 229 SE, Watercooler	6/1/2016 5:00AM	0.783	BA
51082-2-S-WC06-004	Room 229 SE, Watercooler	6/1/2016 5:00AM	0.741	BA
51082-2-S-WC06-005	Room 229 SE, Watercooler	6/1/2016 5:00AM	0.52	BA
51082-2-N-F06-001	Room 229 NW, Fountain	6/1/2016 5:00AM	0.717	BA
51082-2-N-F06-002	Room 229 NW, Fountain	6/1/2016 5:00AM	0.609	BA
51082-2-N-F06-003	Room 229 NW, Fountain	6/1/2016 5:00AM	0.616	BA
51082-2-N-F06-004	Room 229 NW, Fountain	6/1/2016 5:00AM	0.559	BA
51082-2-N-F06-005	Room 229 NW, Fountain	6/1/2016 5:00AM	0.544	BA
51082-2-N-F07-001	Room 229 NE, Fountain	6/1/2016 5:00AM	0.880	BA
51082-2-N-F07-002	Room 229 NE, Fountain	6/1/2016 5:00AM	0.674	BA
51082-2-N-F07-003	Room 229 NE, Fountain	6/1/2016 5:00AM	0.755	BA
51082-2-N-F07-004	Room 229 NE, Fountain	6/1/2016 5:00AM	0.769	BA
51082-2-N-F07-005	Room 229 NE, Fountain	6/1/2016 5:00AM	0.765	BA
51082-2-S-F08-001	Room 226 SW, Fountain	6/1/2016 5:00AM	0.807	BA
51082-2-S-F08-002	Room 226 SW, Fountain	6/1/2016 5:00AM	0.71	BA
51082-2-S-F08-003	Room 226 SW, Fountain	6/1/2016 5:00AM	0.828	BA
51082-2-S-F08-004	Room 226 SW, Fountain	6/1/2016 5:00AM	0.976	BA
51082-2-S-F08-005	Room 226 SW, Fountain	6/1/2016 5:00AM	1.03	BA
51082-2-N-WC10-001	Room 226 NW, Watercooler	6/1/2016 5:00AM	0.493	BA
51082-2-N-WC10-002	Room 226 NW, Watercooler	6/1/2016 5:00AM	0.588	BA
51082-2-N-WC10-003	Room 226 NW, Watercooler	6/1/2016 5:00AM	0.951	BA
51082-2-N-WC10-004	Room 226 NW, Watercooler	6/1/2016 5:00AM	0.897	BA
51082-2-N-WC10-005	Room 226 NW, Watercooler	6/1/2016 5:00AM	0.713	BA
51082-2-N-WC11-001	Room 226 NE, Watercooler	6/1/2016 5:00AM	0.756	BA
51082-2-N-WC11-002	Room 226 NE, Watercooler	6/1/2016 5:00AM	0.698	BA
51082-2-N-WC11-003	Room 226 NE, Watercooler	6/1/2016 5:00AM	0.723	BA
51082-2-N-WC11-004	Room 226 NE, Watercooler	6/1/2016 5:00AM	0.678	BA
51082-2-N-WC11-005	Room 226 NE, Watercooler	6/1/2016 5:00AM	0.666	BA
51082-1-W-F15-001	In Room 120, Pod 122, Fountain	6/1/2016 5:00AM	6.18	BA
51082-1-W-F15-002	In Room 120, Pod 122, Fountain	6/1/2016 5:00AM	9.04	BA
51082-1-W-F15-003	In Room 120, Pod 122, Fountain	6/1/2016 5:00AM	13.3	BA
51082-1-W-F15-004	In Room 120, Pod 122, Fountain	6/1/2016 5:00AM	8.58	BA
51082-1-W-F15-005	In Room 120, Pod 122, Fountain	6/1/2016 5:00AM	9.13	BA
51082-1-NE-S16-001	In Room 120, Pod 124, Sink	6/1/2016 5:00AM	18.1	AA
51082-1-NE-S16-002	In Room 120, Pod 124, Sink	6/1/2016 5:00AM	23.8	AA
51082-1-NE-S16-003	In Room 120, Pod 124, Sink	6/1/2016 5:00AM	16.3	AA
51082-1-NE-S16-004	In Room 120, Pod 124, Sink	6/1/2016 5:00AM	8.01	BA
51082-1-NE-S16-005	In Room 120, Pod 124, Sink	6/1/2016 5:00AM	5.19	BA
51082-1-SW-S17-001	In Room 120, Pod 126, Sink	6/1/2016 5:00AM	1.45	BA
51082-1-SW-S17-002	In Room 120, Pod 126, Sink	6/1/2016 5:00AM	1.15	BA
51082-1-SW-S17-003	In Room 120, Pod 126, Sink	6/1/2016 5:00AM	1.89	BA
51082-1-SW-S17-004	In Room 120, Pod 126, Sink	6/1/2016 5:00AM	2.41	BA
51082-1-SW-S17-005	In Room 120, Pod 126, Sink	6/1/2016 5:00AM	2.72	BA
51082-1-W-S18-001	In Room 120, Pod 128, Sink	6/1/2016 5:00AM	2.5	BA
51082-1-W-S18-002	In Room 120, Pod 128, Sink	6/1/2016 5:00AM	4.19	BA
51082-1-W-S18-003	In Room 120, Pod 128, Sink	6/1/2016 5:00AM	3.99	BA
51082-1-W-S18-004	In Room 120, Pod 128, Sink	6/1/2016 5:00AM	8.67	BA
51082-1-W-S18-005	In Room 120, Pod 128, Sink	6/1/2016 5:00AM	4.81	BA
51082-1-N-F19-001	In Room 120, Pod 128, Fountain	6/1/2016 5:00AM	3.05	BA
51082-1-N-F19-002	In Room 120, Pod 128, Fountain	6/1/2016 5:00AM	6.83	BA
51082-1-N-F19-003	In Room 120, Pod 128, Fountain	6/1/2016 5:00AM	4.72	BA
51082-1-N-F19-004	In Room 120, Pod 128, Fountain	6/1/2016 5:00AM	3.69	BA
51082-1-N-F19-005	In Room 120, Pod 128, Fountain	6/1/2016 5:00AM	1.48	BA
51082-1-W-S20-001	Pre School Room 110, Sink	6/1/2016 5:00AM	4.95	BA
51082-1-W-S20-002	Pre School Room 110, Sink	6/1/2016 5:00AM	1.98	BA
51082-1-W-S20-003	Pre School Room 110, Sink	6/1/2016 5:00AM	1.14	BA
51082-1-W-S20-004	Pre School Room 110, Sink	6/1/2016 5:00AM	0.846	BA
51082-1-W-S20-005	Pre School Room 110, Sink	6/1/2016 5:00AM	0.993	BA
51082-1-N-S21-001	Pre School Outside Boys Toilet, Sink	6/1/2016 5:00AM	1.45	BA
51082-1-N-S21-002	Pre School Outside Boys Toilet, Sink	6/1/2016 5:00AM	0.798	BA
51082-1-N-S21-003	Pre School Outside Boys Toilet, Sink	6/1/2016 5:00AM	0.649	BA
51082-1-N-S21-004	Pre School Outside Boys Toilet, Sink	6/1/2016 5:00AM	0.585	BA
51082-1-N-S21-005	Pre School Outside Boys Toilet, Sink	6/1/2016 5:00AM	0.559	BA

51082-1-N-S22-001	Pre School Room 110, Sink	6/1/2016 5:00AM	7.62	BA
51082-1-N-S22-002	Pre School Room 110, Sink	6/1/2016 5:00AM	2.48	BA
51082-1-N-S22-003	Pre School Room 110, Sink	6/1/2016 5:00AM	1.64	BA
51082-1-N-S22-004	Pre School Room 110, Sink	6/1/2016 5:00AM	1.29	BA
51082-1-N-S22-005	Pre School Room 110, Sink	6/1/2016 5:00AM	1.46	BA
51082-1-W-S23-001	Pre School Room 110, Sink (2)	6/1/2016 5:00AM	2.56	BA
51082-1-W-S23-002	Pre School Room 110, Sink (2)	6/1/2016 5:00AM	1.36	BA
51082-1-W-S23-003	Pre School Room 110, Sink (2)	6/1/2016 5:00AM	0.782	BA
51082-1-W-S23-004	Pre School Room 110, Sink (2)	6/1/2016 5:00AM	0.758	BA
51082-1-W-S23-005	Pre School Room 110, Sink (2)	6/1/2016 5:00AM	0.904	BA
51082-1-S-S24-001	Teachers lounge, Sink	6/1/2016 5:00AM	2.14	BA
51082-1-S-S24-002	Teachers lounge, Sink	6/1/2016 5:00AM	1.28	BA
51082-1-S-S24-003	Teachers lounge, Sink	6/1/2016 5:00AM	0.974	BA
51082-1-S-S24-004	Teachers lounge, Sink	6/1/2016 5:00AM	1.03	BA
51082-1-S-S24-005	Teachers lounge, Sink	6/1/2016 5:00AM	0.814	BA
51082-1-E-F25-001	Teachers lounge, Fountain	6/1/2016 5:00AM	0.802	BA
51082-1-E-F25-002	Teachers lounge, Fountain	6/1/2016 5:00AM	0.668	BA
51082-1-E-F25-003	Teachers lounge, Fountain	6/1/2016 5:00AM	0.536	BA
51082-1-E-F25-004	Teachers lounge, Fountain	6/1/2016 5:00AM	0.42	BA
51082-1-E-F25-005	Teachers lounge, Fountain	6/1/2016 5:00AM	0.347	BA
51082-1-E-F01-001	Near Room 120, Fountain	6/1/2016 5:00AM	1.4	BA
51082-1-E-F01-002	Near Room 120, Fountain	6/1/2016 5:00AM	1.38	BA
51082-1-E-F01-003	Near Room 120, Fountain	6/1/2016 5:00AM	1.54	BA
51082-1-E-F01-004	Near Room 120, Fountain	6/1/2016 5:00AM	1.22	BA
51082-1-E-F01-005	Near Room 120, Fountain	6/1/2016 5:00AM	1.3	BA
51082-1-N-F02-001	Near Room 131, Fountain	6/1/2016 5:00AM	0.518	BA
51082-1-N-F02-002	Near Room 131, Fountain	6/1/2016 5:00AM	1.03	BA
51082-1-N-F02-003	Near Room 131, Fountain	6/1/2016 5:00AM	1.2	BA
51082-1-N-F02-004	Near Room 131, Fountain	6/1/2016 5:00AM	0.58	BA
51082-1-N-F02-005	Near Room 131, Fountain	6/1/2016 5:00AM	0.721	BA
51082-1-S-WC03-001	Hall By Gym, Watercooler	6/1/2016 5:00AM	0.484	BA
51082-1-S-WC03-002	Hall By Gym, Watercooler	6/1/2016 5:00AM	0.563	BA
51082-1-S-WC03-003	Hall By Gym, Watercooler	6/1/2016 5:00AM	0.809	BA
51082-1-S-WC03-004	Hall By Gym, Watercooler	6/1/2016 5:00AM	0.541	BA
51082-1-S-WC03-005	Hall By Gym, Watercooler	6/1/2016 5:00AM	0.99	BA
51082-1-S-WC04-001	Hall By Gym, Watercooler (2)	6/1/2016 5:00AM	0.479	BA
51082-1-S-WC04-002	Hall By Gym, Watercooler (2)	6/1/2016 5:00AM	0.473	BA
51082-1-S-WC04-003	Hall By Gym, Watercooler (2)	6/1/2016 5:00AM	0.496	BA
51082-1-S-WC04-004	Hall By Gym, Watercooler (2)	6/1/2016 5:00AM	0.463	BA
51082-1-S-WC04-005	Hall By Gym, Watercooler (2)	6/1/2016 5:00AM	0.441	BA
51082-1-S-WC05-001	In Lunch Room, Watercooler	6/1/2016 5:00AM	0.324	BA
51082-1-S-WC05-002	In Lunch Room, Watercooler	6/1/2016 5:00AM	0.148	BA
51082-1-S-WC05-003	In Lunch Room, Watercooler	6/1/2016 5:00AM	0.256	BA
51082-1-S-WC05-004	In Lunch Room, Watercooler	6/1/2016 5:00AM	<0.120	ND
51082-1-S-WC05-005	In Lunch Room, Watercooler	6/1/2016 5:00AM	0.216	BA
51082-1-S-WC06-001	In Lunch Room, Watercooler (2)	6/1/2016 5:00AM	0.233	BA
51082-1-S-WC06-002	In Lunch Room, Watercooler (2)	6/1/2016 5:00AM	0.212	BA
51082-1-S-WC06-003	In Lunch Room, Watercooler (2)	6/1/2016 5:00AM	0.265	BA
51082-1-S-WC06-004	In Lunch Room, Watercooler (2)	6/1/2016 5:00AM	0.289	BA
51082-1-S-WC06-005	In Lunch Room, Watercooler (2)	6/1/2016 5:00AM	0.24	BA
51082-1-S-WC07-001	In Lunch Room, Watercooler	6/1/2016 5:00AM	0.341	BA
51082-1-S-WC07-002	In Lunch Room, Watercooler	6/1/2016 5:00AM	0.311	BA
51082-1-S-WC07-003	In Lunch Room, Watercooler	6/1/2016 5:00AM	0.365	BA
51082-1-S-WC07-004	In Lunch Room, Watercooler	6/1/2016 5:00AM	0.355	BA
51082-1-S-WC07-005	In Lunch Room, Watercooler	6/1/2016 5:00AM	0.395	BA
51082-1-S-CS08-001	In Lunch Room, Cooking Sink	6/1/2016 5:00AM	1.54	BA
51082-1-S-CS08-002	In Lunch Room, Cooking Sink	6/1/2016 5:00AM	0.418	BA
51082-1-S-CS08-003	In Lunch Room, Cooking Sink	6/1/2016 5:00AM	0.163	BA
51082-1-S-CS08-004	In Lunch Room, Cooking Sink	6/1/2016 5:00AM	0.255	BA
51082-1-S-CS08-005	In Lunch Room, Cooking Sink	6/1/2016 5:00AM	0.207	BA
51082-1-S-WC09-001	Hall By Room 110, Watercooler	6/1/2016 5:00AM	0.499	BA
51082-1-S-WC09-002	Hall By Room 110, Watercooler	6/1/2016 5:00AM	0.229	BA
51082-1-S-WC09-003	Hall By Room 110, Watercooler	6/1/2016 5:00AM	0.25	BA
51082-1-S-WC09-004	Hall By Room 110, Watercooler	6/1/2016 5:00AM	0.4	BA
51082-1-S-WC09-005	Hall By Room 110, Watercooler	6/1/2016 5:00AM	0.322	BA
51082-1-S-WC10-001	Hall By Room 110, Watercooler (2)	6/1/2016 5:00AM	0.708	BA
51082-1-S-WC10-002	Hall By Room 110, Watercooler (2)	6/1/2016 5:00AM	0.699	BA
51082-1-S-WC10-003	Hall By Room 110, Watercooler (2)	6/1/2016 5:00AM	0.677	BA
51082-1-S-WC10-004	Hall By Room 110, Watercooler (2)	6/1/2016 5:00AM	0.598	BA
51082-1-S-WC10-005	Hall By Room 110, Watercooler (2)	6/1/2016 5:00AM	0.705	BA
51082-1-E-F11-001	Halfway By Central Office, Fountain	6/1/2016 5:00AM	1.29	BA
51082-1-E-F11-002	Halfway By Central Office, Fountain	6/1/2016 5:00AM	1.3	BA
51082-1-E-F11-003	Halfway By Central Office, Fountain	6/1/2016 5:00AM	1.15	BA
51082-1-E-F11-004	Halfway By Central Office, Fountain	6/1/2016 5:00AM	1.28	BA
51082-1-E-F11-005	Halfway By Central Office, Fountain	6/1/2016 5:00AM	1.3	BA
51082-1-N-F12-001	Hall By Girls Toilet, Fountain	6/1/2016 5:00AM	0.897	BA
51082-1-N-F12-002	Hall By Girls Toilet, Fountain	6/1/2016 5:00AM	0.921	BA
51082-1-N-F12-003	Hall By Girls Toilet, Fountain	6/1/2016 5:00AM	0.92	BA
51082-1-N-F12-004	Hall By Girls Toilet, Fountain	6/1/2016 5:00AM	0.873	BA
51082-1-N-F12-005	Hall By Girls Toilet, Fountain	6/1/2016 5:00AM	0.922	BA
51082-1-W-F13-001	Halfby Room 100, Fountain	6/1/2016 5:00AM	1.28	BA
51082-1-W-F13-002	Halfby Room 100, Fountain	6/1/2016 5:00AM	1.35	BA
51082-1-W-F13-003	Halfby Room 100, Fountain	6/1/2016 5:00AM	1.15	BA
51082-1-W-F13-004	Halfby Room 100, Fountain	6/1/2016 5:00AM	1.18	BA
51082-1-W-F13-005	Halfby Room 100, Fountain	6/1/2016 5:00AM	1.17	BA
51082-1-NW-S14-001	Hall By 120, Sink	6/1/2016 5:00AM	2.49	BA
51082-1-NW-S14-002	Hall By 120, Sink	6/1/2016 5:00AM	2.53	BA
51082-1-NW-S14-003	Hall By 120, Sink	6/1/2016 5:00AM	2.63	BA
51082-1-NW-S14-004	Hall By 120, Sink	6/1/2016 5:00AM	5.67	BA
51082-1-NW-S14-005	Hall By 120, Sink	6/1/2016 5:00AM	2.27	BA
51082-B-E-CS01-001	Kitchen, Cooking Sink	6/1/2016 5:00AM	0.373	BA
51082-B-E-CS01-002	Kitchen, Cooking Sink	6/1/2016 5:00AM	0.15	BA
51082-B-E-CS01-003	Kitchen, Cooking Sink	6/1/2016 5:00AM	1.01	BA
51082-B-E-CS01-004	Kitchen, Cooking Sink	6/1/2016 5:00AM	0.266	BA
51082-B-E-CS01-005	Kitchen, Cooking Sink	6/1/2016 5:00AM	0.144	BA
51082-B-C-CS02-001	Kitchen, Cooking Sink (2)	6/1/2016 5:00AM	0.256	BA
51082-B-C-CS02-002	Kitchen, Cooking Sink (2)	6/1/2016 5:00AM	0.234	BA
51082-B-C-CS02-003	Kitchen, Cooking Sink (2)	6/1/2016 5:00AM	0.18	BA
51082-B-C-CS02-004	Kitchen, Cooking Sink (2)	6/1/2016 5:00AM	0.296	BA
51082-B-C-CS02-005	Kitchen, Cooking Sink (2)	6/1/2016 5:00AM	0.264	BA
51082-B-C-CS03-001	Kitchen, Cooking Sink (3)	6/1/2016 5:00AM	2.35	BA
51082-B-C-CS03-002	Kitchen, Cooking Sink (3)	6/1/2016 5:00AM	0.909	BA
51082-B-C-CS03-003	Kitchen, Cooking Sink (3)	6/1/2016 5:00AM	0.479	BA
51082-B-C-CS03-004	Kitchen, Cooking Sink (3)	6/1/2016 5:00AM	0.444	BA
51082-B-C-CS03-005	Kitchen, Cooking Sink (3)	6/1/2016 5:00AM	0.45	BA
51082-B-C-CS04-001	Kitchen, Cooking Sink (4)	6/1/2016 5:00AM	0.421	BA
51082-B-C-CS04-002	Kitchen, Cooking Sink (4)	6/1/2016 5:00AM	0.57	BA
51082-B-C-CS04-003	Kitchen, Cooking Sink (4)	6/1/2016 5:00AM	0.678	BA
51082-B-C-CS04-004	Kitchen, Cooking Sink (4)	6/1/2016 5:00AM	0.504	BA
51082-B-C-CS04-005	Kitchen, Cooking Sink (4)	6/1/2016 5:00AM	0.708	BA
51082-B-N-CS05-001	Kitchen, Cooking Sink (5)	6/1/2016 5:00AM	1.04	BA
51082-B-N-CS05-002	Kitchen, Cooking Sink (5)	6/1/2016 5:00AM	0.238	BA
51082-B-N-CS05-003	Kitchen, Cooking Sink (5)	6/1/2016 5:00AM	0.233	BA
51082-B-N-CS05-004	Kitchen, Cooking Sink (5)	6/1/2016 5:00AM	0.246	BA
51082-B-N-CS05-005	Kitchen, Cooking Sink (5)	6/1/2016 5:00AM	0.622	BA
51082-B-W-ST06-001	Slow Top Kitchen	6/1/2016 5:00AM	10.8	BA
51082-B-W-ST06-002	Slow Top Kitchen	6/1/2016 5:00AM	2.11	BA
51082-B-W-ST06-003	Slow Top Kitchen	6/1/2016 5:00AM	4.32	BA
51082-B-W-ST06-004	Slow Top Kitchen	6/1/2016 5:00AM	1.98	BA
51082-B-W-ST06-005	Slow Top Kitchen	6/1/2016 5:00AM	1.75	BA
51082-B-W-CS07-001	Kitchen, Cooking Sink	6/1/2016 5:00AM	<0.120	ND
51082-B-W-CS07-002	Kitchen, Cooking Sink	6/1/2016 5:00AM	<0.120	ND
51082-B-W-CS07-003	Kitchen, Cooking Sink	6/1/2016 5:00AM	1.8	BA
51082-B-W-CS07-004	Kitchen, Cooking Sink	6/1/2016 5:00AM	0.224	BA
51082-B-W-CS07-005	Kitchen, Cooking Sink	6/1/2016 5:00AM	0.13	BA
51082-B-W-CS08-001	Kitchen, Cooking Sink (2)	6/1/2016 5:00AM	8.13	BA
51082-B-W-CS08-002	Kitchen, Cooking Sink (2)	6/1/2016 5:00AM	5.7	BA
51082-B-W-CS08-003	Kitchen, Cooking Sink (2)	6/1/2016 5:00AM	6.77	BA
51082-B-W-CS08-004	Kitchen, Cooking Sink (2)	6/1/2016 5:00AM	7.72	BA
51082-B-W-CS08-005	Kitchen, Cooking Sink (2)	6/1/2016 5:00AM	4.21	BA
51082-1-SE-F01-001	Art Building Disney Hall CAC, Fountain	6/1/2016 5:00AM	0.233	BA
51082-1-SE-F01-002	Art Building Disney Hall CAC, Fountain	6/1/2016 5:00AM	0.286	BA
51082-1-SE-F01-003	Art Building Disney Hall CAC, Fountain	6/1/2016 5:00AM	0.312	BA
51082-1-SE-F01-004	Art Building Disney Hall CAC, Fountain	6/1/2016 5:00AM	0.238	BA
51082-1-SE-F01-005	Art Building Disney Hall CAC, Fountain	6/1/2016 5:00AM	0.252	BA

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit
BA-Below EPA Action Level of 15 ppb
AA-Above EPA Action Level