



July 12, 2016

Dear CPS family,

In light of national events that have brought increased attention to the issue of water quality, the City of Chicago announced several additional precautionary measures that will be added to the City's water testing protocol, continuing the City's track record of complying with current state and federal regulations as well as exceeding industry standards.

As part of this announcement, Chicago Public Schools (CPS) began testing the water for levels of lead from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe. Schools are being tested based on a priority criteria that includes the age of the school, age of the students (with priority given to schools with pre-K programs), presence of a kitchen (where meals are prepared) and presence of pipes that could need repairs or replacement.

The results of all the schools are coming in on a rolling basis, and the majority have had levels under the EPA's action level of 15 parts per billion (ppb). We wanted to let you know that no lead was found above the action level in your child's school. The full results of your school's water samples can be found online at cps.edu/leadtesting.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician for testing. Additionally, CDPH's lead hotline can address any health related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

Forrest Claypool
CEO, Chicago Public Schools

Dr. Julie Morita
Commissioner, Chicago Department of Public Health





12 de julio de 2016

Estimadas familias de CPS,

Ante los eventos nacionales que han incrementado la atención en el tema de la calidad del agua, la Alcaldía de Chicago anunció varias medidas adicionales de precaución que serán agregadas al protocolo de prueba del agua de la ciudad, continuando con el cumplimiento de las regulaciones estatales y federales, que exceden los estándares industriales.

Como parte de este anuncio, las Escuelas Públicas de Chicago (CPS) comenzaron a medir los niveles de plomo en el agua de todas las escuelas del distrito. Nuestra principal prioridad es la salud y seguridad de todos nuestros estudiantes y personal, y estas pruebas fueron iniciadas solamente para extremar las precauciones y estar seguros de que el agua es segura. Las escuelas son examinadas con base a un criterio de prioridad que incluye la antigüedad del edificio, edad de los estudiantes (con prioridad para las escuelas con programas preescolares), presencia de una cocina (donde se preparan alimentos) y la presencia de cañerías que necesiten reparación o reemplazo.

Los resultados de todas las escuelas se están conociendo, y la mayoría ha registrado niveles por debajo del nivel de acción de la EPA, que es de 15 partículas por billón (ppb). Queremos hacerles saber que no se encontraron rastros de plomo por encima del nivel de acción en la escuela de su niño. Los resultados completos de las pruebas en su escuela se pueden ver en línea en cps.edu/leadtesting.

Los lineamientos federales indican que los niños menores de seis años son los que corren mayores riesgos con la exposición al plomo, algo que puede ocurrir de varias fuentes, incluyendo pintura, tierra y algunos productos de consumo. Si están preocupados por la posible exposición de su hijo al plomo, el Departamento de Salud Pública de la ciudad de Chicago (CDPH) recomienda visitar a su pediatra o a alguno de los centros de salud listados en el material adjunto, para una prueba. Además, la línea directa del CDPH puede responder cualquier pregunta que tengan, o ayudarlos a decidir si su niño debe ser examinado; por preguntas o más información, llame por favor al 312-747-5323. Por información adicional sobre el plomo y los niños, visite www.cdc.gov/lead.

La seguridad de sus hijos es nuestra principal prioridad, y hacemos todo lo que está en nuestro poder para resolver esta situación de una manera rápida y rigurosa. Continuaremos informándoles sobre este proceso.

Atentamente,

Forrest Claypool
CEO, Escuelas Públicas de Chicago

Dra. Julie Morita, Comisionada
Departamento de Salud Pública de Chicago





School Lead Water Testing - Data Collection Form

School Name

Armour

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
B-W-CS01-01	Kitchen	5/24/16 6:19 AM	0.266	BA
B-W-CS01-02	Kitchen	5/24/16 6:19 AM	0.183	BA
B-W-CS01-03	Kitchen	5/24/16 6:19 AM	0.165	BA
B-W-CS01-04	Kitchen	5/24/16 6:20 AM	0.171	BA
B-W-CS01-05	Kitchen	5/24/16 6:20 AM	0.150	BA
B-W-CS02-06	Kitchen	5/24/16 6:21 AM	1.34	BA
B-W-CS02-07	Kitchen	5/24/16 6:22 AM	0.192	BA
B-W-CS02-08	Kitchen	5/24/16 6:22 AM	0.200	BA
B-W-CS02-09	Kitchen	5/24/16 6:23 AM	0.162	BA
B-W-CS02-10	Kitchen	5/24/16 6:23 AM	0.147	BA
3-N-WC01-11	Room 302	5/24/16 6:31 AM	0.513	BA
3-N-WC01-12	Room 302	5/24/16 6:32 AM	0.589	BA
3-N-WC01-13	Room 302	5/24/16 6:32 AM	0.644	BA
3-N-WC01-14	Room 302	5/24/16 6:32 AM	0.662	BA
3-N-WC01-15	Room 302	5/24/16 6:32 AM	0.700	BA
3-S-F01-16	Room 301 E	5/24/16 6:38 AM	0.814	BA
3-S-F01-17	Room 301 E	5/24/16 6:38 AM	0.430	BA
3-S-F01-18	Room 301 E	5/24/16 6:39 AM	0.498	BA
3-S-F01-19	Room 301 E	5/24/16 6:39 AM	0.459	BA
3-S-F01-20	Room 301 E	5/24/16 6:40 AM	0.438	BA
3-S-F02-21	Room 301 E	5/24/16 6:42 AM	0.247	BA
3-S-F02-22	Room 301 E	5/24/16 6:42 AM	0.223	BA
3-S-F02-23	Room 301 E	5/24/16 6:43 AM	0.221	BA
3-S-F02-24	Room 301 E	5/24/16 6:43 AM	0.22	BA
3-S-F02-25	Room 301 E	5/24/16 6:43 AM	0.224	BA
3-S-F03-26	Room 301 E	5/24/16 6:45 AM	0.494	BA
3-S-F03-27	Room 301 E	5/24/16 6:45 AM	0.322	BA
3-S-F03-28	Room 301 E	5/24/16 6:46 AM	0.321	BA
3-S-F03-29	Room 301 E	5/24/16 6:46 AM	0.311	BA
3-S-F03-30	Room 301 E	5/24/16 6:46 AM	0.391	BA
2-S-F01-31	Room 201 E	5/24/16 6:55 AM	0.254	BA
2-S-F01-32	Room 201 E	5/24/16 6:55 AM	0.262	BA
2-S-F01-33	Room 201 E	5/24/16 6:56 AM	0.394	BA
2-S-F01-34	Room 201 E	5/24/16 6:56 AM	0.387	BA
2-S-F01-35	Room 201 E	5/24/16 6:56 AM	0.382	BA
2-S-F02-36	Room 201 E	5/24/16 6:58 AM	0.236	BA
2-S-F02-37	Room 201 E	5/24/16 6:58 AM	0.287	BA
2-S-F02-38	Room 201 E	5/24/16 6:59 AM	0.359	BA
2-S-F02-39	Room 201 E	5/24/16 6:59 AM	0.424	BA
2-S-F02-40	Room 201 E	5/24/16 6:59 AM	0.365	BA
2-S-F03-41	Room 201 E	5/24/16 7:02 AM	0.404	BA
2-S-F03-42	Room 201 E	5/24/16 7:02 AM	0.719	BA
2-S-F03-43	Room 201 E	5/24/16 7:03 AM	0.440	BA
2-S-F03-44	Room 201 E	5/24/16 7:03 AM	0.553	BA
2-S-F03-45	Room 201 E	5/24/16 7:03 AM	0.663	BA
1-S-F01-46	Room 101 E	5/24/16 7:16 AM	0.243	BA
1-S-F01-47	Room 101 E	5/24/16 7:16 AM	0.354	BA
1-S-F01-48	Room 101 E	5/24/16 7:16 AM	0.441	BA
1-S-F01-49	Room 101 E	5/24/16 7:17 AM	0.453	BA
1-S-F01-50	Room 101 E	5/24/16 7:17 AM	0.455	BA
1-S-F02-51	Room 101 E	5/24/16 7:18 AM	0.274	BA
1-S-F02-52	Room 101 E	5/24/16 7:18 AM	0.428	BA
1-S-F02-53	Room 101 E	5/24/16 7:18 AM	0.435	BA
1-S-F02-54	Room 101 E	5/24/16 7:19 AM	0.527	BA
1-S-F02-55	Room 101 E	5/24/16 7:19 AM	0.466	BA
1-S-F03-56	Room 101 E	5/24/16 7:20 AM	0.292	BA
1-S-F03-57	Room 101 E	5/24/16 7:20 AM	0.405	BA
1-S-F03-58	Room 101 E	5/24/16 7:20 AM	0.391	BA
1-S-F03-59	Room 101 E	5/24/16 7:21 AM	0.384	BA
1-S-F03-60	Room 101 E	5/24/16 7:21 AM	0.410	BA
B-N-F01-61	Lunchroom	5/24/16 7:47 AM	0.382	BA
B-N-F01-62	Lunchroom	5/24/16 7:47 AM	0.299	BA
B-N-F01-63	Lunchroom	5/24/16 7:48 AM	0.312	BA
B-N-F01-64	Lunchroom	5/24/16 7:48 AM	0.470	BA
B-N-F01-65	Lunchroom	5/24/16 7:48 AM	0.448	BA
B-N-F02-66	Lunchroom	5/24/16 7:49 AM	0.346	BA
B-N-F02-67	Lunchroom	5/24/16 7:49 AM	0.418	BA
B-N-F02-68	Lunchroom	5/24/16 7:50 AM	0.740	BA
B-N-F02-69	Lunchroom	5/24/16 7:50 AM	0.467	BA
B-N-F02-70	Lunchroom	5/24/16 7:50 AM	<0.120	BA
B-N-F03-71	Lunchroom	5/24/16 7:51 AM	0.341	BA
B-N-F03-72	Lunchroom	5/24/16 7:51 AM	0.449	BA
B-N-F03-73	Lunchroom	5/24/16 7:51 AM	0.424	BA
B-N-F03-74	Lunchroom	5/24/16 7:52 AM	0.397	BA
B-N-F03-75	Lunchroom	5/24/16 7:52 AM	0.396	BA
B-W-CS01-01	Kitchen	6/10/16 6:18 AM	None Detected	ND
B-W-CS01-02	Kitchen	6/10/16 6:18 AM	None Detected	ND
B-W-CS01-03	Kitchen	6/10/16 6:18 AM	None Detected	ND
B-W-CS01-04	Kitchen	6/10/16 6:18 AM	None Detected	ND
B-W-CS01-05	Kitchen	6/10/16 6:18 AM	None Detected	ND
B-W-CS02-06	Kitchen	6/10/16 6:19 AM	None Detected	ND
B-W-CS02-07	Kitchen	6/10/16 6:19 AM	None Detected	ND
B-W-CS02-08	Kitchen	6/10/16 6:19 AM	None Detected	ND
B-W-CS02-09	Kitchen	6/10/16 6:19 AM	None Detected	ND
B-W-CS02-10	Kitchen	6/10/16 6:19 AM	None Detected	ND
B-S-F01-11	Lunchroom	6/10/16 6:25 AM	None Detected	ND
B-S-F01-12	Lunchroom	6/10/16 6:25 AM	None Detected	ND
B-S-F01-13	Lunchroom	6/10/16 6:25 AM	None Detected	ND
B-S-F01-14	Lunchroom	6/10/16 6:25 AM	None Detected	ND
B-S-F01-15	Lunchroom	6/10/16 6:25 AM	None Detected	ND
B-S-WC01-16	Lunchroom	6/10/16 6:26 AM	None Detected	ND
B-S-WC01-17	Lunchroom	6/10/16 6:26 AM	None Detected	ND
B-S-WC01-18	Lunchroom	6/10/16 6:26 AM	None Detected	ND
B-S-WC01-19	Lunchroom	6/10/16 6:26 AM	None Detected	ND
B-S-WC01-20	Lunchroom	6/10/16 6:26 AM	None Detected	ND
B-S-WC02-21	Lunchroom	6/10/16 6:27 AM	None Detected	ND
B-S-WC02-22	Lunchroom	6/10/16 6:27 AM	None Detected	ND
B-S-WC02-23	Lunchroom	6/10/16 6:27 AM	None Detected	ND
B-S-WC02-24	Lunchroom	6/10/16 6:27 AM	None Detected	ND
B-S-WC02-25	Lunchroom	6/10/16 6:27 AM	None Detected	ND
2-N-F01-26	Room 212	6/10/16 6:37 AM	None Detected	ND
2-N-F01-27	Room 212	6/10/16 6:37 AM	None Detected	ND
2-N-F01-28	Room 212	6/10/16 6:37 AM	None Detected	ND
2-N-F01-29	Room 212	6/10/16 6:37 AM	None Detected	ND
2-N-F01-30	Room 212	6/10/16 6:37 AM	None Detected	ND
2-N-F02-31	Room 212	6/10/16 6:41 AM	None Detected	ND
2-N-F02-32	Room 212	6/10/16 6:41 AM	None Detected	ND
2-N-F02-33	Room 212	6/10/16 6:41 AM	None Detected	ND
2-N-F02-34	Room 212	6/10/16 6:41 AM	None Detected	ND
2-N-F02-35	Room 212	6/10/16 6:41 AM	None Detected	ND
2-N-F03-36	Room 212	6/10/16 6:43 AM	None Detected	ND
2-N-F03-37	Room 212	6/10/16 6:43 AM	None Detected	ND
2-N-F03-38	Room 212	6/10/16 6:43 AM	None Detected	ND
2-N-F03-39	Room 212	6/10/16 6:43 AM	None Detected	ND
2-N-F03-40	Room 212	6/10/16 6:43 AM	None Detected	ND
1-E-F01-41	Room 115	6/10/16 6:54 AM	None Detected	ND
1-E-F01-42	Room 115	6/10/16 6:54 AM	None Detected	ND
1-E-F01-43	Room 115	6/10/16 6:54 AM	None Detected	ND
1-E-F01-44	Room 115	6/10/16 6:54 AM	None Detected	ND
1-E-F01-45	Room 115	6/10/16 6:54 AM	None Detected	ND
1-E-WC01-46	Staff Restroom	6/10/16 6:59 AM	None Detected	ND
1-E-WC01-47	Staff Restroom	6/10/16 6:59 AM	None Detected	ND
1-E-WC01-48	Staff Restroom	6/10/16 6:59 AM	None Detected	ND
1-E-WC01-49	Staff Restroom	6/10/16 6:59 AM	None Detected	ND
1-E-WC01-50	Staff Restroom	6/10/16 6:59 AM	None Detected	ND
1-N-F01-51	Girls Restroom	6/10/16 7:05 AM	None Detected	ND
1-N-F01-52	Girls Restroom	6/10/16 7:05 AM	None Detected	ND
1-N-F01-53	Girls Restroom	6/10/16 7:05 AM	None Detected	ND
1-N-F01-54	Girls Restroom	6/10/16 7:05 AM	None Detected	ND
1-N-F01-55	Girls Restroom	6/10/16 7:05 AM	None Detected	ND

1-N-F02-56	Girls Restroom	6/10/16 7:08 AM	None Detected	ND
1-N-F02-57	Girls Restroom	6/10/16 7:08 AM	None Detected	ND
1-N-F02-58	Girls Restroom	6/10/16 7:08 AM	None Detected	ND
1-N-F02-59	Girls Restroom	6/10/16 7:08 AM	None Detected	ND
1-N-F02-60	Girls Restroom	6/10/16 7:08 AM	None Detected	ND
1-N-F03-61	Girls Restroom	6/10/16 7:11 AM	None Detected	ND
1-N-F03-62	Girls Restroom	6/10/16 7:11 AM	None Detected	ND
1-N-F03-63	Girls Restroom	6/10/16 7:11 AM	None Detected	ND
1-N-F03-64	Girls Restroom	6/10/16 7:11 AM	None Detected	ND
1-N-F03-65	Girls Restroom	6/10/16 7:11 AM	None Detected	ND

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit
 BA-Below EPA Action Level of 15 ppb
 AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations