



School Lead Water Testing - Data Collection Form

School Short Name **Brentano**
Address 2723 N. Fairfield Ave.
Facility ID 51159

Length of time water remained in pipes before sampled (hours) 13.00
Report based on lab results dated 6/3/16
Date of test 05/24/16
Water last used (Time and date) Approx. 4 pm 5/20/16

School Short Name	Facility ID	Sample ID #	Sample Location	Water Last Used (Time & Date)	Sample Collection Time & Date	Length of time water remained in pipes before sampled (Hours)	Name of CCA or GSG Collector	Name-CPS Collector	Manufacturer	Test Result (ppb)	Test Results
Brentano	51159	22311-B-N-S-001	Kitchen - South Wall	5/23/16 4:00 PM	5/24/16 5:01 AM	13:01	0	n/a	n/a	0.440	BA
Brentano	51159	22311-B-N-S-002	Kitchen South Wall	5/23/16 4:00 PM	5/24/16 5:02 AM	13:02	0	n/a	n/a	0.600	BA
Brentano	51159	22311-B-N-S-003	Kitchen South Wall	5/23/16 4:00 PM	5/24/16 5:03 AM	13:03	0	n/a	n/a	0.366	BA
Brentano	51159	22311-B-N-S-004	Kitchen South Wall	5/23/16 4:00 PM	5/24/16 5:04 AM	13:04	0	n/a	n/a	0.586	BA
Brentano	51159	22311-B-N-S-005	Kitchen South Wall	5/23/16 4:00 PM	5/24/16 5:05 AM	13:05	0	n/a	n/a	0.594	BA
Brentano	51159	22311-B-E-S-001	Kitchen - East Wall	5/23/16 4:00 PM	5/24/16 5:10 AM	13:10	0	n/a	n/a	39.100	AA
Brentano	51159	22311-B-E-S-002	Kitchen - East Wall	5/23/16 4:00 PM	5/24/16 5:12 AM	13:12	0	n/a	n/a	55.600	AA
Brentano	51159	22311-B-E-S-003	Kitchen - East Wall	5/23/16 4:00 PM	5/24/16 5:12 AM	13:12	0	n/a	n/a	5.780	BA
Brentano	51159	22311-B-E-S-004	Kitchen - East Wall	5/23/16 4:00 PM	5/24/16 5:13 AM	13:13	0	n/a	n/a	5.140	BA
Brentano	51159	22311-B-E-S-005	Kitchen - East Wall	5/23/16 4:00 PM	5/24/16 5:15 AM	13:15	0	n/a	n/a	2.500	BA
Brentano	51159	22311-B-N1-F-001	Basement South Corridor	5/23/16 4:00 PM	5/24/16 5:25 AM	13:25	0	n/a	n/a	16.600	AA
Brentano	51159	22311-B-N1-F-002	Basement South Corridor	5/23/16 4:00 PM	5/24/16 5:27 AM	13:27	0	n/a	n/a	8.460	BA
Brentano	51159	22311-B-N1-F-003	Basement South Corridor	5/23/16 4:00 PM	5/24/16 5:27 AM	13:27	0	n/a	n/a	4.520	BA
Brentano	51159	22311-B-N1-F-004	Basement South Corridor	5/23/16 4:00 PM	5/24/16 5:28 AM	13:28	0	n/a	n/a	2.200	BA
Brentano	51159	22311-B-N1-F-005	Basement South Corridor	5/23/16 4:00 PM	5/24/16 5:28 AM	13:28	0	n/a	n/a	1.260	BA
Brentano	51159	22311-1-N2-S-001	Pre-K Room 105	5/23/16 4:00 PM	5/24/16 5:35 AM	13:35	0	n/a	n/a	0.665	BA
Brentano	51159	22311-1-N2-S-002	Pre-K Room 105	5/23/16 4:00 PM	5/24/16 5:36 AM	13:36	0	n/a	n/a	0.682	BA
Brentano	51159	22311-1-N2-S-003	Pre-K Room 105	5/23/16 4:00 PM	5/24/16 5:36 AM	13:36	0	n/a	n/a	0.216	BA
Brentano	51159	22311-1-N2-S-004	Pre-K Room 105	5/23/16 4:00 PM	5/24/16 5:37 AM	13:37	0	n/a	n/a	0.121	BA
Brentano	51159	22311-1-N2-S-005	Pre-K Room 105	5/23/16 4:00 PM	5/24/16 5:37 AM	13:37	0	n/a	n/a	<0.120	ND
Brentano	51159	22311-1-N3-S-001	Pre-K Room 113	5/23/16 4:00 PM	5/24/16 5:40 AM	13:40	0	n/a	n/a	8.100	BA
Brentano	51159	22311-1-N3-S-002	Pre-K Room 113	5/23/16 4:00 PM	5/24/16 5:41 AM	13:41	0	n/a	n/a	3.190	BA
Brentano	51159	22311-1-N3-S-003	Pre-K Room 113	5/23/16 4:00 PM	5/24/16 5:43 AM	13:43	0	n/a	n/a	1.310	BA
Brentano	51159	22311-1-N3-S-004	Pre-K Room 113	5/23/16 4:00 PM	5/24/16 5:44 AM	13:44	0	n/a	n/a	2.030	BA
Brentano	51159	22311-1-N3-S-005	Pre-K Room 113	5/23/16 4:00 PM	5/24/16 5:45 AM	13:45	0	n/a	n/a	1.600	BA
Brentano	51159	22311-1-N4-F-001	1st Floor Corridor by Room 113	5/23/16 4:00 PM	5/24/16 5:47 AM	13:47	0	n/a	n/a	<0.120	ND
Brentano	51159	22311-1-N4-F-002	1st Floor Corridor by Room 113	5/23/16 4:00 PM	5/24/16 5:47 AM	13:47	0	n/a	n/a	<0.120	ND
Brentano	51159	22311-1-N4-F-003	1st Floor Corridor by Room 113	5/23/16 4:00 PM	5/24/16 5:48 AM	13:48	0	n/a	n/a	0.257	BA
Brentano	51159	22311-1-N4-F-004	1st Floor Corridor by Room 113	5/23/16 4:00 PM	5/24/16 5:48 AM	13:48	0	n/a	n/a	0.354	BA
Brentano	51159	22311-1-N4-F-005	1st Floor Corridor by Room 113	5/23/16 4:00 PM	5/24/16 5:50 AM	13:50	0	n/a	n/a	0.396	BA
Brentano	51159	22311-1-N1-F-001	1st Floor Corridor by Room 103	5/23/16 4:00 PM	5/24/16 5:51 AM	13:51	0	n/a	n/a	0.348	BA
Brentano	51159	22311-1-N1-F-002	1st Floor Corridor by Room 103	5/23/16 4:00 PM	5/24/16 5:52 AM	13:52	0	n/a	n/a	0.539	BA
Brentano	51159	22311-1-N1-F-003	1st Floor Corridor by Room 103	5/23/16 4:00 PM	5/24/16 5:52 AM	13:52	0	n/a	n/a	0.697	BA
Brentano	51159	22311-1-N1-F-004	1st Floor Corridor by Room 103	5/23/16 4:00 PM	5/24/16 5:53 AM	13:53	0	n/a	n/a	0.794	BA
Brentano	51159	22311-1-N1-F-005	1st Floor Corridor by Room 103	5/23/16 4:00 PM	5/24/16 5:54 AM	13:54	0	n/a	n/a	0.851	BA
Brentano	51159	22311-2-N-F-001	2nd Floor Corridor by Room 213	5/23/16 4:00 PM	5/24/16 6:02 AM	14:02	0	n/a	n/a	0.827	BA
Brentano	51159	22311-2-N-F-002	2nd Floor Corridor by Room 213	5/23/16 4:00 PM	5/24/16 6:03 AM	14:03	0	n/a	n/a	0.658	BA
Brentano	51159	22311-2-N-F-003	2nd Floor Corridor by Room 213	5/23/16 4:00 PM	5/24/16 6:05 AM	14:05	0	n/a	n/a	0.659	BA
Brentano	51159	22311-2-N-F-004	2nd Floor Corridor by Room 213	5/23/16 4:00 PM	5/24/16 6:05 AM	14:05	0	n/a	n/a	0.644	BA
Brentano	51159	22311-2-N-F-005	2nd Floor Corridor by Room 213	5/23/16 4:00 PM	5/24/16 6:07 AM	14:07	0	n/a	n/a	0.623	BA
Brentano	51159	22311-2-N1-F-001	2nd Floor Corridor by Room 203	5/23/16 4:00 PM	5/24/16 6:10 AM	14:10	0	n/a	n/a	0.584	BA
Brentano	51159	22311-2-N1-F-002	2nd Floor Corridor by Room 203	5/23/16 4:00 PM	5/24/16 6:12 AM	14:12	0	n/a	n/a	0.469	BA
Brentano	51159	22311-2-N1-F-003	2nd Floor Corridor by Room 203	5/23/16 4:00 PM	5/24/16 6:12 AM	14:12	0	n/a	n/a	0.432	BA
Brentano	51159	22311-2-N1-F-004	2nd Floor Corridor by Room 203	5/23/16 4:00 PM	5/24/16 6:13 AM	14:13	0	n/a	n/a	0.328	BA
Brentano	51159	22311-2-N1-F-005	2nd Floor Corridor by Room 203	5/23/16 4:00 PM	5/24/16 6:15 AM	14:15	0	n/a	n/a	0.285	BA
Brentano	51159	22311-3-N2-F-001	3rd Floor Corridor by Room 313	5/23/16 4:00 PM	5/24/16 6:25 AM	14:25	0	n/a	n/a	1.500	BA
Brentano	51159	22311-3-N2-F-002	3rd Floor Corridor by Room 313	5/23/16 4:00 PM	5/24/16 6:27 AM	14:27	0	n/a	n/a	1.400	BA
Brentano	51159	22311-3-N2-F-003	3rd Floor Corridor by Room 313	5/23/16 4:00 PM	5/24/16 6:27 AM	14:27	0	n/a	n/a	1.130	BA
Brentano	51159	22311-3-N2-F-004	3rd Floor Corridor by Room 313	5/23/16 4:00 PM	5/24/16 6:29 AM	14:29	0	n/a	n/a	1.100	BA
Brentano	51159	22311-3-N2-F-005	3rd Floor Corridor by Room 313	5/23/16 4:00 PM	5/24/16 6:30 AM	14:30	0	n/a	n/a	1.010	BA
Brentano	51159	22311-3-N1-F-001	3rd Floor Corridor by Room 303	5/23/16 4:00 PM	5/24/16 6:35 AM	14:35	0	n/a	n/a	0.567	BA
Brentano	51159	22311-3-N1-F-002	3rd Floor Corridor by Room 303	5/23/16 4:00 PM	5/24/16 6:37 AM	14:37	0	n/a	n/a	0.280	BA
Brentano	51159	22311-3-N1-F-003	3rd Floor Corridor by Room 303	5/23/16 4:00 PM	5/24/16 6:39 AM	14:39	0	n/a	n/a	0.222	BA
Brentano	51159	22311-3-N1-F-004	3rd Floor Corridor by Room 303	5/23/16 4:00 PM	5/24/16 6:40 AM	14:40	0	n/a	n/a	0.247	BA
Brentano	51159	22311-3-N1-F-005	3rd Floor Corridor by Room 303	5/23/16 4:00 PM	5/24/16 6:42 AM	14:42	0	n/a	n/a	0.229	BA

School Short Name	Facility ID	Sample ID #	Sample Location	Water Last Used (Time & Date)	Sample Collection Time & Date	Length of time water remained in pipes before sampled (Hours)	Name of CCA or GSG Collector	Name-CPS Collector	Manufacturer	Test Result (ppb)	Test Results
-------------------	-------------	-------------	-----------------	----------------------------------	----------------------------------	--	---------------------------------	-----------------------	--------------	-------------------	--------------

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND
ND-Not Detected at the Reporting Limit
BA-Below EPA Action Level of 15 ppb
AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations