



October 3, 2016

Dear LaSalle families,

In light of national events that have brought increased attention to the issue of water quality, the City of Chicago announced several additional precautionary measures that will be added to the City's water testing protocol, continuing the City's track record of complying with current state and federal regulations as well as exceeding industry standards.

As part of this announcement, Chicago Public Schools (CPS) began testing the water for levels of lead from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe. Schools are being tested based on a priority criteria that includes the age of the school, age of the students (with priority given to schools with pre-K programs), presence of a kitchen (where meals are prepared) and presence of pipes that could need repairs or replacement.

The results of all the schools are coming in on a rolling basis, and the majority have had levels under the EPA's action level of 15 parts per billion (ppb). At LaSalle samples were tested from 14 sites and the water sampled from a drinking fountain and sink were above the action level of 15 ppb: A drinking fountain on the first floor outside of the lunchroom, and a sink on the first floor inside Room 102. The water from the sink and fountain have been turned off and remediation plans are being created.

Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why only two of the samples at LaSalle returned with elevated results – the issue is not system-wide, but is specific to the fixtures or pipes for that sink and fountain and will be addressed through the remediation plan. The full results of every school's water samples can be found online at cps.edu/leadtesting.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

Forrest Claypool
CEO, Chicago Public Schools

Dr. Julie Morita
Commissioner, Chicago Department of Public Health



3 de octubre de 2016

Estimadas familias de la escuela LaSalle,

Ante recientes eventos nacionales que han aumentado la atención sobre el tema de la calidad del agua, la ciudad de Chicago anunció varias medidas de precaución adicionales que se sumarán al protocolo de la ciudad sobre control del agua, en cumplimiento de las regulaciones estatales y federales, así como de los estándares industriales

Como parte de este anuncio, las Escuelas Públicas de Chicago (CPS) comenzaron a examinar los niveles de plomo en el agua de las escuelas de todo el distrito. Nuestra prioridad máxima es la salud y seguridad de los estudiantes y del personal, y estas pruebas se iniciaron como precaución para estar seguros de la calidad del agua de las escuelas. Las pruebas se realizan según un criterio de prioridad que incluye la edad del edificio, edad de los estudiantes (con prioridad para las escuelas con programas de preescolares), la presencia de una cocina (donde se preparan alimentos) y de cañerías que puedan necesitar reparación o reemplazo.

Los resultados de todas las escuelas se han ido conociendo, y la mayoría registró niveles por debajo del nivel de acción de EPA que es de 15 partículas por billón (ppb). En LaSalle se tomaron muestras en 14 lugares y el agua de un bebedero y de una pileta tenía rastros de plomo por encima del nivel de acción de 15 ppb: un bebedero del primer piso, afuera de la cafetería, y una pileta del primer piso, dentro del salón 102. El suministro de agua fue interrumpido y se están creando planes para remediar la situación.

El agua de Chicago no tiene plomo cuando sale de la planta de tratamiento. Sin embargo, se puede encontrar en algunas cañerías internas y materiales, y el plomo encontrado en el agua potable es provocado usualmente por la corrosión de las cañerías. Esto explica por qué solamente dos de las muestras de LaSalle registraron niveles elevados. Este no es problema general sino específico de las cañerías y será solucionado. Los resultados completos de cada escuela se pueden ver en línea en cps.edu/leadtesting.

Los lineamientos federales indican que los niños menores de seis años son los que corren mayores riesgos con la exposición al plomo, algo que puede ocurrir de varias fuentes, incluyendo pintura, tierra y algunos productos de consumo. Si están preocupados por la posible exposición de su hijo al plomo, el Departamento de Salud Pública de la ciudad de Chicago (CDPH) recomienda visitar a su pediatra o a alguno de los centros de salud listados en el material adjunto, para una prueba. Además, la línea directa del CDPH puede responder cualquier pregunta que tengan, o ayudarlos a decidir si su niño debe ser examinado; por preguntas o más información, llame por favor al 312-747-5323. Por información adicional sobre el plomo y los niños, visite www.cdc.gov/lead.

La seguridad de sus hijos es nuestra principal prioridad, y hacemos todo lo que está en nuestro poder para resolver esta situación de una manera rápida y rigurosa. Continuaremos informándoles sobre este proceso.

Atentamente,



Forrest Claypool
CEO, Escuelas Públicas de Chicago



Dra. Julie Morita, Comisionada
Departamento de Salud Pública de Chicago



School Lead Water Testing - Data Collection Form

School Short Name

LaSalle

Date of test

09/21/16

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
52615-1-KIT-KS01-001	Main- Kitchen, North Sink	9/21/16 6:00 AM	<2.0	ND
52615-1-KIT-KS01-002	Main- Kitchen, North Sink	9/21/16 6:00 AM	<2.0	ND
52615-1-KIT-KS01-003	Main- Kitchen, North Sink	9/21/16 6:00 AM	<2.0	ND
52615-1-KIT-KS01-004	Main- Kitchen, North Sink	9/21/16 6:00 AM	<2.0	ND
52615-1-KIT-KS01-005	Main- Kitchen, North Sink	9/21/16 6:00 AM	<2.0	ND
52615-1-KIT-KS02-001	Main- Kitchen, Center Sink	9/21/16 6:00 AM	<2.0	ND
52615-1-KIT-KS02-002	Main- Kitchen, Center Sink	9/21/16 6:00 AM	<2.0	ND
52615-1-KIT-KS02-003	Main- Kitchen, Center Sink	9/21/16 6:00 AM	<2.0	ND
52615-1-KIT-KS02-004	Main- Kitchen, Center Sink	9/21/16 6:00 AM	<2.0	ND
52615-1-KIT-KS02-005	Main- Kitchen, Center Sink	9/21/16 6:00 AM	<2.0	ND
52615-1-KIT-KS03-001	Main- Kitchen, South Sink	9/21/16 6:00 AM	<2.0	ND
52615-1-KIT-KS03-002	Main- Kitchen, South Sink	9/21/16 6:00 AM	<2.0	ND
52615-1-KIT-KS03-003	Main- Kitchen, South Sink	9/21/16 6:00 AM	<2.0	ND
52615-1-KIT-KS03-004	Main- Kitchen, South Sink	9/21/16 6:00 AM	<2.0	ND
52615-1-KIT-KS03-005	Main- Kitchen, South Sink	9/21/16 6:00 AM	<2.0	ND
52615-1-HAL-F04-001	Main- Outside Restrooms, North Fountain	9/21/16 6:00 AM	<2.0	ND
52615-1-HAL-F04-002	Main- Outside Restrooms, North Fountain	9/21/16 6:00 AM	<2.0	ND
52615-1-HAL-F04-003	Main- Outside Restrooms, North Fountain	9/21/16 6:00 AM	<2.0	ND
52615-1-HAL-F04-004	Main- Outside Restrooms, North Fountain	9/21/16 6:00 AM	<2.0	ND
52615-1-HAL-F04-005	Main- Outside Restrooms, North Fountain	9/21/16 6:00 AM	<2.0	ND
52615-1-HAL-F05-001	Main- Outside Restrooms, South Fountain	9/21/16 6:00 AM	<2.0	ND
52615-1-HAL-F05-002	Main- Outside Restrooms, South Fountain	9/21/16 6:00 AM	<2.0	ND
52615-1-HAL-F05-003	Main- Outside Restrooms, South Fountain	9/21/16 6:00 AM	<2.0	ND
52615-1-HAL-F05-004	Main- Outside Restrooms, South Fountain	9/21/16 6:00 AM	<2.0	ND
52615-1-HAL-F05-005	Main- Outside Restrooms, South Fountain	9/21/16 6:00 AM	<2.0	ND
52615-1-HAL-F06-001	Main- Outside Girls Toilets, East Fountain	9/21/16 6:00 AM	<2.0	ND
52615-1-HAL-F06-002	Main- Outside Girls Toilets, East Fountain	9/21/16 6:00 AM	<2.0	ND
52615-1-HAL-F06-003	Main- Outside Girls Toilets, East Fountain	9/21/16 6:00 AM	<2.0	ND
52615-1-HAL-F06-004	Main- Outside Girls Toilets, East Fountain	9/21/16 6:00 AM	<2.0	ND
52615-1-HAL-F06-005	Main- Outside Girls Toilets, East Fountain	9/21/16 6:00 AM	<2.0	ND
52615-1-HAL-F07-001	Main- Outside Girls Toilets, West Fountain	9/21/16 6:00 AM	<2.0	ND
52615-1-HAL-F07-002	Main- Outside Girls Toilets, West Fountain	9/21/16 6:00 AM	<2.0	ND
52615-1-HAL-F07-003	Main- Outside Girls Toilets, West Fountain	9/21/16 6:00 AM	<2.0	ND
52615-1-HAL-F07-004	Main- Outside Girls Toilets, West Fountain	9/21/16 6:00 AM	<2.0	ND
52615-1-HAL-F07-005	Main- Outside Girls Toilets, West Fountain	9/21/16 6:00 AM	<2.0	ND
52615-1-HAL-F08-001	Main- Outside Lunchroom, East Fountain	9/21/16 6:00 AM	310	AA
52615-1-HAL-F08-002	Main- Outside Lunchroom, East Fountain	9/21/16 6:00 AM	130	AA
52615-1-HAL-F08-003	Main- Outside Lunchroom, East Fountain	9/21/16 6:00 AM	230	AA
52615-1-HAL-F08-004	Main- Outside Lunchroom, East Fountain	9/21/16 6:00 AM	280	AA
52615-1-HAL-F08-005	Main- Outside Lunchroom, East Fountain	9/21/16 6:00 AM	110	AA
52615-1-HAL-F09-001	Main- Outside Lunchroom, West Fountain	9/21/16 6:00 AM	<2.0	ND
52615-1-HAL-F09-002	Main- Outside Lunchroom, West Fountain	9/21/16 6:00 AM	<2.0	ND

52615-1-HAL-F09-003	Main- Outside Lunchroom, West Fountain	9/21/16 6:00 AM	<2.0	ND
52615-1-HAL-F09-004	Main- Outside Lunchroom, West Fountain	9/21/16 6:00 AM	2.5	BA
52615-1-HAL-F09-005	Main- Outside Lunchroom, West Fountain	9/21/16 6:00 AM	2.7	BA
52615-1-102-S10-001	Main- Inside Room 102, Sink	9/21/16 6:00 AM	21	AA
52615-1-102-S10-002	Main- Inside Room 102, Sink	9/21/16 6:00 AM	18	AA
52615-1-102-S10-003	Main- Inside Room 102, Sink	9/21/16 6:00 AM	19	AA
52615-1-102-S10-004	Main- Inside Room 102, Sink	9/21/16 6:00 AM	23	AA
52615-1-102-S10-005	Main- Inside Room 102, Sink	9/21/16 6:00 AM	6.5	BA
52615-1-102-F11-001	Main- Inside Room 102, Fountain	9/21/16 6:00 AM	8.8	BA
52615-1-102-F11-002	Main- Inside Room 102, Fountain	9/21/16 6:00 AM	3	BA
52615-1-102-F11-003	Main- Inside Room 102, Fountain	9/21/16 6:00 AM	2.7	BA
52615-1-102-F11-004	Main- Inside Room 102, Fountain	9/21/16 6:00 AM	2.2	BA
52615-1-102-F11-005	Main- Inside Room 102, Fountain	9/21/16 6:00 AM	2.1	BA
52615-1-100-S12-001	Main- Inside Room 100, Sink	9/21/16 6:00 AM	11	BA
52615-1-100-S12-002	Main- Inside Room 100, Sink	9/21/16 6:00 AM	5.3	BA
52615-1-100-S12-003	Main- Inside Room 100, Sink	9/21/16 6:00 AM	6	BA
52615-1-100-S12-004	Main- Inside Room 100, Sink	9/21/16 6:00 AM	3.6	BA
52615-1-100-S12-005	Main- Inside Room 100, Sink	9/21/16 6:00 AM	2.8	BA
52615-2-HAL-F01-001	Main- 2nd Floor Outside Restrooms, North Fountain	9/21/16 6:00 AM	<2.0	ND
52615-2-HAL-F01-002	Main- 2nd Floor Outside Restrooms, North Fountain	9/21/16 6:00 AM	<2.0	ND
52615-2-HAL-F01-003	Main- 2nd Floor Outside Restrooms, North Fountain	9/21/16 6:00 AM	<2.0	ND
52615-2-HAL-F01-004	Main- 2nd Floor Outside Restrooms, North Fountain	9/21/16 6:00 AM	<2.0	ND
52615-2-HAL-F01-005	Main- 2nd Floor Outside Restrooms, North Fountain	9/21/16 6:00 AM	<2.0	ND
52615-2-HAL-F02-001	Main- 2nd Floor Outside Restrooms, South Fountain	9/21/16 6:00 AM	<2.0	ND
52615-2-HAL-F02-002	Main- 2nd Floor Outside Restrooms, South Fountain	9/21/16 6:00 AM	<2.0	ND
52615-2-HAL-F02-003	Main- 2nd Floor Outside Restrooms, South Fountain	9/21/16 6:00 AM	<2.0	ND
52615-2-HAL-F02-004	Main- 2nd Floor Outside Restrooms, South Fountain	9/21/16 6:00 AM	<2.0	ND
52615-2-HAL-F02-005	Main- 2nd Floor Outside Restrooms, South Fountain	9/21/16 6:00 AM	<2.0	ND

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit

BA-Below EPA Action Level of 15 ppb

AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations