



School Lead Water Testing - Data Collection Form

School Short Name **James Shields Elementary**

Length of time water remained in pipes before sampled (hours) 13.00
Report based on lab results dated 6/14/16
Date of test 05/27/16
Water last used (Time and date) Approx 4 PM 5/26/16

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
51333-3-E-F01-001	Fountain Outside room 306	5/27/16 5:00 AM	0.13	BA
51333-3-E-F01-002	Fountain Outside room 306	5/27/16 5:00 AM	0.186	BA
51333-3-E-F01-003	Fountain Outside room 306	5/27/16 5:00 AM	0.253	BA
51333-3-E-F01-004	Fountain Outside room 306	5/27/16 5:00 AM	0.315	BA
51333-3-E-F01-005	Fountain Outside room 306	5/27/16 5:00 AM	0.369	BA
51333-1-E-F01-001	Fountain Outside room 106	5/27/16 5:00 AM	0.134	BA
51333-1-E-F01-002	Fountain Outside room 106	5/27/16 5:00 AM	0.164	BA
51333-1-E-F01-003	Fountain Outside room 106	5/27/16 5:00 AM	0.255	BA
51333-1-E-F01-004	Fountain Outside room 106	5/27/16 5:00 AM	0.3	BA
51333-1-E-F01-005	Fountain Outside room 106	5/27/16 5:00 AM	0.318	BA
51333-B-E-S01-001	Kitchen Sink	5/27/16 5:00 AM	0.357	BA
51333-B-E-S01-002	Kitchen Sink	5/27/16 5:00 AM	0.407	BA
51333-B-E-S01-003	Kitchen Sink	5/27/16 5:00 AM	0.442	BA
51333-B-E-S01-004	Kitchen Sink	5/27/16 5:00 AM	0.529	BA
51333-B-E-S01-005	Kitchen Sink	5/27/16 5:00 AM	0.517	BA
51333-B-E-F02-001	Fountain Outside Girls Toilet	5/27/16 5:00 AM	1.6	BA
51333-B-E-F02-002	Fountain Outside Girls Toilet	5/27/16 5:00 AM	1.28	BA
51333-B-E-F02-003	Fountain Outside Girls Toilet	5/27/16 5:00 AM	1.19	BA
51333-B-E-F02-004	Fountain Outside Girls Toilet	5/27/16 5:00 AM	0.87	BA
51333-B-E-F02-005	Fountain Outside Girls Toilet	5/27/16 5:00 AM	0.757	BA
51333-B-E-F03-001	(2) Fountain Outside Girls Toilet	5/27/16 5:00 AM	0.544	BA
51333-B-E-F03-002	(2) Fountain Outside Girls Toilet	5/27/16 5:00 AM	0.376	BA
51333-B-E-F03-003	(2) Fountain Outside Girls Toilet	5/27/16 5:00 AM	0.486	BA
51333-B-E-F03-004	(2) Fountain Outside Girls Toilet	5/27/16 5:00 AM	1.29	BA
51333-B-E-F03-005	(2) Fountain Outside Girls Toilet	5/27/16 5:00 AM	0.368	BA
51333-B-W-F04-001	Fountain near Assembly stage	5/27/16 5:00 AM	1.11	BA
51333-B-W-F04-002	Fountain near Assembly stage	5/27/16 5:00 AM	0.901	BA
51333-B-W-F04-003	Fountain near Assembly stage	5/27/16 5:00 AM	0.408	BA
51333-B-W-F04-004	Fountain near Assembly stage	5/27/16 5:00 AM	0.403	BA
51333-B-W-F04-005	Fountain near Assembly stage	5/27/16 5:00 AM	0.35	BA
51333-B-W-F06-001	(2) Fountain near Assembly stage	5/27/16 5:00 AM	0.727	BA
51333-B-W-F06-002	(2) Fountain near Assembly stage	5/27/16 5:00 AM	0.837	BA
51333-B-W-F06-003	(2) Fountain near Assembly stage	5/27/16 5:00 AM	0.673	BA
51333-B-W-F06-004	(2) Fountain near Assembly stage	5/27/16 5:00 AM	0.68	BA
51333-B-W-F06-005	(2) Fountain near Assembly stage	5/27/16 5:00 AM	0.477	BA
51333-1-E-S02-001	Annex Sink Kindergarten room 124	5/27/16 5:00 AM	0.24	BA
51333-1-E-S02-002	Annex Sink Kindergarten room 124	5/27/16 5:00 AM	0.591	BA
51333-1-E-S02-003	Annex Sink Kindergarten room 124	5/27/16 5:00 AM	0.705	BA
51333-1-E-S02-004	Annex Sink Kindergarten room 124	5/27/16 5:00 AM	0.594	BA
51333-1-E-S02-005	Annex Sink Kindergarten room 124	5/27/16 5:00 AM	0.742	BA
51333-1-E-S03-001	Annex Sink (2) Kindergarten room 124	5/27/16 5:00 AM	2.76	BA
51333-1-E-S03-002	Annex Sink (2) Kindergarten room 124	5/27/16 5:00 AM	3.28	BA
51333-1-E-S03-003	Annex Sink (2) Kindergarten room 124	5/27/16 5:00 AM	3.18	BA
51333-1-E-S03-004	Annex Sink (2) Kindergarten room 124	5/27/16 5:00 AM	2.83	BA
51333-1-E-S03-005	Annex Sink (2) Kindergarten room 124	5/27/16 5:00 AM	2.33	BA
51333-1-C-S04-001	Annex Sink Kindergarten room 123	5/27/16 5:00 AM	2.02	BA
51333-1-C-S04-002	Annex Sink Kindergarten room 123	5/27/16 5:00 AM	0.289	BA
51333-1-C-S04-003	Annex Sink Kindergarten room 123	5/27/16 5:00 AM	0.494	BA
51333-1-C-S04-004	Annex Sink Kindergarten room 123	5/27/16 5:00 AM	0.279	BA
51333-1-C-S04-005	Annex Sink Kindergarten room 123	5/27/16 5:00 AM	0.432	BA
51333-1-C-S05-001	Annex Sink (2) Kindergarten room 123	5/27/16 5:00 AM	2.29	BA
51333-1-C-S05-002	Annex Sink (2) Kindergarten room 123	5/27/16 5:00 AM	0.669	BA
51333-1-C-S05-003	Annex Sink (2) Kindergarten room 123	5/27/16 5:00 AM	0.44	BA
51333-1-C-S05-004	Annex Sink (2) Kindergarten room 123	5/27/16 5:00 AM	0.421	BA
51333-1-C-S05-005	Annex Sink (2) Kindergarten room 123	5/27/16 5:00 AM	0.285	BA
51333-1-W-S06-001	Annex Sink Kindergarten room 122	5/27/16 5:00 AM	1.97	BA
51333-1-W-S06-002	Annex Sink Kindergarten room 122	5/27/16 5:00 AM	0.829	BA
51333-1-W-S06-003	Annex Sink Kindergarten room 122	5/27/16 5:00 AM	0.783	BA
51333-1-W-S06-004	Annex Sink Kindergarten room 122	5/27/16 5:00 AM	0.564	BA
51333-1-W-S06-005	Annex Sink Kindergarten room 122	5/27/16 5:00 AM	0.21	BA
51333-1-W-S07-001	Annex Sink (2) Kindergarten room 122	5/27/16 5:00 AM	2.37	BA
51333-1-W-S07-002	Annex Sink (2) Kindergarten room 122	5/27/16 5:00 AM	0.66	BA
51333-1-W-S07-003	Annex Sink (2) Kindergarten room 122	5/27/16 5:00 AM	0.48	BA
51333-1-W-S07-004	Annex Sink (2) Kindergarten room 122	5/27/16 5:00 AM	0.512	BA
51333-1-W-S07-005	Annex Sink (2) Kindergarten room 122	5/27/16 5:00 AM	0.704	BA
51333-1-W-F08-001	Annex Fountain Across from room 122	5/27/16 5:00 AM	<0.120	ND
51333-1-W-F08-002	Annex Fountain Across from room 122	5/27/16 5:00 AM	<0.120	ND
51333-1-W-F08-003	Annex Fountain Across from room 122	5/27/16 5:00 AM	0.174	BA
51333-1-W-F08-004	Annex Fountain Across from room 122	5/27/16 5:00 AM	<0.120	ND
51333-1-W-F08-005	Annex Fountain Across from room 122	5/27/16 5:00 AM	<0.120	ND
51333-1-W-F09-001	Annex Fountain (2) Across from room 122	5/27/16 5:00 AM	0.186	BA
51333-1-W-F09-002	Annex Fountain (2) Across from room 122	5/27/16 5:00 AM	0.82	BA
51333-1-W-F09-003	Annex Fountain (2) Across from room 122	5/27/16 5:00 AM	0.184	BA
51333-1-W-F09-004	Annex Fountain (2) Across from room 122	5/27/16 5:00 AM	0.137	BA
51333-1-W-F09-005	Annex Fountain (2) Across from room 122	5/27/16 5:00 AM	0.126	BA
51333-1-W-S10-001	Annex Sink kindergarten room 121	5/27/16 5:00 AM	0.416	BA
51333-1-W-S10-002	Annex Sink kindergarten room 121	5/27/16 5:00 AM	0.201	BA
51333-1-W-S10-003	Annex Sink kindergarten room 121	5/27/16 5:00 AM	0.238	BA
51333-1-W-S10-004	Annex Sink kindergarten room 121	5/27/16 5:00 AM	0.286	BA
51333-1-W-S10-005	Annex Sink kindergarten room 121	5/27/16 5:00 AM	0.211	BA
51333-1-W-S11-001	Annex Sink (2) Kindergarten room 121	5/27/16 5:00 AM	4.53	BA
51333-1-W-S11-002	Annex Sink (2) Kindergarten room 121	5/27/16 5:00 AM	1.81	BA
51333-1-W-S11-003	Annex Sink (2) Kindergarten room 121	5/27/16 5:00 AM	1.27	BA
51333-1-W-S11-004	Annex Sink (2) Kindergarten room 121	5/27/16 5:00 AM	0.989	BA
51333-1-W-S11-005	Annex Sink (2) Kindergarten room 121	5/27/16 5:00 AM	0.762	BA
51333-3-W-F01-001	Annex Fountain Across from room 322	5/27/16 5:00 AM	0.416	BA
51333-3-W-F01-002	Annex Fountain Across from room 322	5/27/16 5:00 AM	0.475	BA
51333-3-W-F01-003	Annex Fountain Across from room 322	5/27/16 5:00 AM	0.444	BA
51333-3-W-F01-004	Annex Fountain Across from room 322	5/27/16 5:00 AM	0.362	BA
51333-3-W-F01-005	Annex Fountain Across from room 322	5/27/16 5:00 AM	0.339	BA
51333-3-W-F02-001	Annex Fountain (2) Across from room 322	5/27/16 5:00 AM	0.438	BA
51333-3-W-F02-002	Annex Fountain (2) Across from room 322	5/27/16 5:00 AM	0.326	BA
51333-3-W-F02-003	Annex Fountain (2) Across from room 322	5/27/16 5:00 AM	0.342	BA
51333-3-W-F02-004	Annex Fountain (2) Across from room 322	5/27/16 5:00 AM	0.421	BA
51333-3-W-F02-005	Annex Fountain (2) Across from room 322	5/27/16 5:00 AM	0.269	BA
51333-2-E-S01-001	Annex Sink Kindergarten room 225	5/27/16 5:00 AM	1.72	BA
51333-2-E-S01-002	Annex Sink Kindergarten room 225	5/27/16 5:00 AM	0.772	BA
51333-2-E-S01-003	Annex Sink Kindergarten room 225	5/27/16 5:00 AM	0.955	BA
51333-2-E-S01-004	Annex Sink Kindergarten room 225	5/27/16 5:00 AM	0.753	BA
51333-2-E-S01-005	Annex Sink Kindergarten room 225	5/27/16 5:00 AM	0.49	BA
51333-2-C-S02-001	Annex Sink Kindergarten room 224	5/27/16 5:00 AM	0.56	BA
51333-2-C-S02-002	Annex Sink Kindergarten room 224	5/27/16 5:00 AM	0.344	BA
51333-2-C-S02-003	Annex Sink Kindergarten room 224	5/27/16 5:00 AM	0.445	BA
51333-2-C-S02-004	Annex Sink Kindergarten room 224	5/27/16 5:00 AM	0.434	BA
51333-2-C-S02-005	Annex Sink Kindergarten room 224	5/27/16 5:00 AM	0.95	BA
51333-2-W-S03-001	Annex Sink Kindergarten room 222	5/27/16 5:00 AM	1.51	BA
51333-2-W-S03-002	Annex Sink Kindergarten room 222	5/27/16 5:00 AM	0.616	BA
51333-2-W-S03-003	Annex Sink Kindergarten room 222	5/27/16 5:00 AM	0.55	BA
51333-2-W-S03-004	Annex Sink Kindergarten room 222	5/27/16 5:00 AM	0.465	BA
51333-2-W-S03-005	Annex Sink Kindergarten room 222	5/27/16 5:00 AM	0.683	BA
51333-2-W-F04-001	Annex Fountain (1) Across from room 222	5/27/16 5:00 AM	0.191	BA
51333-2-W-F04-002	Annex Fountain (1) Across from room 222	5/27/16 5:00 AM	0.195	BA
51333-2-W-F04-003	Annex Fountain (1) Across from room 222	5/27/16 5:00 AM	<0.120	ND
51333-2-W-F04-004	Annex Fountain (1) Across from room 222	5/27/16 5:00 AM	<0.120	ND
51333-2-W-F04-005	Annex Fountain (1) Across from room 222	5/27/16 5:00 AM	<0.120	ND
51333-2-W-F05-001	Annex Fountain (2) Across from room 222	5/27/16 5:00 AM	<0.120	ND
51333-2-W-F05-002	Annex Fountain (2) Across from room 222	5/27/16 5:00 AM	<0.120	ND
51333-2-W-F05-003	Annex Fountain (2) Across from room 222	5/27/16 5:00 AM	<0.120	ND
51333-2-W-F05-004	Annex Fountain (2) Across from room 222	5/27/16 5:00 AM	<0.120	ND
51333-2-W-F05-005	Annex Fountain (2) Across from room 222	5/27/16 5:00 AM	<0.120	ND
51333-1-E-S01-001	Annex Kitchen Sink	5/27/16 5:00 AM	0.498	BA
51333-1-E-S01-002	Annex Kitchen Sink	5/27/16 5:00 AM	0.489	BA
51333-1-E-S01-003	Annex Kitchen Sink	5/27/16 5:00 AM	0.151	BA
51333-1-E-S01-004	Annex Kitchen Sink	5/27/16 5:00 AM	0.141	BA
51333-1-E-S01-005	Annex Kitchen Sink	5/27/16 5:00 AM	0.234	BA
51333-1-C-F01-001	West Modular Fountain	5/27/16 5:00 AM	<0.120	ND
51333-1-C-F01-002	West Modular Fountain	5/27/16 5:00 AM	<0.120	ND
51333-1-C-F01-003	West Modular Fountain	5/27/16 5:00 AM	<0.120	ND
51333-1-C-F01-004	West Modular Fountain	5/27/16 5:00 AM	<0.120	ND
51333-1-C-F01-005	West Modular Fountain	5/27/16 5:00 AM	<0.120	ND
51333-1-N-F01-001	East Modular, Fountain Pre-K room 001	5/27/16 5:00 AM	1.15	BA
51333-1-N-F01-002	East Modular, Fountain Pre-K room 001	5/27/16 5:00 AM	0.373	BA
51333-1-N-F01-003	East Modular, Fountain Pre-K room 001	5/27/16 5:00 AM	0.281	BA
51333-1-N-F01-004	East Modular, Fountain Pre-K room 001	5/27/16 5:00 AM	0.272	BA
51333-1-N-F01-005	East Modular, Fountain Pre-K room 001	5/27/16 5:00 AM	0.273	BA

51333-1-N-S02-001	East Modular, Sink Pre-K room 001	5/27/16 5:00 AM	<0.120	ND
51333-1-N-S02-002	East Modular, Sink Pre-K room 001	5/27/16 5:00 AM	<0.120	ND
51333-1-N-S02-003	East Modular, Sink Pre-K room 001	5/27/16 5:00 AM	<0.120	ND
51333-1-N-S02-004	East Modular, Sink Pre-K room 001	5/27/16 5:00 AM	<0.120	ND
51333-1-N-S02-005	East Modular, Sink Pre-K room 001	5/27/16 5:00 AM	<0.120	ND
51333-1-S-F03-001	East Modular, Fountain Pre-K room 002	5/27/16 5:00 AM	0.881	BA
51333-1-S-F03-002	East Modular, Fountain Pre-K room 002	5/27/16 5:00 AM	0.306	BA
51333-1-S-F03-003	East Modular, Fountain Pre-K room 002	5/27/16 5:00 AM	0.211	BA
51333-1-S-F03-004	East Modular, Fountain Pre-K room 002	5/27/16 5:00 AM	0.202	BA
51333-1-S-F03-005	East Modular, Fountain Pre-K room 002	5/27/16 5:00 AM	0.206	BA
51333-1-S-S04-001	East Modular, Sink Pre-K room 002	5/27/16 5:00 AM	<0.120	ND
51333-1-S-S04-002	East Modular, Sink Pre-K room 002	5/27/16 5:00 AM	<0.120	ND
51333-1-S-S04-003	East Modular, Sink Pre-K room 002	5/27/16 5:00 AM	<0.120	ND
51333-1-S-S04-004	East Modular, Sink Pre-K room 002	5/27/16 5:00 AM	0.185	BA
51333-1-S-S04-005	East Modular, Sink Pre-K room 002	5/27/16 5:00 AM	<0.120	ND

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit

BA-Below EPA Action Level of 15 ppb

AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations