



School Lead Water Testing - Data Collection Form

School Short Name
Address
Facility ID

Budlong
2701 W. Foster Avenue
51050

Length of time water remained in pipes before sampled (hours)
Report based on lab results dated
Date of test
Water last used (Time and date)

13.00
6/3/16
05/26/16
Approx 4 PM 5/25/16

MEC Team Member
School Phone #

John Ivancich
(773) 534-2591

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
22391-G-S-S01-001	Ground Level Kitchen	5/26/16 5:00 AM	<0.120	ND
22391-G-S-S01-002	Ground Level Kitchen	5/26/16 5:00 AM	<0.120	ND
22391-G-S-S01-003	Ground Level Kitchen	5/26/16 5:00 AM	<0.120	ND
22391-G-S-S01-004	Ground Level Kitchen	5/26/16 5:00 AM	<0.120	ND
22391-G-S-S01-005	Ground Level Kitchen	5/26/16 5:00 AM	<0.120	ND
22391-G-N-F02-001	Ground Level Across from Room 120, Fountain 1	5/26/16 5:00 AM	3.03	BA
22391-G-N-F02-002	Ground Level Across from Room 120, Fountain 1	5/26/16 5:00 AM	2.02	BA
22391-G-N-F02-003	Ground Level Across from Room 120, Fountain 1	5/26/16 5:00 AM	1.69	BA
22391-G-N-F02-004	Ground Level Across from Room 120, Fountain 1	5/26/16 5:00 AM	1.48	BA
22391-G-N-F02-005	Ground Level Across from Room 120, Fountain 1	5/26/16 5:00 AM	1.16	BA
22391-G-N-F03-001	Ground Level Across Room 120, Fountain 2	5/26/16 5:00 AM	2.98	BA
22391-G-N-F03-002	Ground Level Across Room 120, Fountain 2	5/26/16 5:00 AM	2.22	BA
22391-G-N-F03-003	Ground Level Across Room 120, Fountain 2	5/26/16 5:00 AM	4.64	BA
22391-G-N-F03-004	Ground Level Across Room 120, Fountain 2	5/26/16 5:00 AM	1.4	BA
22391-G-N-F03-005	Ground Level Across Room 120, Fountain 2	5/26/16 5:00 AM	1.39	BA
22391-G-N-F04-001	Ground Level Across Room 120, Fountain 3	5/26/16 5:00 AM	1.63	BA
22391-G-N-F04-002	Ground Level Across Room 120, Fountain 3	5/26/16 5:00 AM	1.05	BA
22391-G-N-F04-003	Ground Level Across Room 120, Fountain 3	5/26/16 5:00 AM	0.881	BA
22391-G-N-F04-004	Ground Level Across Room 120, Fountain 3	5/26/16 5:00 AM	1.09	BA
22391-G-N-F04-005	Ground Level Across Room 120, Fountain 3	5/26/16 5:00 AM	0.882	BA
22391-G-S-F05-001	Ground Level by Entrance 9, Fountain 1	5/26/16 5:00 AM	<0.120	ND
22391-G-S-F05-002	Ground Level by Entrance 9, Fountain 1	5/26/16 5:00 AM	<0.120	ND
22391-G-S-F05-003	Ground Level by Entrance 9, Fountain 1	5/26/16 5:00 AM	<0.120	ND
22391-G-S-F05-004	Ground Level by Entrance 9, Fountain 1	5/26/16 5:00 AM	1.84	BA
22391-G-S-F05-005	Ground Level by Entrance 9, Fountain 1	5/26/16 5:00 AM	<0.120	ND
22391-G-S-F06-001	Ground Level by Entrance 9, Fountain 2	5/26/16 5:00 AM	<0.120	ND
22391-G-S-F06-002	Ground Level by Entrance 9, Fountain 2	5/26/16 5:00 AM	0.127	BA
22391-G-S-F06-003	Ground Level by Entrance 9, Fountain 2	5/26/16 5:00 AM	0.173	BA
22391-G-S-F06-004	Ground Level by Entrance 9, Fountain 2	5/26/16 5:00 AM	0.236	BA
22391-G-S-F06-005	Ground Level by Entrance 9, Fountain 2	5/26/16 5:00 AM	0.297	BA
22391-G-S-F07-001	Ground Level by Entrance 9, Fountain 3	5/26/16 5:00 AM	0.233	BA
22391-G-S-F07-002	Ground Level by Entrance 9, Fountain 3	5/26/16 5:00 AM	0.359	BA
22391-G-S-F07-003	Ground Level by Entrance 9, Fountain 3	5/26/16 5:00 AM	0.382	BA
22391-G-S-F07-004	Ground Level by Entrance 9, Fountain 3	5/26/16 5:00 AM	0.398	BA
22391-G-S-F07-005	Ground Level by Entrance 9, Fountain 3	5/26/16 5:00 AM	0.41	BA

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
22391-1-W-F01-001	1st Floor Across from Main Office, Fountain 1	5/26/16 5:00 AM	<0.120	ND
22391-1-W-F01-002	1st Floor Across from Main Office, Fountain 1	5/26/16 5:00 AM	0.162	BA
22391-1-W-F01-003	1st Floor Across from Main Office, Fountain 1	5/26/16 5:00 AM	0.133	BA
22391-1-W-F01-004	1st Floor Across from Main Office, Fountain 1	5/26/16 5:00 AM	<0.120	ND
22391-1-W-F01-005	1st Floor Across from Main Office, Fountain 1	5/26/16 5:00 AM	<0.120	ND
22391-1-W-F02-001	1st Floor Across from Main Office, Fountain 2	5/26/16 5:00 AM	<0.120	ND
22391-1-W-F02-002	1st Floor Across from Main Office, Fountain 2	5/26/16 5:00 AM	<0.120	ND
22391-1-W-F02-003	1st Floor Across from Main Office, Fountain 2	5/26/16 5:00 AM	<0.120	ND
22391-1-W-F02-004	1st Floor Across from Main Office, Fountain 2	5/26/16 5:00 AM	<0.120	ND
22391-1-W-F02-005	1st Floor Across from Main Office, Fountain 2	5/26/16 5:00 AM	<0.120	ND
22391-1-W-S03-001	1st Floor Room 105 / 106	5/26/16 5:00 AM	0.21	BA
22391-1-W-S03-002	1st Floor Room 105 / 106	5/26/16 5:00 AM	0.167	BA
22391-1-W-S03-003	1st Floor Room 105 / 106	5/26/16 5:00 AM	0.14	BA
22391-1-W-S03-004	1st Floor Room 105 / 106	5/26/16 5:00 AM	0.181	BA
22391-1-W-S03-005	1st Floor Room 105 / 106	5/26/16 5:00 AM	0.215	BA
22391-1-W-S04-001	1st Floor Room 102 / 103	5/26/16 5:00 AM	0.345	BA
22391-1-W-S04-002	1st Floor Room 102 / 103	5/26/16 5:00 AM	0.198	BA
22391-1-W-S04-003	1st Floor Room 102 / 103	5/26/16 5:00 AM	0.249	BA
22391-1-W-S04-004	1st Floor Room 102 / 103	5/26/16 5:00 AM	0.292	BA
22391-1-W-S04-005	1st Floor Room 102 / 103	5/26/16 5:00 AM	0.284	BA
22391-1-E-S05-001	1st Floor Room 108	5/26/16 5:00 AM	4.86	BA
22391-1-E-S05-002	1st Floor Room 108	5/26/16 5:00 AM	17.4	AA
22391-1-E-S05-003	1st Floor Room 108	5/26/16 5:00 AM	4.22	BA
22391-1-E-S05-004	1st Floor Room 108	5/26/16 5:00 AM	3.44	BA
22391-1-E-S05-005	1st Floor Room 108	5/26/16 5:00 AM	4.01	BA
22391-1-N-S06-001	1st Floor Room 101	5/26/16 5:00 AM	1.03	BA
22391-1-N-S06-002	1st Floor Room 101	5/26/16 5:00 AM	0.754	BA
22391-1-N-S06-003	1st Floor Room 101	5/26/16 5:00 AM	1.16	BA
22391-1-N-S06-004	1st Floor Room 101	5/26/16 5:00 AM	0.613	BA
22391-1-N-S06-005	1st Floor Room 101	5/26/16 5:00 AM	0.73	BA
22391-1-S-S07-001	1st Floor Room 102	5/26/16 5:00 AM	7.04	BA
22391-1-S-S07-002	1st Floor Room 102	5/26/16 5:00 AM	4.63	BA
22391-1-S-S07-003	1st Floor Room 102	5/26/16 5:00 AM	6.23	BA
22391-1-S-S07-004	1st Floor Room 102	5/26/16 5:00 AM	8.1	BA
22391-1-S-S07-005	1st Floor Room 102	5/26/16 5:00 AM	6.21	BA
22391-2-W-F01-001	2nd Floor Across from Room 207, Fountain 1	5/26/16 5:00 AM	0.171	BA
22391-2-W-F01-002	2nd Floor Across from Room 207, Fountain 1	5/26/16 5:00 AM	<0.120	ND
22391-2-W-F01-003	2nd Floor Across from Room 207, Fountain 1	5/26/16 5:00 AM	<0.120	ND
22391-2-W-F01-004	2nd Floor Across from Room 207, Fountain 1	5/26/16 5:00 AM	<0.120	ND
22391-2-W-F01-005	2nd Floor Across from Room 207, Fountain 1	5/26/16 5:00 AM	<0.120	ND
22391-2-W-F02-001	2nd Floor Across from Room 207, Fountain 2	5/26/16 5:00 AM	<0.120	ND
22391-2-W-F02-002	2nd Floor Across from Room 207, Fountain 2	5/26/16 5:00 AM	<0.120	ND
22391-2-W-F02-003	2nd Floor Across from Room 207, Fountain 2	5/26/16 5:00 AM	<0.120	ND
22391-2-W-F02-004	2nd Floor Across from Room 207, Fountain 2	5/26/16 5:00 AM	<0.120	ND
22391-2-W-F02-005	2nd Floor Across from Room 207, Fountain 2	5/26/16 5:00 AM	<0.120	ND
22391-3-W-F01-001	3rd Floor Across from Room 307, Fountain 1	5/26/16 5:00 AM	0.141	BA
22391-3-W-F01-002	3rd Floor Across from Room 307, Fountain 1	5/26/16 5:00 AM	0.282	BA
22391-3-W-F01-003	3rd Floor Across from Room 307, Fountain 1	5/26/16 5:00 AM	0.356	BA
22391-3-W-F01-004	3rd Floor Across from Room 307, Fountain 1	5/26/16 5:00 AM	0.383	BA
22391-3-W-F01-005	3rd Floor Across from Room 307, Fountain 1	5/26/16 5:00 AM	0.415	BA
22391-3-W-F02-001	3rd Floor Across from Room 307, Fountain 2	5/26/16 5:00 AM	0.421	BA
22391-3-W-F02-002	3rd Floor Across from Room 307, Fountain 2	5/26/16 5:00 AM	0.469	BA

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
22391-3-W-F02-003	3rd Floor Across from Room 307, Fountain 2	5/26/16 5:00 AM	0.459	BA
22391-3-W-F02-004	3rd Floor Across from Room 307, Fountain 2	5/26/16 5:00 AM	0.46	BA
22391-3-W-F02-005	3rd Floor Across from Room 307, Fountain 2	5/26/16 5:00 AM	0.441	BA

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND
ND-Not Detected at the Reporting Limit
BA-Below EPA Action Level of 15 ppb
AA-Above EPA Action Level